



**Addendum to Invitation for Bid  
Wastewater Infrastructure Installation at Hankins  
Farm Industrial Park 2561 State Highway MM**

**Addendum # 1**

**7/1/2022**

This is Addendum #1 to the Invitation for Bid, Wastewater Infrastructure Installation at Hankins Farm Industrial Park 2561 State Highway MM. Please note the bid opening date remains the same.

**Clarification in the bid document:**

1. Erosion control such as silt sock or silt fence shall be required downhill of all excavation work.
2. Fencing around the new lift station shall consist of 6ft chain link, with 3 strands barbwire arms at ~45 degrees outward on top. Gate into the lift station shall be minimum 12 ft double swing.
3. Inside lift station fencing, gravel is acceptable for surfacing.

**End of Addendum #1.**

Any questions regarding this addendum may be directed as follows:

**Garrett Brickner PE**

**Engineering Manager**

BUILDS Department

City of Republic, Missouri

417.732.3405

[gbrickner@republicmo.com](mailto:gbrickner@republicmo.com)