

Klingaman Heating & Cooling LLC  
 24727 Hope Ln  
 Richland Center, WI 53581  
 (608) 604-2866

**Estimate 1429**



|  |  |             |              |
|--|--|-------------|--------------|
| <b>ADDRESS</b>   | <b>SHIP TO</b>   | <b>DATE</b> | <b>TOTAL</b> |
| City Of Richland Center<br>450 S. Main St<br>Richland Center, WI 53581 | City Of Richland Center<br>450 S. Main St<br>Richland Center, WI 53581 | 11/26/2023  | \$3,700.00   |

| DATE       | ACTIVITY                   | DESCRIPTION  | QTY | RATE     | AMOUNT   |
|------------|----------------------------|--|-----|----------|----------|
| 11/27/2023 | <b>Furnace Replacement</b> | Police Dept Command Room<br><br>Furnace is running high co than normal. 140 ppm was my highest reading. Other furnaces on site were running around 5 ppm. This is signs of heat exchanger failure. Recommend replacing furnace.<br><br>1- Bryant 2- Stage 40,000 Btu Furnace Variable Speed Blower<br>1- Reconnect Return Drop<br>1- Plenum Transition<br>1- Drain<br>1- Venting 2"<br>1- Low Voltage<br>1- High Voltage<br>1- Gas Pipe<br>1- Misc Materials<br>1- Labor | 1   | 3,700.00 | 3,700.00 |

SUBTOTAL 3,700.00  
 TAX 0.00

**TOTAL \$3,700.00**

THANK YOU.

Accepted By

Accepted Date

Thank You For Your Business!!