

# CITY OF RICHLAND CENTER

## AGENDA ITEM DATA SHEET

---

**Agenda Items:** Police Department Command Room Furnace

**Meeting Date:** Finance Committee – February 6, 2024  
City Council – February 6, 2024

**Requested by:** Spencer Reed, Buildings and Grounds Department Lead

**Background:** It was recently learned that the existing furnace that heats the Police Department command room has an abnormally high CO2 reading. Due to the high CO2 reading Klingaman Heating and Cooling recommended replacement of the furnace.

**Financial Impact:** Requesting authorization to purchase a Bryant two stage 40,000 BTU furnace at a cost not to exceed \$3,700.

**Funding Source:** 10-51850-460 BLDG-PROP/BLDG REPAIR, budgeted for \$12,000.00.  
This project was discussed during the recent budget process. As such \$12,000 was allocated for furnace replacements.

**Requested Action:**

### **Finance**

Motion to recommend to Council to approve the purchase of a new Bryant two stage 40,000 BTU furnace from Klingaman Heating and Cooling.

### **Council**

Motion to approve the purchase of a new Bryant two stage 40,000 BTU furnace from Klingaman Heating and Cooling.

**Attachment(s):** One (1) quote from Klingaman Heating and Cooling.