



## **AGENDA MEMORANDUM**

**CONTACT:** CLIF CUSTER

**SUBJECT:** WISTERIA DRAINAGE REPAIR

### **SUMMARY:**

Wisteria St. has sustained a drainage failure in the form of a collapsed tin horn pipe that serves at the stormwater transfer line from the south side to north side of the street.

### **BACKGROUND INFORMATION:**

Within the past year complaints of stormwater backing up on Wisteria have become more frequent. Upon further investigation, a collapsed 18-inch tin horn stormwater transfer pipe was discovered in the vicinity of 319 Wisteria. Public Works attempted to clean the line utilizing Richwood's jetter trailer to promote stormwater flow only to discover that the collapse was severe enough not to allow the 4-inch culvert cleaning attachment to pass through the collapsed section of pipe.

### **ISSUE:**

If the issue is left without being repaired, it is assumed the issue will get worse over time causing further stormwater backup on Wisteria.

### **FISCAL IMPACT:**

To be discussed

### **RECOMMENDATION:**

Motion to allow Public Works to pursue a repair of the stormwater transfer line located between 319 and 314 Wisteria.

Motion to allow Public Works to pursue a repair of stormwater drainage infrastructure on Wisteria between 319 Wisteria and the East Ditch.