



Wisconsin State Laboratory of Hygiene
 2601 Agriculture Drive, PO Box 7996
 Madison, WI 53707-7996
 (800)442-4618 - Fax (608)224-6213
<http://www.slh.wisc.edu>

Laboratory Report

Environmental Health Division

WSLH Sample: 677545001

Report To:
 DALE PETERSON
 206 KIRBY ST
 RIDGEWAY, WI 53582

Invoice To:
 HAILEY ROESSLER
 208 Jarvis Street
 Suite A
 Ridgeway, WI 53582
 Customer ID: 12500873

System Name: RIDGEWAY WATERWORKS
 City: RIDGEWAY
 Collection Date/Time: 5/9/2023 10:40
 Collected By: D PETERSON
 County: 25 - Iowa
 Source Code: E - Entry Point
 Collection Address: LORAIN CT
 Location of Sample: SAMPLE TAP BEFORE
 TREATMENT

Monitor Point ID: W2
 PWS ID#: 12500873
 WI Unique Well#: BF969
 Entry Point ID: 2
 Date Received: 5/9/2023
 Date Reported: 5/18/2023
 Sample Type: D-Rout Dist Comp & FU

PFAS in DW

Analyte	Analysis Method	Result	Units	LOD	LOQ
Prep Date: 05/11/23 10:00		Analysis Date: 05/12/23 12:47			
PFBS (375-73-5)	EPA Method 537.1	<0.335	ng/L	0.335	1.12
PFHxA (307-24-4)	EPA Method 537.1	<0.477	ng/L	0.477	2.23
HFPO-DA (13252-13-6)	EPA Method 537.1	<0.493	ng/L	0.493	2.23
PFHpA (375-85-9)	EPA Method 537.1	<0.431	ng/L	0.431	2.23
PFHxS (355-46-4)	EPA Method 537.1	<0.308	ng/L	0.308	1.12
DONA (919005-14-4)	EPA Method 537.1	<0.459	ng/L	0.459	2.23
PFNA (375-95-1)	EPA Method 537.1	<0.451	ng/L	0.451	2.23
PFOS (1763-23-1)	EPA Method 537.1	<0.339	ng/L	0.339	1.12
9CI-PF3ONS (756426-58-1)	EPA Method 537.1	<0.340	ng/L	0.340	1.12
PFDA (335-76-2)	EPA Method 537.1	<0.486	ng/L	0.486	2.23
N-MeFOSAA (2355-31-9)	EPA Method 537.1	<0.344	ng/L	0.344	1.12
N-EtFOSAA (2991-50-6)	EPA Method 537.1	<0.332	ng/L	0.332	1.12
PFUnA (2058-94-8)	EPA Method 537.1	<0.466	ng/L	0.466	2.23
PFOA (335-67-1)	EPA Method 537.1	<0.466	ng/L	0.466	2.23
11CI-PF3OUdS (763051-92-9)	EPA Method 537.1	<0.326	ng/L	0.326	1.12

Environmental Health Division

WSLH Sample: 677545001

PFAS in DW

Analyte	Analysis Method	Result	Units	LOD	LOQ
Prep Date: 05/11/23 10:00		Analysis Date: 05/12/23 12:47			
PFDaA (307-55-1)	EPA Method 537.1	<0.430	ng/L	0.430	2.23
PFTTrDA (72629-94-8)	EPA Method 537.1	<0.510	ng/L	0.510	2.23
PFTeDA (376-06-7)	EPA Method 537.1	<0.447	ng/L	0.447	2.23



Environmental Health Division

WSLH Sample: 677545001

WDNR LAB ID:113133790 NELAP LAB ID:2091 EPA LAB ID:WI00007, WI00008 WI DATCP ID:105-415

List of Abbreviations:

LOD = Level of detection
LOQ = Level of quantification (for PFAS the LOQ = MRL)
ND = None detected. Results are less than the LOD
F next to result = Result is between LOD and LOQ
Z next to result = Result is between 0 (zero) and LOD
if LOD=LOQ, Limits were not statistically derived

Test results for NELAP accredited tests are certified to meet the requirements of the NELAC standards. For a list of accredited analytes see <http://www.slh.wisc.edu/about/compliance/nelac-laboratory-accreditation>
Results, LOD and LOQ values have been adjusted for analytical dilutions and percent moisture where applicable.
Results relate only to the items tested.
This Laboratory Report shall not be reproduced except in full, without written approval of the laboratory.
The water microbiology unit analyzes samples as received and not all samples are tested for preservation before analysis is performed.

Responsible Party

Inorganic Chemistry: Graham Anderson, Supervisor 608-224-6281
Metals: Graham Anderson, Supervisor 608-224-6281
Organics: Erin Mani, Supervisor 608-224-6269
Environmental Toxicology: Dawn Perkins, Supervisor 608-224-6230
Water Microbiology: Martin Collins, Supervisor 608-224-6239
Radiochemistry: Jesse Wouters, Radiochemistry Supervisor 608-224-6227