

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

## Influent Flow and Loading

### 1. Monthly Average Flows and BOD Loadings

1.1 Verify the following monthly flows and BOD loadings to your facility.

Influent No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average BOD Concentration mg/L	x	8.34	=	Influent Monthly Average BOD Loading, lbs/day
January	0.0331	x	252	x	8.34	=	70
February	0.0318	x	269	x	8.34	=	71
March	0.0371	x	263	x	8.34	=	81
April	0.0430	x	217	x	8.34	=	78
May	0.0384	x	218	x	8.34	=	70
June	0.0321	x	228	x	8.34	=	61
July	0.0288	x	310	x	8.34	=	75
August	0.0308	x	202	x	8.34	=	52
September	0.0328	x	157	x	8.34	=	43
October	0.0285	x	227	x	8.34	=	54
November	0.0314	x	207	x	8.34	=	54
December	0.0371	x	270	x	8.34	=	84

### 2. Maximum Monthly Design Flow and Design BOD Loading

2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	.114	x	90	=	0.1026
		x	100	=	.114
Design BOD, lbs/day	104	x	90	=	93.6
		x	100	=	104

2.2 Verify the number of times the flow and BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times BOD was greater than 90% of design	Number of times BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	0	0
March	1	0	0	0	0
April	1	0	0	0	0
May	1	0	0	0	0
June	1	0	0	0	0
July	1	0	0	0	0
August	1	0	0	0	0
September	1	0	0	0	0
October	1	0	0	0	0
November	1	0	0	0	0
December	1	0	0	0	0
Points per each		2	1	3	2
Exceedances		0	0	0	0
Points		0	0	0	0
<b>Total Number of Points</b>					<b>0</b>

0

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 2022

## 3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?  
 Yes Enter last calibration date (MM/DD/YYYY)

No

If No, please explain:

## 4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

Yes

No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

Yes

No

If Yes, please explain:

## 5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks

Holding Tanks

Grease Traps

Yes

Yes

Yes

No

No

No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

Yes

gallons

No

Holding Tanks

Yes

gallons

No

Grease Traps

Yes

gallons

No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

## 6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

Yes

No

If yes, describe the situation and your community's response.

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

Yes

No

If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.

--

<b>Total Points Generated</b>	0
<b>Score (100 - Total Points Generated)</b>	100
<b>Section Grade</b>	<b>A</b>

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

## Effluent Quality and Plant Performance (BOD/CBOD)

### 1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	15	13.5	7	1	0	0
February	15	13.5	6	1	0	0
March	15	13.5	4	1	0	0
April	15	13.5	4	1	0	0
May	15	13.5	6	1	0	0
June	15	13.5	4	1	0	0
July	15	13.5	5	1	0	0
August	15	13.5	3	1	0	0
September	15	13.5	4	1	0	0
October	15	13.5	3	1	0	0
November	15	13.5	8	1	0	0
December	15	13.5	19	1	1	1

\* Equals limit if limit is <= 10

Months of discharge/yr	12		
Points per each exceedance with 12 months of discharge		7	3
Exceedances		1	1
Points		7	3
<b>Total number of points</b>			<b>10</b>

10

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is  $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Prior operator wasn't using standard methods of testing, adjustments to the overall operation of the plant were made and corrected the issues.

### 2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

- Yes Enter last calibration date (MM/DD/YYYY)

2022-04-19

- No

If No, please explain:

### 3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

None

### 4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

- Yes

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

<p><input checked="" type="radio"/> No</p> <p>If Yes, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>
<p>4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test?</p> <p><input type="radio"/> Yes</p> <p><input checked="" type="radio"/> No</p> <p>If Yes, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>
<p>4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity?</p> <p><input type="radio"/> Yes</p> <p><input type="radio"/> No</p> <p><input checked="" type="radio"/> N/A</p> <p>Please explain unless not applicable:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>

<b>Total Points Generated</b>	10
<b>Score (100 - Total Points Generated)</b>	90
<b>Section Grade</b>	<b>B</b>

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

## Effluent Quality and Plant Performance (Total Suspended Solids)

### 1. Effluent Total Suspended Solids Results

1.1 Verify the following monthly average effluent values, exceedances, and points for TSS:

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit >10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	15	13.5	9	1	0	0
February	15	13.5	7	1	0	0
March	15	13.5	4	1	0	0
April	15	13.5	2	1	0	0
May	15	13.5	7	1	0	0
June	15	13.5	3	1	0	0
July	15	13.5	6	1	0	0
August	15	13.5	4	1	0	0
September	15	13.5	11	1	0	0
October	15	13.5	6	1	0	0
November	15	13.5	24	1	1	1
December	15	13.5	25	1	1	1

20

\* Equals limit if limit is <= 10

Months of Discharge/yr	12		
<b>Points per each exceedance with 12 months of discharge:</b>	<b>7</b>	<b>3</b>	
Exceedances	2	2	
Points	14	6	
<b>Total Number of Points</b>		<b>20</b>	

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is  $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Prior operator wasn't using standard methods of testing, adjustments to the overall operation of the plant were made and corrected the issues.

<b>Total Points Generated</b>	20
<b>Score (100 - Total Points Generated)</b>	80
<b>Section Grade</b>	<b>C</b>

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

## Effluent Quality and Plant Performance (Ammonia - NH3)

### 1. Effluent Ammonia Results

1.1 Verify the following monthly and weekly average effluent values, exceedances and points for ammonia

Outfall No. 001	Monthly Average NH3 Limit (mg/L)	Weekly Average NH3 Limit (mg/L)	Effluent Monthly Average NH3 (mg/L)	Monthly Permit Limit Exceedance	Effluent Weekly Average for Week 1	Effluent Weekly Average for Week 2	Effluent Weekly Average for Week 3	Effluent Weekly Average for Week 4	Weekly Permit Limit Exceedance
January	8.6		.305	0					
February	8.6		.635	0					
March	8.6		1.177	0					
April	8.6		.473	0					
May	4		.27	0					
June	4		.126	0					
July	4		.104	0					
August	4		.114	0					
September	4		.125	0					
October	8.6		.169	0					
November	8.6		.08	0					
December	8.6		.561	0					
Points per each exceedance of Monthly average:									10
Exceedances, Monthly:									0
Points:									0
Points per each exceedance of weekly average (when there is no monthly average):									2.5
Exceedances, Weekly:									0
Points:									0
<b>Total Number of Points</b>									<b>0</b>

0

NOTE: Limit exceedances are considered for monthly OR weekly averages but not both. When a monthly average limit exists it will be used to determine exceedances and generate points. This will be true even if a weekly limit also exists. When a weekly average limit exists and a monthly limit does not exist, the weekly limit will be used to determine exceedances and generate points.

1.2 If any violations occurred, what action was taken to regain compliance?

<b>Total Points Generated</b>	0
<b>Score (100 - Total Points Generated)</b>	100
<b>Section Grade</b>	<b>A</b>

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

## Effluent Quality and Plant Performance (Phosphorus)

### 1. Effluent Phosphorus Results

#### 1.1 Verify the following monthly average effluent values, exceedances, and points for Phosphorus

Outfall No. 001	Monthly Average phosphorus Limit (mg/L)	Effluent Monthly Average phosphorus (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance
January	3	0.219	1	0
February	3	0.160	1	0
March	3	0.105	1	0
April	3	0.188	1	0
May	3	0.200	1	0
June	3	0.424	1	0
July	3	0.403	1	0
August	3	0.166	1	0
September	3	0.366	1	0
October	3	0.263	1	0
November	3	0.513	1	0
December	3	0.580	1	0
Months of Discharge/yr			12	
<b>Points per each exceedance with 12 months of discharge:</b>				<b>10</b>
Exceedances				0
<b>Total Number of Points</b>				<b>0</b>

0

NOTE: For systems that discharge intermittently to waters of the state, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is  $12/6 = 2.0$

#### 1.2 If any violations occurred, what action was taken to regain compliance?

<b>Total Points Generated</b>	0
<b>Score (100 - Total Points Generated)</b>	100
<b>Section Grade</b>	<b>A</b>

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

## Biosolids Quality and Management

<p>1. Biosolids Use/Disposal</p> <p>1.1 How did you use or dispose of your biosolids? (Check all that apply)</p> <p><input type="checkbox"/> Land applied under your permit</p> <p><input type="checkbox"/> Publicly Distributed Exceptional Quality Biosolids</p> <p><input type="checkbox"/> Hauled to another permitted facility</p> <p><input checked="" type="checkbox"/> Landfilled</p> <p><input type="checkbox"/> Incinerated</p> <p><input type="checkbox"/> Other</p> <p>NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.</p> <p>1.1.1 If you checked Other, please describe:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	
<p>6. Biosolids Storage</p> <p>6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site?</p> <p><input checked="" type="radio"/> &gt;= 180 days (0 Points)</p> <p><input type="radio"/> 150 - 179 days (10 Points)</p> <p><input type="radio"/> 120 - 149 days (20 Points)</p> <p><input type="radio"/> 90 - 119 days (30 Points)</p> <p><input type="radio"/> &lt; 90 days (40 Points)</p> <p><input type="radio"/> N/A (0 Points)</p> <p>6.2 If you checked N/A above, explain why.</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	<b>0</b>
<p>7. Issues</p> <p>7.1 Describe any outstanding biosolids issues with treatment, use or overall management:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	

<b>Total Points Generated</b>	<b>0</b>
<b>Score (100 - Total Points Generated)</b>	<b>100</b>
<b>Section Grade</b>	<b>A</b>

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

## Staffing and Preventative Maintenance (All Treatment Plants)

<p>1. Plant Staffing</p> <p>1.1 Was your wastewater treatment plant adequately staffed last year?</p> <ul style="list-style-type: none"><li>● Yes</li><li>○ No</li></ul> <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>Could use more help/staff for:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?</p> <ul style="list-style-type: none"><li>● Yes</li><li>○ No</li></ul> <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	
<p>2. Preventative Maintenance</p> <p>2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?</p> <ul style="list-style-type: none"><li>● Yes (Continue with question 2) <input type="checkbox"/><input type="checkbox"/></li><li>○ No (40 points) <input type="checkbox"/><input type="checkbox"/></li></ul> <p>If No, please explain, then go to question 3:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?</p> <ul style="list-style-type: none"><li>● Yes</li><li>○ No (10 points)</li></ul> <p>2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?</p> <ul style="list-style-type: none"><li>● Yes<ul style="list-style-type: none"><li>○ Paper file system</li><li>○ Computer system</li><li>● Both paper and computer system</li></ul></li><li>○ No (10 points)</li></ul>	<b>0</b>
<p>3. O&amp;M Manual</p> <p>3.1 Does your plant have a detailed O&amp;M and Manufacturer Equipment Manuals that can be used as a reference when needed?</p> <ul style="list-style-type: none"><li>● Yes</li><li>○ No</li></ul>	
<p>4. Overall Maintenance /Repairs</p> <p>4.1 Rate the overall maintenance of your wastewater plant.</p> <ul style="list-style-type: none"><li>● Excellent</li><li>○ Very good</li><li>○ Good</li><li>○ Fair</li><li>○ Poor</li></ul> <p>Describe your rating:</p> <div style="border: 1px solid black; padding: 5px;">The plant was new in 2019 and maintained at a high level.</div>	

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

<b>Total Points Generated</b>	<b>0</b>
<b>Score (100 - Total Points Generated)</b>	<b>100</b>
<b>Section Grade</b>	<b>A</b>

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

## Operator Certification and Education

### 1. Operator-In-Charge

1.1 Did you have a designated operator-in-charge during the report year?

- Yes (0 points)
- No (20 points)

Name:

DALE T PETERSON

Certification No:

37403

0

### 2. Certification Requirements

2.1 In accordance with Chapter NR 114.56 and 114.57, Wisconsin Administrative Code, what level and subclass(es) were required for the operator-in-charge (OIC) to operate the wastewater treatment plant and what level and subclass(es) were held by the operator-in-charge?

Sub Class	SubClass Description	WWTP	OIC		
		Basic	OIT	Basic	Advanced
A1	Suspended Growth Processes	X		X	
A2	Attached Growth Processes				
A3	Recirculating Media Filters			X	
A4	Ponds, Lagoons and Natural				
A5	Anaerobic Treatment Of Liquid				
B	Solids Separation	X		X	
C	Biological Solids/Sludges	X		X	
P	Total Phosphorus			X	
N	Total Nitrogen				
D	Disinfection	X		X	
L	Laboratory				
U	Unique Treatment Systems				
SS	Sanitary Sewage Collection	X	NA	X	NA

0

2.2 Was the operator-in-charge certified at the appropriate level and subclass(es) to operate this plant? (Note: Certification in subclass SS is required 5 years after permit reissuance.)

- Yes (0 points)
- No (20 points)

### 3. Succession Planning

3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?

- One or more additional certified operators on staff
- An arrangement with another certified operator
- An arrangement with another community with a certified operator
- An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year
- A consultant to serve as your certified operator
- None of the above (20 points)

If "None of the above" is selected, please explain:

0

### 4. Continuing Education Credits

4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates?

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

OIT and Basic Certification: <ul style="list-style-type: none"><li>● Averaging 6 or more CECs per year.</li><li>○ Averaging less than 6 CECs per year.</li></ul> Advanced Certification: <ul style="list-style-type: none"><li>○ Averaging 8 or more CECs per year.</li><li>○ Averaging less than 8 CECs per year.</li></ul>	
--	--

<b>Total Points Generated</b>	<b>0</b>
<b>Score (100 - Total Points Generated)</b>	<b>100</b>
<b>Section Grade</b>	<b>A</b>

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

## Financial Management

<p>1. Provider of Financial Information</p> <p>Name: <input style="width: 300px;" type="text" value="Hailey Roessler"/></p> <p>Telephone: <input style="width: 150px;" type="text" value="608-924-5881"/> (XXX) XXX-XXXX</p> <p>E-Mail Address (optional): <input style="width: 300px;" type="text" value="clerk@ridgewaywi.gov"/></p>																	
<p>2. Treatment Works Operating Revenues</p> <p>2.1 Are User Charges or other revenues sufficient to cover O&amp;M expenses for your wastewater treatment plant AND/OR collection system ?</p> <p>● Yes (0 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ No (40 points)</p> <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised?</p> <p>Year: <input style="width: 100px;" type="text" value="2022"/></p> <p>● 0-2 years ago (0 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ 3 or more years ago (20 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ N/A (private facility)</p> <p>2.3 Did you have a special account (e.g., CFWP required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system?</p> <p>● Yes (0 points)</p> <p>○ No (40 points)</p>	0																
<p>REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]</p>																	
<p>3. Equipment Replacement Funds</p> <p>3.1 When was the Equipment Replacement Fund last reviewed and/or revised?</p> <p>Year: <input style="width: 100px;" type="text" value="2022"/></p> <p>● 1-2 years ago (0 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ 3 or more years ago (20 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ N/A</p> <p>If N/A, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>																	
<p>3.2 Equipment Replacement Fund Activity</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;"><b>3.2.1 Ending Balance Reported on Last Year's CMAR</b></td> <td style="width: 5%;"></td> <td style="width: 5%; text-align: right;">\$</td> <td style="width: 30%; text-align: right;"><input style="width: 150px;" type="text" value="128,983.35"/></td> </tr> <tr> <td>3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)</td> <td style="text-align: center;">-</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 150px;" type="text" value="2,596.32"/></td> </tr> <tr> <td>3.2.3 Adjusted January 1st Beginning Balance</td> <td></td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 150px;" type="text" value="126,387.03"/></td> </tr> <tr> <td>3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)</td> <td style="text-align: center;">+</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 150px;" type="text" value="8,375.27"/></td> </tr> </table>	<b>3.2.1 Ending Balance Reported on Last Year's CMAR</b>		\$	<input style="width: 150px;" type="text" value="128,983.35"/>	3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	-	\$	<input style="width: 150px;" type="text" value="2,596.32"/>	3.2.3 Adjusted January 1st Beginning Balance		\$	<input style="width: 150px;" type="text" value="126,387.03"/>	3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	+	\$	<input style="width: 150px;" type="text" value="8,375.27"/>	
<b>3.2.1 Ending Balance Reported on Last Year's CMAR</b>		\$	<input style="width: 150px;" type="text" value="128,983.35"/>														
3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	-	\$	<input style="width: 150px;" type="text" value="2,596.32"/>														
3.2.3 Adjusted January 1st Beginning Balance		\$	<input style="width: 150px;" type="text" value="126,387.03"/>														
3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	+	\$	<input style="width: 150px;" type="text" value="8,375.27"/>														

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below\*) -

\$ 0.00

3.2.6 Ending Balance as of December 31st for CMAR Reporting Year

\$ 134,762.30

All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.

3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.

3.3 What amount should be in your Replacement Fund?

\$ 125,810.00

0

Please note: If you had a CWFPP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the SectionInstructions link under Info header in the left-side menu.

3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?

- Yes
- No

If No, please explain.

## 4. Future Planning

4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?

- Yes - If Yes, please provide major project information, if not already listed below.
- No

Project #	Project Description	Estimated Cost	Approximate Construction Year
None reported			

## 5. Financial Management General Comments

### ENERGY EFFICIENCY AND USE

## 6. Collection System

### 6.1 Energy Usage

6.1.1 Enter the monthly energy usage from the different energy sources:

#### **COLLECTION SYSTEM PUMPAGE: Total Power Consumed**

Number of Municipally Owned Pump/Lift Stations:

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

	Electricity Consumed (kWh)	Natural Gas Consumed (therms)
January	16,529	
February	16,286	
March	16,265	
April	16,864	
May	13,452	
June	17,362	
July	14,898	
August	15,494	
September	14,280	
October	14,319	
November	13,431	
December	14,085	
<b>Total</b>	<b>183,265</b>	<b>0</b>
<b>Average</b>	<b>15,272</b>	<b>0</b>

## 6.1.2 Comments:

## 6.2 Energy Related Processes and Equipment

6.2.1 Indicate equipment and practices utilized at your pump/lift stations (Check all that apply):

- Comminution or Screening
- Extended Shaft Pumps
- Flow Metering and Recording
- Pneumatic Pumping
- SCADA System
- Self-Priming Pumps
- Submersible Pumps
- Variable Speed Drives
- Other:

## 6.2.2 Comments:

6.3 Has an Energy Study been performed for your pump/lift stations?

No

Yes

Year:

By Whom:

Describe and Comment:

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

## 6.4 Future Energy Related Equipment

6.4.1 What energy efficient equipment or practices do you have planned for the future for your pump/lift stations?

## 7. Treatment Facility

### 7.1 Energy Usage

7.1.1 Enter the monthly energy usage from the different energy sources:

#### TREATMENT PLANT: Total Power Consumed/Month

	Electricity Consumed (kWh)	Total Influent Flow (MG)	Electricity Consumed/Flow (kWh/MG)	Total Influent BOD (1000 lbs)	Electricity Consumed/Total Influent BOD (kWh/1000lbs)	Natural Gas Consumed (therms)
January	16,200	1.03	15,728	2.17	7,465	
February	15,900	0.89	17,865	1.99	7,990	
March	15,900	1.15	13,826	2.51	6,335	
April	16,500	1.29	12,791	2.34	7,051	
May	13,200	1.19	11,092	2.17	6,083	
June	17,100	0.96	17,813	1.83	9,344	
July	14,700	0.89	16,517	2.33	6,309	
August	15,300	0.95	16,105	1.61	9,503	
September	14,100	0.98	14,388	1.29	10,930	
October	14,100	0.88	16,023	1.67	8,443	
November	13,200	0.94	14,043	1.62	8,148	
December	13,800	1.15	12,000	2.60	5,308	
<b>Total</b>	<b>180,000</b>	<b>12.30</b>		<b>24.13</b>		<b>0</b>
<b>Average</b>	<b>15,000</b>	<b>1.03</b>	<b>14,849</b>	<b>2.01</b>	<b>7,742</b>	<b>0</b>

7.1.2 Comments:

### 7.2 Energy Related Processes and Equipment

7.2.1 Indicate equipment and practices utilized at your treatment facility (Check all that apply):

- Aerobic Digestion
- Anaerobic Digestion
- Biological Phosphorus Removal
- Coarse Bubble Diffusers
- Dissolved O2 Monitoring and Aeration Control
- Effluent Pumping
- Fine Bubble Diffusers
- Influent Pumping
- Mechanical Sludge Processing
- Nitrification
- SCADA System
- UV Disinfection
- Variable Speed Drives
- Other:

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 2022

## 7.2.2 Comments:

Nonne

## 7.3 Future Energy Related Equipment

7.3.1 What energy efficient equipment or practices do you have planned for the future for your treatment facility?

None at this time.

## 8. Biogas Generation

8.1 Do you generate/produce biogas at your facility?

No

Yes

If Yes, how is the biogas used (Check all that apply):

Flared Off

Building Heat

Process Heat

Generate Electricity

Other:

## 9. Energy Efficiency Study

9.1 Has an Energy Study been performed for your treatment facility?

No

Yes

Entire facility

Year:

2018

By Whom:

MSA Engineering

Describe and Comment:

Prior to new facility construction in 2019

Part of the facility

Year:

By Whom:

Describe and Comment:

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

<b>Total Points Generated</b>	<b>0</b>
<b>Score (100 - Total Points Generated)</b>	<b>100</b>
<b>Section Grade</b>	<b>A</b>

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 2022

## Sanitary Sewer Collection Systems

### 1. Capacity, Management, Operation, and Maintenance (CMOM) Program

#### 1.1 Do you have a CMOM program that is being implemented?

- Yes
- No

If No, explain:

Previous Operator indicated that a CMOM existed in the past years CMAR's, however current staff has been unable to locate it and in discussion with Village Engineer's, has determined that it didn't exist. We are in discussion with the current engineer on getting one developed ASAP.

#### 1.2 Do you have a CMOM program that contains all the applicable components and items according to Wisc. Adm Code NR 210.23 (4)?

- Yes
- No (30 points)
- N/A

If No or N/A, explain:

Previous Operator indicated that a CMOM existed in the past years CMAR's, however current staff has been unable to locate it and in discussion with Village Engineer's, has determined that it didn't exist. We are in discussion with the current engineer on getting one developed ASAP.

#### 1.3 Does your CMOM program contain the following components and items? (check the components and items that apply)

- Goals [NR 210.23 (4)(a)]

Describe the major goals you had for your collection system last year:

As a new operator with the Village of Ridgeway, there was very little documentation, so moving forward good documentation and file systems will be in place.

Did you accomplish them?

- Yes
- No

If No, explain:

As a new operator with the Village of Ridgeway, there was very little documentation, so moving forward good documentation and file systems will be in place.

- Organization [NR 210.23 (4) (b)]

Does this chapter of your CMOM include:

- Organizational structure and positions (eg. organizational chart and position descriptions)
- Internal and external lines of communication responsibilities
- Person(s) responsible for reporting overflow events to the department and the public

- Legal Authority [NR 210.23 (4) (c)]

What is the legally binding document that regulates the use of your sewer system?

Chapter 6 Water and Sewer

If you have a Sewer Use Ordinance or other similar document, when was it last reviewed and revised? (MM/DD/YYYY) 2022-07-19

Does your sewer use ordinance or other legally binding document address the following:

- Private property inflow and infiltration
- New sewer and building sewer design, construction, installation, testing and inspection
- Rehabilitated sewer and lift station installation, testing and inspection
- Sewage flows satellite system and large private users are monitored and controlled, as necessary
- Fat, oil and grease control
- Enforcement procedures for sewer use non-compliance
- Operation and Maintenance [NR 210.23 (4) (d)]

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

Does your operation and maintenance program and equipment include the following:

- Equipment and replacement part inventories
- Up-to-date sewer system map
- A management system (computer database and/or file system) for collection system information for O&M activities, investigation and rehabilitation
- A description of routine operation and maintenance activities (see question 2 below)
- Capacity assessment program
- Basement back assessment and correction
- Regular O&M training
- Design and Performance Provisions [NR 210.23 (4) (e)]

What standards and procedures are established for the design, construction, and inspection of the sewer collection system, including building sewers and interceptor sewers on private property?

- State Plumbing Code, DNR NR 110 Standards and/or local Municipal Code Requirements
- Construction, Inspection, and Testing
- Others:

Overflow Emergency Response Plan [NR 210.23 (4) (f)]

Does your emergency response capability include:

- Responsible personnel communication procedures
- Response order, timing and clean-up
- Public notification protocols
- Training
- Emergency operation protocols and implementation procedures

Annual Self-Auditing of your CMOM Program [NR 210.23 (5)]

Special Studies Last Year (check only those that apply):

- Infiltration/Inflow (I/I) Analysis
- Sewer System Evaluation Survey (SSES)
- Sewer Evaluation and Capacity Management Plan (SECAP)
- Lift Station Evaluation Report
- Others:

0

2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning	0	% of system/year
Root removal	0	% of system/year
Flow monitoring	0	% of system/year
Smoke testing	0	% of system/year
Sewer line televising	10	% of system/year
Manhole inspections	0	% of system/year
Lift station O&M	0	# per L.S./year
Manhole rehabilitation	13	% of manholes rehabbed
Mainline rehabilitation	19	% of sewer lines rehabbed

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

Private sewer inspections  % of system/year  
 Private sewer I/I removal  % of private services  
 River or water crossings  % of pipe crossings evaluated or maintained

Please include additional comments about your sanitary sewer collection system below:

### 3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

Total actual amount of precipitation last year in inches  
 Annual average precipitation (for your location)  
 Miles of sanitary sewer  
 Number of lift stations  
 Number of lift station failures  
 Number of sewer pipe failures  
 Number of basement backup occurrences  
 Number of complaints  
 Average daily flow in MGD (if available)  
 Peak monthly flow in MGD (if available)  
 Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

Lift station failures (failures/year)  
 Sewer pipe failures (pipe failures/sewer mile/yr)  
 Sanitary sewer overflows (number/sewer mile/yr)  
 Basement backups (number/sewer mile)  
 Complaints (number/sewer mile)  
 Peaking factor ratio (Peak Monthly:Annual Daily Avg)  
 Peaking factor ratio (Peak Hourly:Annual Daily Avg)

### 4. Overflows

#### LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OVERFLOWS REPORTED \*\*

Date	Location	Cause	Estimated Volume
None reported			

\*\* If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

### 5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

- Yes
- No

If Yes, please describe:

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

Yes

No

If Yes, please describe:

5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:

We have identified areas of concern and are addressing those areas.

5.4 What is being done to address infiltration/inflow in your collection system?

We are addressing known areas of I&I and completing a plan to mitigate those areas.

<b>Total Points Generated</b>	<b>0</b>
<b>Score (100 - Total Points Generated)</b>	<b>100</b>
<b>Section Grade</b>	<b>A</b>

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 **2022**

## Grading Summary

WPDES No: 0031348

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	A	4	3	12
BOD/CBOD	B	3	10	30
TSS	C	2	5	10
Ammonia	A	4	5	20
Phosphorus	A	4	3	12
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
<b>TOTALS</b>			<b>37</b>	<b>128</b>
<b>GRADE POINT AVERAGE (GPA) = 3.46</b>				

### Notes:

- A = Voluntary Range (Response Optional)
- B = Voluntary Range (Response Optional)
- C = Recommendation Range (Response Required)
- D = Action Range (Response Required)
- F = Action Range (Response Required)

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
5/23/2023 2022

## Resolution or Owner's Statement

Name of Governing  
Body or Owner:

Village of Ridgeway

Date of Resolution or  
Action Taken:

2023-06-13

Resolution Number:

2023-06

Date of Submittal:

### ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR SECTIONS (Optional for grade A or B. Required for grade C, D, or F):

Influent Flow and Loadings: Grade = A

Effluent Quality: BOD: Grade = B

Effluent Quality: TSS: Grade = C

Prior operator wasn't using standard methods of testing, adjustments to the overall operation of the plant were made and corrected the issues.

Effluent Quality: Ammonia: Grade = A

Effluent Quality: Phosphorus: Grade = A

Biosolids Quality and Management: Grade = A

Staffing: Grade = A

Operator Certification: Grade = A

Financial Management: Grade = A

Collection Systems: Grade = A

(Regardless of grade, response required for Collection Systems if SSOs were reported)

### ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL GRADE POINT AVERAGE AND ANY GENERAL COMMENTS

(Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)

**G.P.A. = 3.46**