

# **James Orr Coating Inspection**



**Exterior Power Washing**

**150,000 Gallon Water Spheroid**

**Ridgeway Water Utility, Ridgeway, WI**

**Power Washing Performed on: May 1, 2026**

**Inspection Performed by: James Orr Coating Inspection, LLC**

On May 1, 2026, James Orr Coating Inspection performed an exterior power washing on the exterior of the 150,000-gallon sphere for the Village of Ridgeway, WI. James Orr project manager completed the power washing from the boom lift. Eric Jacobs, Scott Halbach and Chloe Orr supported the project. All the dirt and mildew were removed from the exterior of the tank. There were some miscellaneous minor areas of discoloration in the exterior topcoat, the coating 100% intact and the adhesion was very good. The coating is performing as specified.

### **FUTURE RECOMMENDATIONS:**

Perform an exterior power wash when the mildew and dirt build up again over the next few years.

### **PROJECT PHOTOS:**



**Worker Power Washing to Remove Dirt and Mildew**



**Base Cone Before Power Washing**



**Base Cone After Power Washing**