

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:

6/19/2025

2024

## Influent Flow and Loading

### 1. Monthly Average Flows and BOD Loadings

#### 1.1 Verify the following monthly flows and BOD loadings to your facility.

Influent No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average BOD Concentration mg/L	x	8.34	=	Influent Monthly Average BOD Loading, lbs/day
January	0.0309	x	292	x	8.34	=	75
February	0.0347	x	327	x	8.34	=	95
March	0.0342	x	292	x	8.34	=	83
April	0.0888	x	172	x	8.34	=	127
May	0.0795	x	146	x	8.34	=	97
June	0.0794	x	220	x	8.34	=	146
July	0.0947	x	195	x	8.34	=	154
August	0.0403	x	226	x	8.34	=	76
September	0.0454	x	293	x	8.34	=	111
October	0.0389	x	298	x	8.34	=	97
November	0.0767	x	316	x	8.34	=	202
December	0.0410	x	509	x	8.34	=	174

### 2. Maximum Monthly Design Flow and Design BOD Loading

#### 2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	.114	x	90	=	0.1026
		x	100	=	.114
Design BOD, lbs/day	104	x	90	=	93.6
		x	100	=	104

#### 2.2 Verify the number of times the flow and BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times BOD was greater than 90% of design	Number of times BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	1	0
March	1	0	0	0	0
April	1	0	0	1	1
May	1	0	0	1	0
June	1	0	0	1	1
July	1	0	0	1	1
August	1	0	0	0	0
September	1	0	0	1	1
October	1	0	0	1	0
November	1	0	0	1	1
December	1	0	0	1	1
Points per each		2	1	3	2
Exceedances		0	0	9	6
Points		0	0	27	12
<b>Total Number of Points</b>					<b>39</b>

39

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
6/19/2025 2024

## 3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?

- ☒ Yes Enter last calibration date (MM/DD/YYYY)

2024-04-10

☐ No

If No, please explain:

## 4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

☒ Yes

☐ No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

☐ Yes

☒ No

If Yes, please explain:

## 5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks

Holding Tanks

Grease Traps

☒ Yes

☒ Yes

☐ Yes

☐ No

☐ No

☒ No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

☒ Yes

299,542

gallons

☐ No

Holding Tanks

☒ Yes

156,925

gallons

☐ No

Grease Traps

☐ Yes

gallons

☒ No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

No issues from hauled septage.

## 6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

☐ Yes

☒ No

If yes, describe the situation and your community's response.

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated:    Reporting For:  
6/19/2025                    **2024**

<div><div><input type="radio"/> Yes</div><div><input checked="" type="radio"/> No</div></div> <div>If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.</div> <div></div>	
--	--

Total Points Generated	39
Score (100 - Total Points Generated)	61
Section Grade	D

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
6/19/2025 **2024**

## Effluent Quality and Plant Performance (BOD/CBOD)

### 1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	15	13.5	4	1	0	0
February	15	13.5	3	1	0	0
March	15	13.5	6	1	0	0
April	15	13.5	5	1	0	0
May	15	13.5	7	1	0	0
June	15	13.5	4	1	0	0
July	15	13.5	4	1	0	0
August	15	13.5	6	1	0	0
September	15	13.5	6	1	0	0
October	15	13.5	4	1	0	0
November	15	13.5	3	1	0	0
December	15	13.5	4	1	0	0

\* Equals limit if limit is  $\leq 10$

Months of discharge/yr	12		
Points per each exceedance with 12 months of discharge		7	3
Exceedances		0	0
Points		0	0
<b>Total number of points</b>			<b>0</b>

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is  $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

### 2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

☐ Yes Enter last calibration date (MM/DD/YYYY)

☒ No

If No, please explain:

We do not have an effluent flow meter. Therefore it is the same calibration as the influent meter.

### 3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

None.

### 4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

☐ Yes



# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
6/19/2025 2024

## Effluent Quality and Plant Performance (Total Suspended Solids)

1. Effluent Total Suspended Solids Results

1.1 Verify the following monthly average effluent values, exceedances, and points for TSS:

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit >10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	15	13.5	8	1	0	0
February	15	13.5	4	1	0	0
March	15	13.5	4	1	0	0
April	15	13.5	7	1	0	0
May	15	13.5	6	1	0	0
June	15	13.5	2	1	0	0
July	15	13.5	3	1	0	0
August	15	13.5	7	1	0	0
September	15	13.5	10	1	0	0
October	15	13.5	7	1	0	0
November	15	13.5	4	1	0	0
December	15	13.5	4	1	0	0
* Equals limit if limit is <= 10						
Months of Discharge/yr				12		
Points per each exceedance with 12 months of discharge:					7	3
Exceedances					0	0
Points					0	0
Total Number of Points						0
NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is 12/6 = 2.0						
1.2 If any violations occurred, what action was taken to regain compliance?						

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
6/19/2025 2024

## Effluent Quality and Plant Performance (Ammonia - NH3)

1. Effluent Ammonia Results									
1.1 Verify the following monthly and weekly average effluent values, exceedances and points for ammonia									
Outfall No. 001	Monthly Average NH3 Limit (mg/L)	Weekly Average NH3 Limit (mg/L)	Effluent Monthly Average NH3 (mg/L)	Monthly Permit Limit Exceed ance	Effluent Weekly Average for Week 1	Effluent Weekly Average for Week 2	Effluent Weekly Average for Week 3	Effluent Weekly Average for Week 4	Weekly Permit Limit Exceed ance
January	8.6	17	.468	0	.54	.15	.92	.205	0
February	8.6	17	1.024	0	.595	.575	2.37	.775	0
March	8.6	17	.446	0	.685	.39	.435	.275	0
April	8.6	17	.378	0	.235	.695	0	.58	0
May	4	8.6	.603	0	.115	.51	.5	.985	0
June	4	8.6	.246	0	.23	.25	.095	.41	0
July	4	8.6	.422	0	.61	.325	.585	.166	0
August	4	8.6	.121	0	.11	.355	.08	0	0
September	4	8.6	.155	0	.13	.085	.05	.355	0
October	8.6	17	.339	0	.13	.08	0	.11	0
November	8.6	17	.111	0	.185	.095	.165	0	0
December	8.6	17	.249	0	.055	.365	.29	.285	0
Points per each exceedance of Monthly average:									10
Exceedances, Monthly:									0
Points:									0
Points per each exceedance of weekly average (when there is no monthly average):									2.5
Exceedances, Weekly:									0
Points:									0
Total Number of Points									0
NOTE: Limit exceedances are considered for monthly OR weekly averages but not both. When a monthly average limit exists it will be used to determine exceedances and generate points. This will be true even if a weekly limit also exists. When a weekly average limit exists and a monthly limit does not exist, the weekly limit will be used to determine exceedances and generate points.									
1.2 If any violations occurred, what action was taken to regain compliance?									

0

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
6/19/2025 2024

## Effluent Quality and Plant Performance (Phosphorus)

1. Effluent Phosphorus Results				
1.1 Verify the following monthly average effluent values, exceedances, and points for Phosphorus				
Outfall No. 001	Monthly Average phosphorus Limit (mg/L)	Effluent Monthly Average phosphorus (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance
January	1	0.379	1	0
February	1	0.154	1	0
March	1	0.154	1	0
April	1	0.213	1	0
May	1	0.208	1	0
June	1	0.184	1	0
July	1	0.165	1	0
August	1	0.402	1	0
September	1	0.593	1	0
October	1	0.481	1	0
November	1	0.171	1	0
December	1	0.196	1	0
Months of Discharge/yr			12	
Points per each exceedance with 12 months of discharge:				10
Exceedances				0
Total Number of Points				0
NOTE: For systems that discharge intermittently to waters of the state, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is 12/6 = 2.0				
1.2 If any violations occurred, what action was taken to regain compliance?				

0

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A



# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
6/19/2025 2024

## Biosolids Quality and Management

1. Biosolids Use/Disposal

1.1 How did you use or dispose of your biosolids? (Check all that apply)

☐ Land applied under your permit

☐ Publicly Distributed Exceptional Quality Biosolids

☐ Hauled to another permitted facility

☒ Landfilled

☐ Incinerated

☐ Other

NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.

1.1.1 If you checked Other, please describe:

3. Biosolids Metals

Number of biosolids outfalls in your WPDES permit:

3.1 For each outfall tested, verify the biosolids metal quality values for your facility during the last calendar year.

Outfall No. 003 - SLUDGE

Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75					<1.7									0	0
Cadmium		39	85					.29									0	0
Copper		1500	4300					310									0	0
Lead		300	840					15									0	0
Mercury		17	57					.59									0	0
Molybdenum	60		75					3.5								0		0
Nickel	336		420					12								0		0
Selenium	80		100					5.8								0		0
Zinc		2800	7500					700									0	0

3.1.1 Number of times any of the metals exceeded the high quality limits OR 80% of the limit for molybdenum, nickel, or selenium = 0

Exceedence Points

☒ 0 (0 Points)

☐ 1-2 (10 Points)

☐ > 2 (15 Points)

3.1.2 If you exceeded the high quality limits, did you cumulatively track the metals loading at each land application site? (check applicable box)

☐ Yes

☐ No (10 points)

☒ N/A - Did not exceed limits or no HQ limit applies (0 points)

☐ N/A - Did not land apply biosolids until limit was met (0 points)

3.1.3 Number of times any of the metals exceeded the ceiling limits = 0

Exceedence Points

☒ 0 (0 Points)

☐ 1 (10 Points)

☐ > 1 (15 Points)

3.1.4 Were biosolids land applied which exceeded the ceiling limit?

☐ Yes (20 Points)

☒ No (0 Points)

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
6/19/2025 2024

3.1.5 If any metal limit (high quality or ceiling) was exceeded at any time, what action was taken? Has the source of the metals been identified? <div></div>	0
6. Biosolids Storage 6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site? ● >= 180 days (0 Points) ○ 150 - 179 days (10 Points) ○ 120 - 149 days (20 Points) ○ 90 - 119 days (30 Points) ○ < 90 days (40 Points) ○ N/A (0 Points) 6.2 If you checked N/A above, explain why. <div></div>	0
7. Issues 7.1 Describe any outstanding biosolids issues with treatment, use or overall management: <div></div>	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:

6/19/2025

2024

## Staffing and Preventative Maintenance (All Treatment Plants)

<p>1. Plant Staffing</p> <p>1.1 Was your wastewater treatment plant adequately staffed last year?</p> <ul style="list-style-type: none"><li>● Yes</li><li>○ No</li></ul> <p>If No, please explain:</p> <div></div> <p>Could use more help/staff for:</p> <div></div> <p>1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?</p> <ul style="list-style-type: none"><li>● Yes</li><li>○ No</li></ul> <p>If No, please explain:</p> <div></div>	
<p>2. Preventative Maintenance</p> <p>2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?</p> <ul style="list-style-type: none"><li>● Yes (Continue with question 2) <input type="checkbox"/><input type="checkbox"/></li><li>○ No (40 points)<input type="checkbox"/><input type="checkbox"/></li></ul> <p>If No, please explain, then go to question 3:</p> <div></div> <p>2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?</p> <ul style="list-style-type: none"><li>● Yes</li><li>○ No (10 points)</li></ul> <p>2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?</p> <ul style="list-style-type: none"><li>● Yes<ul style="list-style-type: none"><li>● Paper file system</li><li>○ Computer system</li><li>○ Both paper and computer system</li></ul></li><li>○ No (10 points)</li></ul>	0
<p>3. O&amp;M Manual</p> <p>3.1 Does your plant have a detailed O&amp;M and Manufacturer Equipment Manuals that can be used as a reference when needed?</p> <ul style="list-style-type: none"><li>● Yes</li><li>○ No</li></ul>	
<p>4. Overall Maintenance /Repairs</p> <p>4.1 Rate the overall maintenance of your wastewater plant.</p> <ul style="list-style-type: none"><li>● Excellent</li><li>○ Very good</li><li>○ Good</li><li>○ Fair</li><li>○ Poor</li></ul> <p>Describe your rating:</p> <div>The plant is relatively new, meeting limits and operating well.</div>	

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated:    Reporting For:  
6/19/2025                    **2024**

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	<b>A</b>

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
6/19/2025 **2024**

## Operator Certification and Education

### 1. Operator-In-Charge

1.1 Did you have a designated operator-in-charge during the report year?

- Yes (0 points)
- No (20 points)

Name:

DAVID A BEKKUM

Certification No:

16970

0

### 2. Certification Requirements

2.1 In accordance with Chapter NR 114.56 and 114.57, Wisconsin Administrative Code, what level and subclass(es) were required for the operator-in-charge (OIC) to operate the wastewater treatment plant and what level and subclass(es) were held by the operator-in-charge?

Sub Class	SubClass Description	WWTP	OIC		
		Basic	OIT	Basic	Advanced
A1	Suspended Growth Processes	X			X
A2	Attached Growth Processes				
A3	Recirculating Media Filters				
A4	Ponds, Lagoons and Natural				
A5	Anaerobic Treatment Of Liquid				
B	Solids Separation	X			X
C	Biological Solids/Sludges	X			X
P	Total Phosphorus	X			X
N	Total Nitrogen				
D	Disinfection	X			X
L	Laboratory				X
U	Unique Treatment Systems				
SS	Sanitary Sewage Collection	X	NA	NA	NA

0

2.2 Was the operator-in-charge certified at the appropriate level and subclass(es) to operate this plant? (Note: Certification in subclass SS is required 5 years after permit reissuance.)

- Yes (0 points)
- No (20 points)

2.3 For wastewater treatment facilities with a registered or certified laboratory, is at least one operator that works in the laboratory certified at the basic level in the laboratory (L) subclass?

- Yes
- No

● N/A – Wastewater treatment facility does not have a registered or certified laboratory

2.4 For wastewater treatment facilities that own and operate a sanitary sewage collection system, has at least one operator been designated the OIC for sanitary sewage collection system and certified at the basic level in the sanitary sewage collection system (SS) subclass?

- Yes
- No

○ N/A – Owner of the Wastewater treatment facility does not own and operate a sanitary sewage collection system

### 3. Succession Planning

3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?

☐ One or more additional certified operators on staff

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
6/19/2025 2024

<div><div><input type="checkbox"/> An arrangement with another certified operator</div><div><input type="checkbox"/> An arrangement with another community with a certified operator</div><div><input type="checkbox"/> An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year</div><div><input checked="" type="checkbox"/> A consultant to serve as your certified operator</div><div><input type="checkbox"/> None of the above (20 points)</div><div>If "None of the above" is selected, please explain:</div><div></div></div>	0
<div>4. Continuing Education Credits</div> <div>4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates?</div> <div>OIT and Basic Certification:</div> <div><div><input type="radio"/> Averaging 6 or more CECs per year.</div><div><input type="radio"/> Averaging less than 6 CECs per year.</div></div> <div>Advanced Certification:</div> <div><div><input checked="" type="radio"/> Averaging 8 or more CECs per year.</div><div><input type="radio"/> Averaging less than 8 CECs per year.</div></div>	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
6/19/2025 2024

## Financial Management

### 1. Provider of Financial Information

Name:

Lori Phelan

Telephone:

608-924-5881

(XXX) XXX-XXXX

E-Mail Address  
(optional):

clerk@ridgewaywi.gov

### 2. Treatment Works Operating Revenues

2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ?

● Yes (0 points) ☐

○ No (40 points)

If No, please explain:

2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised?  
Year:

2024

● 0-2 years ago (0 points) ☐

○ 3 or more years ago (20 points) ☐

○ N/A (private facility)

2.3 Did you have a special account (e.g., CWFPP required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system?

● Yes (0 points)

○ No (40 points)

0

REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]

### 3. Equipment Replacement Funds

3.1 When was the Equipment Replacement Fund last reviewed and/or revised?

Year:

2024

● 1-2 years ago (0 points) ☐

○ 3 or more years ago (20 points) ☐

○ N/A

If N/A, please explain:

### 3.2 Equipment Replacement Fund Activity

#### 3.2.1 Ending Balance Reported on Last Year's CMAR

\$ 138,361.19

3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)

\$ 0.00

3.2.3 Adjusted January 1st Beginning Balance

\$ 138,361.19

3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)

+ \$ 3,736.99

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:

6/19/2025

2024

3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below\*)

-

\$ 0.00

3.2.6 Ending Balance as of December 31st for CMAR Reporting Year

\$ 142,098.18

All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.

3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.

3.3 What amount should be in your Replacement Fund?

\$ 140,210.00

0

Please note: If you had a CWWFP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the SectionInstructions link under Info header in the left-side menu.

3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?

☒ Yes

☐ No

If No, please explain.

## 4. Future Planning

4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?

☐ Yes - If Yes, please provide major project information, if not already listed below. ☐ ☐

☒ No

Project #	Project Description	Estimated Cost	Approximate Construction Year
None reported			

## 5. Financial Management General Comments

### ENERGY EFFICIENCY AND USE

## 6. Collection System

### 6.1 Energy Usage

6.1.1 Enter the monthly energy usage from the different energy sources:

#### **COLLECTION SYSTEM PUMPAGE: Total Power Consumed**

Number of Municipally Owned Pump/Lift Stations: 2



# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
6/19/2025 **2024**

	Electricity Consumed (kWh)	Natural Gas Consumed (therms)
January	386	
February	282	
March	266	
April	258	
May	222	
June	228	
July	276	
August	240	
September	242	
October	213	
November	209	
December	305	
Total	<b>3,127</b>	<b>0</b>
Average	<b>261</b>	<b>0</b>

## 6.1.2 Comments:

kWh was taken from the online usage for Alliant Energy.

## 6.2 Energy Related Processes and Equipment

### 6.2.1 Indicate equipment and practices utilized at your pump/lift stations (Check all that apply):

- ☐ Comminution or Screening
- ☐ Extended Shaft Pumps
- ☐ Flow Metering and Recording
- ☐ Pneumatic Pumping
- ☒ SCADA System
- ☐ Self-Priming Pumps
- ☒ Submersible Pumps
- ☒ Variable Speed Drives
- ☐ Other:

### 6.2.2 Comments:

## 6.3 Has an Energy Study been performed for your pump/lift stations?

● No

○ Yes

Year:

By Whom:

Describe and Comment:

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
6/19/2025 **2024**

## 6.4 Future Energy Related Equipment

6.4.1 What energy efficient equipment or practices do you have planned for the future for your pump/lift stations?

## 7. Treatment Facility

### 7.1 Energy Usage

7.1.1 Enter the monthly energy usage from the different energy sources:

#### TREATMENT PLANT: Total Power Consumed/Month

	Electricity Consumed (kWh)	Total Influent Flow (MG)	Electricity Consumed/ Flow (kWh/MG)	Total Influent BOD (1000 lbs)	Electricity Consumed/ Total Influent BOD (kWh/1000lbs)	Natural Gas Consumed (therms)
January	19,200	0.96	20,000	2.33	8,240	
February	14,700	1.01	14,554	2.76	5,326	
March	13,200	1.06	12,453	2.57	5,136	
April	14,400	2.66	5,414	3.81	3,780	
May	14,700	2.46	5,976	3.01	4,884	
June	11,700	2.38	4,916	4.38	2,671	
July	12,600	2.94	4,286	4.77	2,642	
August	16,800	1.25	13,440	2.36	7,119	
September	21,900	1.36	16,103	3.33	6,577	
October	19,200	1.21	15,868	3.01	6,379	
November	15,600	2.30	6,783	6.06	2,574	
December	15,600	1.27	12,283	5.39	2,894	
Total	189,600	20.86		43.78		0
Average	15,800	1.74	11,006	3.65	4,852	0

#### 7.1.2 Comments:

kWh was taken from the online usage for Alliant Energy.

## 7.2 Energy Related Processes and Equipment

7.2.1 Indicate equipment and practices utilized at your treatment facility (Check all that apply):

- ☒ Aerobic Digestion
- ☐ Anaerobic Digestion
- ☒ Biological Phosphorus Removal
- ☐ Coarse Bubble Diffusers
- ☒ Dissolved O2 Monitoring and Aeration Control
- ☐ Effluent Pumping
- ☐ Fine Bubble Diffusers
- ☐ Influent Pumping
- ☐ Mechanical Sludge Processing
- ☐ Nitrification
- ☒ SCADA System
- ☒ UV Disinfection
- ☒ Variable Speed Drives
- ☐ Other:

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
6/19/2025 2024

<div></div>	
<p>7.2.2 Comments:</p> <div>None</div>	
<p>7.3 Future Energy Related Equipment</p> <p>7.3.1 What energy efficient equipment or practices do you have planned for the future for your treatment facility?</p> <div>With everything fairly new nothing is currently planned.</div>	
<p>8. Biogas Generation</p> <p>8.1 Do you generate/produce biogas at your facility?</p> <ul style="list-style-type: none"><li>● No</li><li>○ Yes</li></ul> <p>If Yes, how is the biogas used (Check all that apply):</p> <ul style="list-style-type: none"><li><input type="checkbox"/> Flared Off</li><li><input type="checkbox"/> Building Heat</li><li><input type="checkbox"/> Process Heat</li><li><input type="checkbox"/> Generate Electricity</li><li><input type="checkbox"/> Other:</li></ul> <div></div>	
<p>9. Energy Efficiency Study</p> <p>9.1 Has an Energy Study been performed for your treatment facility?</p> <ul style="list-style-type: none"><li>○ No</li><li>● Yes</li></ul> <p><input checked="" type="checkbox"/> Entire facility</p> <p>Year: <div>2018</div></p> <p>By Whom: <div>MSA Engineering</div></p> <p>Describe and Comment:</p> <div>Prior to construction of the new facility in 2019.</div> <p><input type="checkbox"/> Part of the facility</p> <p>Year: <div></div></p> <p>By Whom: <div></div></p> <p>Describe and Comment:</p> <div></div>	

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
6/19/2025 2024

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
6/19/2025 2024

## Sanitary Sewer Collection Systems

### 1. Capacity, Management, Operation, and Maintenance (CMOM) Program

#### 1.1 Do you have a CMOM program that is being implemented?

- ☒ Yes
- ☐ No

If No, explain:

#### 1.2 Do you have a CMOM program that contains all the applicable components and items according to Wisc. Adm Code NR 210.23 (4)?

- ☒ Yes
- ☐ No (30 points)
- ☐ N/A

If No or N/A, explain:

#### 1.3 Does your CMOM program contain the following components and items? (check the components and items that apply)

##### ☒ Goals [NR 210.23 (4)(a)]

Describe the major goals you had for your collection system last year:

Identified areas of I & I, and are developing strategies to take care of these issues.

Did you accomplish them?

- ☐ Yes
- ☒ No

If No, explain:

Areas of I & I will be addressed as projects are implemented in these areas.

##### ☒ Organization [NR 210.23 (4) (b)] ☐ ☐

Does this chapter of your CMOM include:

- ☒ Organizational structure and positions (eg. organizational chart and position descriptions)
- ☒ Internal and external lines of communication responsibilities
- ☒ Person(s) responsible for reporting overflow events to the department and the public

##### ☒ Legal Authority [NR 210.23 (4) (c)]

What is the legally binding document that regulates the use of your sewer system?

Chapter 6 water and sewer

If you have a Sewer Use Ordinance or other similar document, when was it last reviewed and revised? (MM/DD/YYYY) 2022-07-19

Does your sewer use ordinance or other legally binding document address the following:

- ☒ Private property inflow and infiltration
- ☒ New sewer and building sewer design, construction, installation, testing and inspection
- ☒ Rehabilitated sewer and lift station installation, testing and inspection
- ☒ Sewage flows satellite system and large private users are monitored and controlled, as necessary
- ☒ Fat, oil and grease control
- ☒ Enforcement procedures for sewer use non-compliance

##### ☒ Operation and Maintenance [NR 210.23 (4) (d)]

Does your operation and maintenance program and equipment include the following:

- ☒ Equipment and replacement part inventories
- ☒ Up-to-date sewer system map
- ☒ A management system (computer database and/or file system) for collection system information for O&M activities, investigation and rehabilitation

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:

6/19/2025

2024

- ☒ A description of routine operation and maintenance activities (see question 2 below)
- ☒ Capacity assessment program
- ☒ Basement back assessment and correction
- ☒ Regular O&M training

- ☒ Design and Performance Provisions [NR 210.23 (4) (e)] ☐ ☐

What standards and procedures are established for the design, construction, and inspection of the sewer collection system, including building sewers and interceptor sewers on private property?

- ☒ State Plumbing Code, DNR NR 110 Standards and/or local Municipal Code Requirements
- ☒ Construction, Inspection, and Testing
- ☐ Others:

- ☒ Overflow Emergency Response Plan [NR 210.23 (4) (f)] ☐ ☐

Does your emergency response capability include:

- ☒ Responsible personnel communication procedures
- ☒ Response order, timing and clean-up
- ☒ Public notification protocols
- ☒ Training
- ☒ Emergency operation protocols and implementation procedures

- ☒ Annual Self-Auditing of your CMOM Program [NR 210.23 (5)] ☐ ☐

- ☐ Special Studies Last Year (check only those that apply):

- ☐ Infiltration/Inflow (I/I) Analysis
- ☐ Sewer System Evaluation Survey (SSES)
- ☐ Sewer Evaluation and Capacity Management Plan (SECAP)
- ☐ Lift Station Evaluation Report
- ☐ Others:

0

## 2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning	<input type="text" value="0"/>	% of system/year
Root removal	<input type="text" value="0"/>	% of system/year
Flow monitoring	<input type="text" value="0"/>	% of system/year
Smoke testing	<input type="text" value="0"/>	% of system/year
Sewer line televising	<input type="text" value="45"/>	% of system/year
Manhole inspections	<input type="text" value="60"/>	% of system/year
Lift station O&M	<input type="text" value="4"/>	# per L.S./year
Manhole rehabilitation	<input type="text" value="0"/>	% of manholes rehabbed
Mainline rehabilitation	<input type="text" value="0"/>	% of sewer lines rehabbed
Private sewer inspections	<input type="text" value="0"/>	% of system/year
Private sewer I/I removal	<input type="text" value="0"/>	% of private services

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:

6/19/2025

2024

River or water crossings  % of pipe crossings evaluated or maintained

Please include additional comments about your sanitary sewer collection system below:

## 3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

<input type="text" value="43.8"/>	Total actual amount of precipitation last year in inches
<input type="text" value="39.72"/>	Annual average precipitation (for your location)
<input type="text" value="4.9"/>	Miles of sanitary sewer
<input type="text" value="2"/>	Number of lift stations
<input type="text" value="0"/>	Number of lift station failures
<input type="text" value="0"/>	Number of sewer pipe failures
<input type="text" value="0"/>	Number of basement backup occurrences
<input type="text" value="0"/>	Number of complaints
<input type="text"/>	Average daily flow in MGD (if available)
<input type="text"/>	Peak monthly flow in MGD (if available)
<input type="text"/>	Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

<input type="text" value="0.00"/>	Lift station failures (failures/year)
<input type="text" value="0.00"/>	Sewer pipe failures (pipe failures/sewer mile/yr)
<input type="text" value="0.00"/>	Sanitary sewer overflows (number/sewer mile/yr)
<input type="text" value="0.00"/>	Basement backups (number/sewer mile)
<input type="text" value="0.00"/>	Complaints (number/sewer mile)
<input type="text"/>	Peaking factor ratio (Peak Monthly:Annual Daily Avg)
<input type="text"/>	Peaking factor ratio (Peak Hourly:Annual Daily Avg)

## 4. Overflows

### LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OVERFLOWS REPORTED \*\*

Date	Location	Cause	Estimated Volume
None reported			

\*\* If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

## 5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

☐ Yes

☒ No

If Yes, please describe:

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

☐ Yes

☒ No

If Yes, please describe:

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated:    Reporting For:  
6/19/2025                    **2024**

<div></div> <div>5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:</div> <div>N/A</div> <div>5.4 What is being done to address infiltration/inflow in your collection system?</div> <div>N/A</div>	
---	--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A



# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated: Reporting For:  
6/19/2025 2024

## Grading Summary

WPDES No: 0031348

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	D	1	3	3
BOD/CBOD	A	4	10	40
TSS	A	4	5	20
Ammonia	A	4	5	20
Phosphorus	A	4	3	12
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS			37	139
GRADE POINT AVERAGE (GPA) = 3.76				

- Notes:
- A = Voluntary Range (Response Optional)
  - B = Voluntary Range (Response Optional)
  - C = Recommendation Range (Response Required)
  - D = Action Range (Response Required)
  - F = Action Range (Response Required)

# Compliance Maintenance Annual Report

Ridgeway Wastewater Treatment Facility

Last Updated:    Reporting For:  
6/19/2025                      **2024**

## Resolution or Owner's Statement

Name of Governing Body or Owner:	<div>Village of Ridgeway</div>
Date of Resolution or Action Taken:	<div>2025-06-10</div>
Resolution Number:	<div>2025-04</div>
Date of Submittal:	

**ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR SECTIONS (Optional for grade A or B. Required for grade C, D, or F):**  
Influent Flow and Loadings: Grade =    D  

INI study is being done and smoke testing has been completed. Will address the problem areas once determined.

Effluent Quality: BOD: Grade =    A

Effluent Quality: TSS: Grade =    A

Effluent Quality: Ammonia: Grade =    A

Effluent Quality: Phosphorus: Grade =    A

Biosolids Quality and Management: Grade =    A

Staffing: Grade =    A

Operator Certification: Grade =    A

Financial Management: Grade =    A

Collection Systems: Grade =    A  
(Regardless of grade, response required for Collection Systems if SSOs were reported)

**ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL GRADE POINT AVERAGE AND ANY GENERAL COMMENTS**  
(Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)  
**G.P.A. =    3.76**