

**ROCHELLE CITY COUNCIL  
AGENDA ITEM MEMO  
REGULAR MEETING**

**SUBJECT:** Ordinance for Emergency Repairs to Peaker #2

**Staff Contact:** Blake Toliver Superintendent of Electric Operations

**Summary:** On June 18, 2024, Peaker #2 developed an internal jacket water leak. The Operators were able to continue safely running the engine for that week to shave peak. The week of June 23, operators inspected the issue and discovered a cracked liner. After contacting Fairbanks Morse to replace the liner, we were informed they had availability the week of July 1, otherwise they would not be able to complete the replacement until the end of October. Since that is past the run season, it was necessary to act quickly with the approval of the City Manager. The Technician arrived Sunday evening and began work first thing on Monday, July 1. They installed a new liner and reassembled the engine for operation to continue by July 3.

**Funding Sources:**

Source:	Budgeted Amount:	Proposed Expenditure:
Equipment Budget	\$250,000	\$42,587.02

**Strategic Plan Goal Application:** Infrastructure Effectiveness & Improvement

**Recommendation:** Approve an Ordinance for Emergency Repairs to Peaker #2