



Pollutant (mg/L)	Current City Local Limit (mg/L)	Proposed City Local Limit (mg/L)	Proposed City Surcharge Limit (mg/L)
Ammonia Nitrogen	35.0	REMOVE	15
Arsenic	0.25	1.3	-
Barium	2.0	REMOVE	-
BOD	250.0	REMOVE	250
Cadmium	0.5	0.6	-
Chloride	-	-	-
Chromium (Total)	1.0	REMOVE	-
Copper	1.0	0.5	-
Cyanide	0.025	0.7	-
Fluoride	2.5	REMOVE	-
Iron (Total)	4.0	REMOVE	-
Lead	0.30	REMOVE	-
Manganese	1.0	REMOVE	-
Mercury	0.0005	0.0005	-
Molybdenum	-	-	-
Nickel	1.0	0.6	-
Non-Polar Fats	125	125	-
Polar Oils	20	20	-
Phenols	0.5	REMOVE	-
Phosphorus	10.0	10	-
Selenium	1.0	REMOVE	-
Silver	0.1	0.9	-
Sulfate	-	-	-
TSS	300.0	REMOVE	300
Zinc	2.0	2.5	-