



# OPERATOR'S REPORT

## City of Rollingwood



February 19, 2025



---

**MEMORANDUM**

To: City Administrator, City of Rollingwood  
From: Ben Ingallina, Crossroads Utility Services LLC  
Subject: Monthly Report  
Date: 02/11/25

Previous Directives

- *No directives*

Current Operations Report

- I. **Utility Operations Report**
  - A. **Billing Report/ Water Accountability** – Please see enclosed water operations report
  - B. **Water System Operations and Maintenance** –
    - a. No items to report
  - C. **Wastewater Collection System Operations and Maintenance** – No items to report
  - D. **Lift Station Maintenance** – *See enclosed report*
- II. **Customer Service Issues** – No reported issues
- III. **Emergency Response Items** – No new items
- IV. **Drought Contingency Plan / Watering Restrictions**
  - a. Lake Travis Level –637.38 Current Storage 476,045 acre-feet (43.4% full) -.2% down from last month.
  - b. The City of Austin is currently in Stage 2 watering restrictions – (Started August 15<sup>th</sup> 2023)

Lakes Travis and Buchanan, reservoir lakes for the area's water supply, are expected to drop below 900,000 acre-feet.

The City of Austin is currently in **Stage 2 Drought Water Use Restrictions**.

## Austin's Stage 2 water restrictions

The City of Austin is currently in **Stage 2 Drought Water Use Restrictions**.

- ***Residential***
  - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
    - Even address - Sunday
    - Odd address - Saturday
  - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
    - Even address - Thursday
    - Odd address - Wednesday
- ***Commercial / Multi-family***
  - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
    - Even address - Tuesday
    - Odd address – Friday
  - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
    - Even address - Tuesday
    - Odd address - Friday
- ***Public Schools***
  - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
    - All addresses - Monday
  - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
    - All addresses - Monday
- **Wasting water** is prohibited.

- Washing vehicles at home is permitted with a bucket.
- Charity car washes prohibited.
- Fountains must recirculate water and those with a 4-inch emission or fall of water are prohibited.
- Fountains with a greater than 4-inch emission or fall of water are prohibited
- Restaurants may not serve water unless requested by a customer.
- Patio misters at commercial properties (*including restaurants and bars*) may only operate between 4 p.m. and midnight.
- **Commercial power/pressure washing equipment** must meet efficiency requirements.
- Golf courses using potable water can only irrigate fairways on their watering day; tees and greens can be watered every other day if Austin Water is notified.
- Irrigation of golf course fairways allowed between midnight and 5:00 a.m. or between 7:00 p.m. and midnight on designated outdoor water-use days only
- Irrigation of golf course greens or tees allowed every other day with notice to and approval by Austin Water only



**MEMORANDUM**

To: City of Rollingwood  
From: Ben Ingallina, Crossroads Utility Services LLC  
Subject: Lift Station Report Detail  
Date: 02/12/25

Lift Station 1 – Dellana Ln.

- No issues.

Lift Station 2 – Hatley Dr.

- No issues.

Lift Station 3 – Almarion Way

- No issues.

Lift Station 4- Rockway Cv.

- No issues.

Lift Station 5 – Vale Dr.

- No issues.

Lift Station 6 – Pleasant Cv.

- No issues.

Lift Station 7 – Nixon Dr.

- No issues.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY  
Water Utilities Division

Monthly Operational Report For Public Water Systems Purchasing Treated Water From Another System  
Which Uses Surface Water Sources or Groundwater Sources Under The Influence of Surface Water

PUBLIC WATER SYSTEM NAME: **City of Rollingwood**

System I.D. #: 2270016

Month: **January 2025**

Submitted by:

Date:

No. of Connections: **537**

License #:

Grade:

TREATED WATER PURCHASED FROM A WHOLESALE SUPPLIER				
Date	Quantity (mgd)	Date	Quantity (mgd)	Monthly Summary (mgd)
1	0.282	16	0.289	Total
2	0.406	17	0.245	Monthly
3	0.264	18	0.245	Purchase: 7.535
4	0.265	19	0.245	
5	0.264	20	0.200	Average
6	0.240	21	0.199	Daily: 0.243
7	0.266	22	0.252	
8	0.211	23	0.233	Maximum
9	0.253	24	0.209	Daily: 0.406
10	0.225	25	0.208	
11	0.225	26	0.210	Minimum
12	0.225	27	0.209	Daily: 0.185
13	0.257	28	0.278	
14	0.265	29	0.197	
15	0.273	30	0.185	
		31	0.210	

DISTRIBUTION SYSTEM (DISINFECTANT RESIDUAL MONITORING)		
Minimum allowable disinfectant residual:	<u>0.5</u> mg/L	Percentage of the measurements below the limit this month:
Total no. of measurements this month:	<u>33</u>	<input type="text" value="0%"/> (1A)
No. of measurements below the limit:	<u>0</u>	
Percentage of the measurements below the limit last month:		<input type="text" value="0%"/> (1B)

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATION	Yes/No	If YES, Date when Notice was Given to the:	
		TCEQ	Customers*
More than 5.0% of the disinfectant residuals in the distribution system below acceptable levels for two consecutive months? - see (1A) and (1B)	NO		

\* A sample copy of the Notice to the customers must accompany this report.

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **January 2025**

LOCATION: **Bee Cave Woods**

I.D. #: **2270016**

		METER #07914810	SIZE 6"	METER #18713312	SIZE 3"	TOTAL FLOW	TOTAL GAL PURCHASED	CHLORINE RESIDUAL
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL	MG	mg/L
Wed	1	143141	207.0	29673	75.0	282.0	0.282	2.4
Thu	2	143348	298.0	29748	108.0	406.0	0.406	2.5
Fri	3	143646	184.0	29856	80.0	264.0	0.264	2.6
Sat	4	143830	184.0	29936	81.0	265.0	0.265	1.7
Sun	5	144014	184.0	30017	80.0	264.0	0.264	1.6
Mon	6	144198	156.0	30097	84.0	240.0	0.240	2.1
Tue	7	144354	192.0	30181	74.0	266.0	0.266	2.4
Wed	8	144546	141.0	30255	70.0	211.0	0.211	2.6
Thu	9	144687	161.0	30325	92.0	253.0	0.253	2.5
Fri	10	144848	142.0	30417	83.0	225.0	0.225	2.6
Sat	11	144990	142.0	30500	83.0	225.0	0.225	2.3
Sun	12	145132	142.0	30583	83.0	225.0	0.225	2.5
Mon	13	145274	167.0	30666	90.0	257.0	0.257	3.0
Tue	14	145441	193.0	30756	72.0	265.0	0.265	2.5
Wed	15	145634	195.0	30828	78.0	273.0	0.273	3.8
Thu	16	145829	207.0	30906	82.0	289.0	0.289	2.8
Fri	17	146036	160.0	30988	85.0	245.0	0.245	2.3
Sat	18	146196	160.0	31073	85.0	245.0	0.245	2.5
Sun	19	146356	160.0	31158	85.0	245.0	0.245	2.2
Mon	20	146516	123.0	31243	77.0	200.0	0.200	2.2
Tue	21	146639	122.0	31320	77.0	199.0	0.199	2.8
Wed	22	146761	172.0	31397	80.0	252.0	0.252	2.1
Thu	23	146933	152.0	31477	81.0	233.0	0.233	1.8
Fri	24	147085	130.0	31558	79.0	209.0	0.209	2.5
Sat	25	147215	129.0	31637	79.0	208.0	0.208	2.4
Sun	26	147344	130.0	31716	80.0	210.0	0.210	2.4
Mon	27	147474	130.0	31796	79.0	209.0	0.209	2.4
Tue	28	147604	178.0	31875	100.0	278.0	0.278	2.6
Wed	29	147782	116.0	31975	81.0	197.0	0.197	2.6
Thu	30	147898	112.0	32056	73.0	185.0	0.185	2.6
Fri	31	148010	126.0	32129	84.0	210.0	0.210	2.9
Sat	1	148136		32213				
Total			4995.0	27140.0	2540.0	7535.0	7.5	
Avg.			161.1		81.9	243.1	0.243	2.5
Max.			298.0		108.0	406.0	0.406	3.8
Min.			112.0		70.0	185.0	0.185	1.6

Operator: \_\_\_\_\_

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **January 2025**

LOCATION: **Hatley MM**

I.D. #: **2270016**

		METER No S/n	SIZE 6"	METER #151074A	SIZE 3"	TOTAL FLOW
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL
Wed	1	92	0.0	7544	0.0	0.0
Thu	2	92	0.0	7544	0.0	0.0
Fri	3	92	0.0	7544	0.0	0.0
Sat	4	92	0.0	7544	0.0	0.0
Sun	5	92	0.0	7544	0.0	0.0
Mon	6	92	0.0	7544	0.0	0.0
Tue	7	92	0.0	7544	0.0	0.0
Wed	8	92	0.0	7544	0.0	0.0
Thu	9	92	0.0	7544	0.0	0.0
Fri	10	92	0.0	7544	0.0	0.0
Sat	11	92	0.0	7544	0.0	0.0
Sun	12	92	0.0	7544	0.0	0.0
Mon	13	92	0.0	7544	0.0	0.0
Tue	14	92	0.0	7544	0.0	0.0
Wed	15	92	0.0	7544	0.0	0.0
Thu	16	92	0.0	7544	0.0	0.0
Fri	17	92	0.0	7544	0.0	0.0
Sat	18	92	0.0	7544	0.0	0.0
Sun	19	92	0.0	7544	0.0	0.0
Mon	20	92	0.0	7544	0.0	0.0
Tue	21	92	0.0	7544	0.0	0.0
Wed	22	92	0.0	7544	0.0	0.0
Thu	23	92	0.0	7544	0.0	0.0
Fri	24	92	0.0	7544	0.0	0.0
Sat	25	92	0.0	7544	0.0	0.0
Sun	26	92	0.0	7544	0.0	0.0
Mon	27	92	0.0	7544	0.0	0.0
Tue	28	92	0.0	7544	0.0	0.0
Wed	29	92	0.0	7544	0.0	0.0
Thu	30	92	0.0	7544	0.0	0.0
Fri	31	92	0.0	7544	0.0	0.0
Sat	1	92		7544		
Total			0.0		0.0	0.0
Avg.			0.0		0.0	0.0
Max.			0.0		0.0	0.0
Min.			0.0		0.0	0.0

Operator: \_\_\_\_\_



MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **January 2025**

LOCATION: **Riley MM**

I.D. #: **2270016**

DAY	DATE	METER	SIZE	METER	SIZE	TOTAL
		No S/N	6"	No S/N	3"	FLOW
		A	TH GAL	B	TH GAL	TH GAL
Wed	1	3619	0.0	21519	0.0	0.0
Thu	2	3619	0.0	21519	0.0	0.0
Fri	3	3619	0.0	21519	0.0	0.0
Sat	4	3619	0.0	21519	0.0	0.0
Sun	5	3619	0.0	21519	0.0	0.0
Mon	6	3619	0.0	21519	0.0	0.0
Tue	7	3619	0.0	21519	0.0	0.0
Wed	8	3619	0.0	21519	0.0	0.0
Thu	9	3619	0.0	21519	0.0	0.0
Fri	10	3619	0.0	21519	0.0	0.0
Sat	11	3619	0.0	21519	0.0	0.0
Sun	12	3619	0.0	21519	0.0	0.0
Mon	13	3619	0.0	21519	0.0	0.0
Tue	14	3619	0.0	21519	0.0	0.0
Wed	15	3619	0.0	21519	0.0	0.0
Thu	16	3619	0.0	21519	0.0	0.0
Fri	17	3619	0.0	21519	0.0	0.0
Sat	18	3619	0.0	21519	0.0	0.0
Sun	19	3619	0.0	21519	0.0	0.0
Mon	20	3619	0.0	21519	0.0	0.0
Tue	21	3619	0.0	21519	0.0	0.0
Wed	22	3619	0.0	21519	0.0	0.0
Thu	23	3619	0.0	21519	0.0	0.0
Fri	24	3619	0.0	21519	0.0	0.0
Sat	25	3619	0.0	21519	0.0	0.0
Sun	26	3619	0.0	21519	0.0	0.0
Mon	27	3619	0.0	21519	0.0	0.0
Tue	28	3619	0.0	21519	0.0	0.0
Wed	29	3619	0.0	21519	0.0	0.0
Thu	30	3619	0.0	21519	0.0	0.0
Fri	31	3619	0.0	21519	0.0	0.0
Sat	1	3619		21519		
Total			0.0		0.0	0.0
Avg.			0.0		0.0	0.0
Max.			0.0		0.0	0.0
Min.			0.0		0.0	0.0

Operator: \_\_\_\_\_