



OPERATOR'S REPORT

City of Rollingwood



March 19, 2025



MEMORANDUM

To: City Administrator, City of Rollingwood
From: Ben Ingallina, Crossroads Utility Services LLC
Subject: Monthly Report
Date: 03/11/2025

Previous Directives

- *No directives*

Current Operations Report

- I. **Utility Operations Report**
 - A. **Billing Report/ Water Accountability** – Please see enclosed water operations report
 - B. **Water System Operations and Maintenance** –
 - a. No items to report
 - C. **Wastewater Collection System Operations and Maintenance** – No items to report
 - D. **Lift Station Maintenance** – *See enclosed report*
- II. **Customer Service Issues** – No reported issues
- III. **Emergency Response Items** – No new items
- IV. **Drought Contingency Plan / Watering Restrictions**
 - a. Lake Travis Level –636.89 Current Storage 471,050 acre-feet (42.9% full) -.5% down from last month.
 - b. The City of Austin is currently in Stage 2 watering restrictions – (Started August 15th 2023)

Lakes Travis and Buchanan, reservoir lakes for the area's water supply, are expected to drop below 900,000 acre-feet.

The City of Austin is currently in **Stage 2 Drought Water Use Restrictions**.

Austin's Stage 2 water restrictions

The City of Austin is currently in **Stage 2 Drought Water Use Restrictions**.

- ***Residential***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - Even address - Sunday
 - Odd address - Saturday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - Even address - Thursday
 - Odd address - Wednesday
- ***Commercial / Multi-family***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - Even address - Tuesday
 - Odd address – Friday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - Even address - Tuesday
 - Odd address - Friday
- ***Public Schools***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - All addresses - Monday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - All addresses - Monday
- **Wasting water** is prohibited.

- Washing vehicles at home is permitted with a bucket.
- Charity car washes prohibited.
- Fountains must recirculate water and those with a 4-inch emission or fall of water are prohibited.
- Fountains with a greater than 4-inch emission or fall of water are prohibited
- Restaurants may not serve water unless requested by a customer.
- Patio misters at commercial properties (*including restaurants and bars*) may only operate between 4 p.m. and midnight.
- **Commercial power/pressure washing equipment** must meet efficiency requirements.
- Golf courses using potable water can only irrigate fairways on their watering day; tees and greens can be watered every other day if Austin Water is notified.
- Irrigation of golf course fairways allowed between midnight and 5:00 a.m. or between 7:00 p.m. and midnight on designated outdoor water-use days only
- Irrigation of golf course greens or tees allowed every other day with notice to and approval by Austin Water only



MEMORANDUM

To: City of Rollingwood
From: Ben Ingallina, Crossroads Utility Services LLC
Subject: Lift Station Report Detail
Date: 03/11/2025

Lift Station 1 – Dellana Ln.

- No issues. Replaced Off Float on 3/11/2025

Lift Station 2 – Hatley Dr.

- No issues.

Lift Station 3 – Almarion Way

- No issues.

Lift Station 4- Rockway Cv.

- No issues.

Lift Station 5 – Vale Dr.

- No issues.

Lift Station 6 – Pleasant Cv.

- No issues.

Lift Station 7 – Nixon Dr.

- No issues.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
 Water Utilities Division

Monthly Operational Report For Public Water Systems Purchasing Treated Water From Another System
 Which Uses Surface Water Sources or Groundwater Sources Under The Influence of Surface Water

PUBLIC WATER SYSTEM NAME: **City of Rollingwood**

System I.D. #: 2270016

Month: **February 2025**

Submitted by:

Date:

No. of Connections: **537**

License #:

Grade:

TREATED WATER PURCHASED FROM A WHOLESALE SUPPLIER				
Date	Quantity (mgd)	Date	Quantity (mgd)	Monthly Summary (mgd)
1	0.210	16	0.192	Total
2	0.210	17	0.192	Monthly
3	0.217	18	0.192	Purchase: 6.380
4	0.233	19	0.207	
5	0.332	20	0.228	Average
6	0.174	21	0.162	Daily: 0.228
7	0.283	22	0.162	
8	0.285	23	0.161	Maximum
9	0.284	24	0.315	Daily: 0.367
10	0.184	25	0.313	
11	0.142	26	0.367	Minimum
12	0.241	27	0.238	Daily: 0.142
13	0.175	28	0.298	
14	0.192			
15	0.191			

DISTRIBUTION SYSTEM (DISINFECTANT RESIDUAL MONITORING)		
Minimum allowable disinfectant residual:	<u>0.5</u> mg/L	Percentage of the measurements below the limit this month:
Total no. of measurements this month:	<u>29</u>	<input type="text" value="0%"/> (1A)
No. of measurements below the limit:	<u>0</u>	
Percentage of the measurements below the limit last month:		<input type="text" value="0%"/> (1B)

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATION	Yes/No	If YES, Date when Notice was Given to the:	
		TCEQ	Customers*
More than 5.0% of the disinfectant residuals in the distribution system below acceptable levels for two consecutive months? - see (1A) and (1B)	NO		

* A sample copy of the Notice to the customers must accompany this report.

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **February 2025**

LOCATION: **Bee Cave Woods**

I.D. #: **2270016**

		METER #07914810	SIZE 6"	METER #18713312	SIZE 3"	TOTAL FLOW	TOTAL GAL PURCHASED	CHLORINE RESIDUAL
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL	MG	mg/L
Sat	1	148136	126.0	32213	84.0	210.0	0.210	2.6
Sun	2	148262	126.0	32297	84.0	210.0	0.210	2.2
Mon	3	148388	143.0	32381	74.0	217.0	0.217	3.0
Tue	4	148531	166.0	32455	67.0	233.0	0.233	2.9
Wed	5	148697	234.0	32522	98.0	332.0	0.332	3.0
Thu	6	148931	126.0	32620	48.0	174.0	0.174	2.8
Fri	7	149057	189.0	32668	94.0	283.0	0.283	2.8
Sat	8	149246	190.0	32762	95.0	285.0	0.285	2.4
Sun	9	149436	190.0	32857	94.0	284.0	0.284	2.5
Mon	10	149626	114.0	32951	70.0	184.0	0.184	2.9
Tue	11	149740	81.0	33021	61.0	142.0	0.142	3.0
Wed	12	149821	137.0	33082	104.0	241.0	0.241	2.5
Thu	13	149958	107.0	33186	68.0	175.0	0.175	2.4
Fri	14	150065	111.0	33254	81.0	192.0	0.192	2.6
Sat	15	150176	110.0	33335	81.0	191.0	0.191	2.5
Sun	16	150286	111.0	33416	81.0	192.0	0.192	2.8
Mon	17	150397	111.0	33497	81.0	192.0	0.192	2.6
Tue	18	150508	111.0	33578	81.0	192.0	0.192	2.6
Wed	19	150619	122.0	33659	85.0	207.0	0.207	2.5
Thu	20	150741	149.0	33744	79.0	228.0	0.228	2.6
Fri	21	150890	89.0	33823	73.0	162.0	0.162	2.5
Sat	22	150979	89.0	33896	73.0	162.0	0.162	2.5
Sun	23	151068	89.0	33969	72.0	161.0	0.161	2.5
Mon	24	151157	225.0	34041	90.0	315.0	0.315	2.3
Tue	25	151382	224.0	34131	89.0	313.0	0.313	2.4
Wed	26	151606	272.0	34220	95.0	367.0	0.367	2.6
Thu	27	151878	178.0	34315	60.0	238.0	0.238	2.4
Fri	28	152056	207.0	34375	91.0	298.0	0.298	2.5
Tue	1	152263		34466				
Total			4127.0	27140.0	2253.0	6380.0	6.4	
Avg.			147.4		80.5	227.9	0.228	2.6
Max.			272.0		104.0	367.0	0.367	3.0
Min.			81.0		48.0	142.0	0.142	2.2

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **February 2025**

LOCATION: **Hatley MM**

I.D. #: **2270016**

DAY	DATE	METER	SIZE	METER	SIZE	TOTAL
		No S/n	6"	#151074A	3"	FLOW
		A	TH GAL	B	TH GAL	TH GAL
Sat	1	92	0.0	7544	0.0	0.0
Sun	2	92	0.0	7544	0.0	0.0
Mon	3	92	0.0	7544	0.0	0.0
Tue	4	92	0.0	7544	0.0	0.0
Wed	5	92	0.0	7544	0.0	0.0
Thu	6	92	0.0	7544	0.0	0.0
Fri	7	92	0.0	7544	0.0	0.0
Sat	8	92	0.0	7544	0.0	0.0
Sun	9	92	0.0	7544	0.0	0.0
Mon	10	92	0.0	7544	0.0	0.0
Tue	11	92	0.0	7544	0.0	0.0
Wed	12	92	0.0	7544	0.0	0.0
Thu	13	92	0.0	7544	0.0	0.0
Fri	14	92	0.0	7544	0.0	0.0
Sat	15	92	0.0	7544	0.0	0.0
Sun	16	92	0.0	7544	0.0	0.0
Mon	17	92	0.0	7544	0.0	0.0
Tue	18	92	0.0	7544	0.0	0.0
Wed	19	92	0.0	7544	0.0	0.0
Thu	20	92	0.0	7544	0.0	0.0
Fri	21	92	0.0	7544	0.0	0.0
Sat	22	92	0.0	7544	0.0	0.0
Sun	23	92	0.0	7544	0.0	0.0
Mon	24	92	0.0	7544	0.0	0.0
Tue	25	92	0.0	7544	0.0	0.0
Wed	26	92	0.0	7544	0.0	0.0
Thu	27	92	0.0	7544	0.0	0.0
Fri	28	92	0.0	7544	0.0	0.0
Tue	1	92		7544		
Total			0.0		0.0	0.0
Avg.			0.0		0.0	0.0
Max.			0.0		0.0	0.0
Min.			0.0		0.0	0.0

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **February 2025**

LOCATION: **Riley MM**

I.D. #: **2270016**

DAY	DATE	METER	SIZE	METER	SIZE	TOTAL
		No S/N	6"	No S/N	3"	FLOW
		A	TH GAL	B	TH GAL	TH GAL
Sat	1	3619	0.0	21519	0.0	0.0
Sun	2	3619	0.0	21519	0.0	0.0
Mon	3	3619	0.0	21519	0.0	0.0
Sat	4	3619	0.0	21519	0.0	0.0
Sun	5	3619	0.0	21519	0.0	0.0
Mon	6	3619	0.0	21519	0.0	0.0
Tue	7	3619	0.0	21519	0.0	0.0
Wed	8	3619	0.0	21519	0.0	0.0
Thu	9	3619	0.0	21519	0.0	0.0
Fri	10	3619	0.0	21519	0.0	0.0
Sat	11	3619	0.0	21519	0.0	0.0
Sun	12	3619	0.0	21519	0.0	0.0
Mon	13	3619	0.0	21519	0.0	0.0
Tue	14	3619	0.0	21519	0.0	0.0
Wed	15	3619	0.0	21519	0.0	0.0
Thu	16	3619	0.0	21519	0.0	0.0
Fri	17	3619	0.0	21519	0.0	0.0
Sat	18	3619	0.0	21519	0.0	0.0
Sun	19	3619	0.0	21519	0.0	0.0
Mon	20	3619	0.0	21519	0.0	0.0
Tue	21	3619	0.0	21519	0.0	0.0
Wed	22	3619	0.0	21519	0.0	0.0
Thu	23	3619	0.0	21519	0.0	0.0
Fri	24	3619	0.0	21519	0.0	0.0
Sat	25	3619	0.0	21519	0.0	0.0
Sun	26	3619	0.0	21519	0.0	0.0
Mon	27	3619	0.0	21519	0.0	0.0
Tue	28	3619	0.0	21519	0.0	0.0
Sat	1	3619		21519		
Total			0.0		0.0	0.0
Avg.			0.0		0.0	0.0
Max.			0.0		0.0	0.0
Min.			0.0		0.0	0.0

Operator: _____