



OPERATOR'S REPORT

City of Rollingwood



October 16, 2024



MEMORANDUM

To: Ms. Ashley Wayman, City Administrator, City of Rollingwood
From: Ben Ingallina, Crossroads Utility Services LLC
Subject: Monthly Report
Date: 10/09/24

Previous Directives

- *No directives*

Current Operations Report

- I. **Utility Operations Report**
 - A. **Billing Report/ Water Accountability** – Please see enclosed water operations report
 - B. **Water System Operations and Maintenance** –
 - a. No items to report
 - C. **Wastewater Collection System Operations and Maintenance** – No items to report
 - D. **Lift Station Maintenance** – *See enclosed report*
- II. **Customer Service Issues** – No reported issues
- III. **Emergency Response Items** – No new items
- IV. **Drought Contingency Plan / Watering Restrictions**
 - a. Lake Travis Level – 639.73– Current Storage 500,504 acre-feet (45.6% full) -3.1% down from last month.
 - b. The City of Austin is currently in Stage 2 watering restrictions – (Started August 15th 2023)

Lakes Travis and Buchanan, reservoir lakes for the area's water supply, are expected to drop below 900,000 acre-feet.

The City of Austin is currently in **Stage 2 Drought Water Use Restrictions**.

Austin's Stage 2 water restrictions

The City of Austin is currently in **Stage 2 Drought Water Use Restrictions**.

- ***Residential***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - Even address - Sunday
 - Odd address - Saturday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - Even address - Thursday
 - Odd address - Wednesday
- ***Commercial / Multi-family***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - Even address - Tuesday
 - Odd address – Friday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - Even address - Tuesday
 - Odd address - Friday
- ***Public Schools***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - All addresses - Monday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - All addresses - Monday
- **Wasting water** is prohibited.

- Washing vehicles at home is permitted with a bucket.
- Charity car washes prohibited.
- Fountains must recirculate water and those with a 4-inch emission or fall of water are prohibited.
- Fountains with a greater than 4-inch emission or fall of water are prohibited
- Restaurants may not serve water unless requested by a customer.
- Patio misters at commercial properties (*including restaurants and bars*) may only operate between 4 p.m. and midnight.
- **Commercial power/pressure washing equipment** must meet efficiency requirements.
- Golf courses using potable water can only irrigate fairways on their watering day; tees and greens can be watered every other day if Austin Water is notified.
- Irrigation of golf course fairways allowed between midnight and 5:00 a.m. or between 7:00 p.m. and midnight on designated outdoor water-use days only
- Irrigation of golf course greens or tees allowed every other day with notice to and approval by Austin Water only



MEMORANDUM

To: Ms. Ashley Wayman, City of Rollingwood
From: Ben Ingallina, Crossroads Utility Services LLC
Subject: Lift Station Report Detail
Date: 10/09/24

Lift Station 1 – Dellana Ln.

- Pump 1 off for repair due to check valve issue, maintenance already sent to Rollingwood. No other issues.

Lift Station 2 – Hatley Dr.

- No issues

Lift Station 3 – Almarion Way

- No issues.

Lift Station 4- Rockway Cv.

- No issues.

Lift Station 5 – Vale Dr.

- No issues.

Lift Station 6 – Pleasant Cv.

- No issues.

Lift Station 7 – Nixon Dr.

- No issues.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
 Water Utilities Division

Monthly Operational Report For Public Water Systems Purchasing Treated Water From Another System
 Which Uses Surface Water Sources or Groundwater Sources Under The Influence of Surface Water

PUBLIC WATER SYSTEM NAME: **City of Rollingwood**

System I.D. #: 2270016

Month: **September 2024**

Submitted by:

Date:

No. of Connections: **537**

License #:

Grade:

TREATED WATER PURCHASED FROM A WHOLESALE SUPPLIER				
Date	Quantity (mgd)	Date	Quantity (mgd)	Monthly Summary (mgd)
1	0.532	16	0.636	Total
2	0.533	17	0.727	Monthly
3	0.614	18	0.812	Purchase: 18.495
4	0.667	19	0.678	
5	0.534	20	0.547	Average
6	0.531	21	0.547	Daily: 0.617
7	0.530	22	0.546	
8	0.531	23	0.572	Maximum
9	0.673	24	0.690	Daily: 0.812
10	0.665	25	0.756	
11	0.774	26	0.766	Minimum
12	0.719	27	0.559	Daily: 0.530
13	0.533	28	0.559	
14	0.534	29	0.558	
15	0.533	30	0.639	

DISTRIBUTION SYSTEM (DISINFECTANT RESIDUAL MONITORING)		
Minimum allowable disinfectant residual:	0.5 mg/L	Percentage of the measurements below the limit this month:
Total no. of measurements this month:	32	<input type="text" value="0%"/> (1A)
No. of measurements below the limit:	0	
Percentage of the measurements below the limit last month:		<input type="text" value="0%"/> (1B)

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATION	Yes/No	If YES, Date when Notice was Given to the:	
		TCEQ	Customers*
More than 5.0% of the disinfectant residuals in the distribution system below acceptable levels for two consecutive months? - see (1A) and (1B)	NO		

* A sample copy of the Notice to the customers must accompany this report.

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **September 2024**

LOCATION: **Bee Cave Woods**

I.D. #: **2270016**

		METER #07914810	SIZE 6"	METER #18713312	SIZE 3"	TOTAL FLOW	TOTAL GAL PURCHASED	CHLORINE RESIDUAL
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL	MG	mg/L
Sun	1	93205	478.0	20167	54.0	532.0	0.532	2.1
Mon	2	93683	479.0	20221	54.0	533.0	0.533	2.4
Tue	3	94162	551.0	20275	63.0	614.0	0.614	2.6
Wed	4	94713	599.0	20338	68.0	667.0	0.667	1.1
Thu	5	95312	470.0	20406	64.0	534.0	0.534	2.3
Fri	6	95782	469.0	20470	62.0	531.0	0.531	2.3
Sat	7	96251	468.0	20532	62.0	530.0	0.530	2.3
Sun	8	96719	469.0	20594	62.0	531.0	0.531	2.6
Mon	9	97188	591.0	20656	82.0	673.0	0.673	2.7
Tue	10	97779	602.0	20738	63.0	665.0	0.665	2.4
Wed	11	98381	700.0	20801	74.0	774.0	0.774	2.7
Thu	12	99081	645.0	20875	74.0	719.0	0.719	2.9
Fri	13	99726	467.0	20949	66.0	533.0	0.533	2.6
Sat	14	100193	467.0	21015	67.0	534.0	0.534	2.4
Sun	15	100660	466.0	21082	67.0	533.0	0.533	2.6
Mon	16	101126	567.0	21149	69.0	636.0	0.636	2.5
Tue	17	101693	655.0	21218	72.0	727.0	0.727	2.5
Wed	18	102348	733.0	21290	79.0	812.0	0.812	2.6
Thu	19	103081	608.0	21369	70.0	678.0	0.678	2.0
Fri	20	103689	480.0	21439	67.0	547.0	0.547	2.5
Sat	21	104169	479.0	21506	68.0	547.0	0.547	2.4
Sun	22	104648	479.0	21574	67.0	546.0	0.546	2.5
Mon	23	105127	501.0	21641	71.0	572.0	0.572	1.3
Tue	24	105628	615.0	21712	75.0	690.0	0.690	2.4
Wed	25	106243	691.0	21787	65.0	756.0	0.756	2.3
Thu	26	106934	675.0	21852	91.0	766.0	0.766	1.8
Fri	27	107609	480.0	21943	79.0	559.0	0.559	2.3
Sat	28	108089	480.0	22022	79.0	559.0	0.559	2.3
Sun	29	108569	479.0	22101	79.0	558.0	0.558	2.0
Mon	30	109048	563.0	22180	76.0	639.0	0.639	2.5
Tue	1	109611		22256				
Total			16406.0		2089.0	18495.0	18.5	
Avg.			546.9		69.6	616.5	0.617	2.3
Max.			733.0		91.0	812.0	0.812	2.9
Min.			466.0		54.0	530.0	0.530	1.1

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **September 2024**

LOCATION: **Riley MM**

I.D. #: **2270016**

DAY	DATE	METER	SIZE	METER	SIZE	TOTAL
		No S/N	6"	No S/N	3"	FLOW
		A	TH GAL	B	TH GAL	TH GAL
Sun	1	3604	0.0	21519	0.0	0.0
Mon	2	3604	0.0	21519	0.0	0.0
Tue	3	3604	0.0	21519	0.0	0.0
Wed	4	3604	0.0	21519	0.0	0.0
Thu	5	3604	0.0	21519	0.0	0.0
Fri	6	3604	0.0	21519	0.0	0.0
Sat	7	3604	0.0	21519	0.0	0.0
Sun	8	3604	0.0	21519	0.0	0.0
Mon	9	3604	0.0	21519	0.0	0.0
Tue	10	3604	0.0	21519	0.0	0.0
Wed	11	3604	0.0	21519	0.0	0.0
Thu	12	3604	0.0	21519	0.0	0.0
Fri	13	3604	0.0	21519	0.0	0.0
Sat	14	3604	0.0	21519	0.0	0.0
Sun	15	3604	0.0	21519	0.0	0.0
Mon	16	3604	0.0	21519	0.0	0.0
Tue	17	3604	0.0	21519	0.0	0.0
Wed	18	3604	0.0	21519	0.0	0.0
Thu	19	3604	0.0	21519	0.0	0.0
Fri	20	3604	0.0	21519	0.0	0.0
Sat	21	3604	0.0	21519	0.0	0.0
Sun	22	3604	0.0	21519	0.0	0.0
Mon	23	3604	0.0	21519	0.0	0.0
Tue	24	3604	0.0	21519	0.0	0.0
Wed	25	3604	0.0	21519	0.0	0.0
Thu	26	3604	0.0	21519	0.0	0.0
Fri	27	3604	0.0	21519	0.0	0.0
Sat	28	3604	0.0	21519	0.0	0.0
Sun	29	3604	0.0	21519	0.0	0.0
Mon	30	3604	0.0	21519	0.0	0.0
Tue	1	3604		21519		
Total			0.0		0.0	0.0
Avg.			0.0		0.0	0.0
Max.			0.0		0.0	0.0
Min.			0.0		0.0	0.0

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **September 2024**

LOCATION: **Hatley MM**

I.D. #: **2270016**

DAY	DATE	METER No S/n		METER #151074A		TOTAL FLOW
		A	TH GAL	B	TH GAL	TH GAL
Sun	1	92	0.0	7541	0.0	0.0
Mon	2	92	0.0	7541	0.0	0.0
Tue	3	92	0.0	7541	0.0	0.0
Wed	4	92	0.0	7541	0.0	0.0
Thu	5	92	0.0	7541	0.0	0.0
Fri	6	92	0.0	7541	0.0	0.0
Sat	7	92	0.0	7541	0.0	0.0
Sun	8	92	0.0	7541	0.0	0.0
Mon	9	92	0.0	7541	0.0	0.0
Tue	10	92	0.0	7541	0.0	0.0
Wed	11	92	0.0	7541	0.0	0.0
Thu	12	92	0.0	7541	0.0	0.0
Fri	13	92	0.0	7541	0.0	0.0
Sat	14	92	0.0	7541	0.0	0.0
Sun	15	92	0.0	7541	0.0	0.0
Mon	16	92	0.0	7541	0.0	0.0
Tue	17	92	0.0	7541	0.0	0.0
Wed	18	92	0.0	7541	0.0	0.0
Thu	19	92	0.0	7541	0.0	0.0
Fri	20	92	0.0	7541	0.0	0.0
Sat	21	92	0.0	7541	0.0	0.0
Sun	22	92	0.0	7541	0.0	0.0
Mon	23	92	0.0	7541	0.0	0.0
Tue	24	92	0.0	7541	0.0	0.0
Wed	25	92	0.0	7541	0.0	0.0
Thu	26	92	0.0	7541	0.0	0.0
Fri	27	92	0.0	7541	0.0	0.0
Sat	28	92	0.0	7541	0.0	0.0
Sun	29	92	0.0	7541	0.0	0.0
Mon	30	92	0.0	7541	0.0	0.0
Tue	1	92		7541		
Total			0.0		0.0	0.0
Avg.			0.0		0.0	0.0
Max.			0.0		0.0	0.0
Min.			0.0		0.0	0.0

Operator: _____