



OPERATOR'S REPORT

City of Rollingwood



February 19, 2026



MEMORANDUM

To: City Administrator, City of Rollingwood
From: Ben Ingallina, Crossroads Utility Services LLC
Subject: Monthly Report
Date: 02/11/2026

Previous Directives

- *No directives*

Current Operations Report

- I. **Utility Operations Report**
 - A. **Billing Report/ Water Accountability** – Please see enclosed water operations report
 - B. **Water System Operations and Maintenance** –
 - a. No items to report
 - C. **Wastewater Collection System Operations and Maintenance** – No items to report
 - D. **Lift Station Maintenance** – *See enclosed report*
- II. **Customer Service Issues** – No reported issues
- III. **Emergency Response Items** – No new items
- IV. **Drought Contingency Plan / Watering Restrictions**
 - a. Lake Travis Level –666.82 Current Storage 868,734 acre-feet (77.6% full) -0.5% down from last month.
 - b. The City of Austin returned to Conservation Stage Drought Water Use Restrictions (Stage1) watering restrictions – (Started September 2nd 2025) [Find Your Watering Day | AustinTexas.gov](#)

Current Water Restrictions

Austin residents can protect their lakes, the environment, and their future water supply by watering only one day a week. Join your neighbors in helping your community and wallet by adhering to the mandatory watering days and times.

By watering only one day a week with a typical automatic irrigation system rather than two to three times a week, a household could save 7,000 to 14,000 gallons a month. That could be a savings of up to \$150 a month, depending on how much additional water is used by a household.

As of September 2, 2025, the City of Austin returned to Conservation Stage Drought Water Use Restrictions.

- **Residential**
 - Hose-end Sprinklers & Drip Irrigation - two days per week - midnight to 10 a.m. or 7 p.m. to midnight.
 - Even addresses – Thursday and Sunday
 - Odd addresses – Wednesday and Saturday
 - Automatic & Manual Irrigation Systems - one day per week - midnight to 10 a.m. or 7 p.m. to midnight.
 - Even addresses - Thursday
 - Odd addresses - Wednesday
- **Commercial / Multi-family**
 - Drip Irrigation - two days per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - All Addresses- Tuesday and Friday
 - Automatic & Manual Irrigation Systems - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - Even addresses - Tuesday
 - Odd addresses - Friday
- **Public Schools / HOAs / Golf Course Fairways**
 - Hose-end Sprinklers & Drip Irrigation - two days per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - All addresses – Monday and Thursday
 - Automatic & Manual Irrigation Systems - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - All addresses – Monday
- **Wasting water** is prohibited.
- Home car washing must be done with positive shutoff valve.
- Charity car washes can be held at commercial car washes.
- Fountains must recirculate water.
- Restaurants may not serve water unless requested by a customer.
- Patio misters at commercial properties (including restaurants and bars) may only operate between 4 p.m. and midnight.

- **Commercial power/pressure washing equipment** must meet efficiency requirements.
- Golf courses using potable water can only irrigate fairways on their watering day; tees and greens can be watered every other day if Austin Water is notified.
- Irrigation of golf course fairways allowed between midnight and 5:00 a.m. or between 7:00 p.m. and midnight on designated outdoor water-use days only
- Irrigation of golf course greens or tees allowed every other day with notice to and approval by Austin Water only

**MEMORANDUM**

To: City of Rollingwood
From: Ben Ingallina, Crossroads Utility Services LLC
Subject: Lift Station Report Detail
Date: 02/11/2025

Lift Station 1 – Dellana Ln.

- No issues.

Lift Station 2 – Hatley Dr.

- No issues.

Lift Station 3 – Almarion Way

- No issues.

Lift Station 4- Rockway Cv.

- No issues.

Lift Station 5 – Vale Dr.

- No issues.

Lift Station 6 – Pleasant Cv.

- No issues.

Lift Station 7 – Nixon Dr.

- No issues.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
Water Utilities Division

Monthly Operational Report For Public Water Systems Purchasing Treated Water From Another System
Which Uses Surface Water Sources or Groundwater Sources Under The Influence of Surface Water

PUBLIC WATER SYSTEM NAME: **City of Rollingwood**

System I.D. #: 2270016

Month: **January 2026**

Submitted by:

Date:

No. of Connections: **537**

License #:

Grade:

TREATED WATER PURCHASED FROM A WHOLESALE SUPPLIER				
Date	Quantity (mgd)	Date	Quantity (mgd)	Monthly Summary (mgd)
1	0.314	16	0.262	Total
2	0.315	17	0.262	Monthly
3	0.313	18	0.263	Purchase:
4	0.315	19	0.179	9.192
5	0.330	20	0.556	Average
6	0.406	21	0.285	Daily: 0.297
7	0.399	22	0.287	
8	0.370	23	0.194	Maximum
9	0.306	24	0.193	Daily: 0.556
10	0.312	25	0.195	
11	0.306	26	0.194	Minimum
12	0.361	27	0.289	Daily: 0.179
13	0.361	28	0.268	
14	0.351	29	0.228	
15	0.381	30	0.199	
		31	0.198	

DISTRIBUTION SYSTEM (DISINFECTANT RESIDUAL MONITORING)		
Minimum allowable disinfectant residual:	0.5 mg/L	Percentage of the measurements below the limit this month:
Total no. of measurements this month:	31	0% (1A)
No. of measurements below the limit:	0	
Percentage of the measurements below the limit last month:	0%	(1B)

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATION	Yes/No	If YES, Date when Notice was Given to the:	
		TCEQ	Customers*
More than 5.0% of the disinfectant residuals in the distribution system below acceptable levels for two consecutive months? - see (1A) and (1B)	NO		

* A sample copy of the Notice to the customers must accompany this report.

MASTER METER REPORT

DISTRICT: **City of Rollingwood**MONTH: **January 2026**LOCATION: **Bee Cave Woods**I.D. #: **2270016**

		METER #07914810	SIZE 6"	METER #18713312	SIZE 3"	TOTAL FLOW	TOTAL GAL PURCHASED	CHLORINE RESIDUAL
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL	MG	mg/L
Thu	1	251259	240.0	57923	74.0	314.0	0.314	2.0
Fri	2	251499	241.0	57997	74.0	315.0	0.315	2.1
Sat	3	251740	240.0	58071	73.0	313.0	0.313	1.9
Sun	4	251980	241.0	58144	74.0	315.0	0.315	2.2
Mon	5	252221	257.0	58218	73.0	330.0	0.330	2.0
Tue	6	252478	331.0	58291	75.0	406.0	0.406	1.9
Wed	7	252809	325.0	58366	74.0	399.0	0.399	2.4
Thu	8	253134	296.0	58440	74.0	370.0	0.370	2.2
Fri	9	253430	232.0	58514	74.0	306.0	0.306	2.0
Sat	10	253662	233.0	58588	74.0	307.0	0.312	1.7
Sun	11	253895	233.0	58662	73.0	306.0	0.306	3.0
Mon	12	254128	287.0	58735	74.0	361.0	0.361	2.1
Tue	13	254415	287.0	58809	74.0	361.0	0.361	2.2
Wed	14	254702	279.0	58883	72.0	351.0	0.351	2.5
Thu	15	254981	304.0	58955	77.0	381.0	0.381	2.2
Fri	16	255285	189.0	59032	73.0	262.0	0.262	2.1
Sat	17	255474	189.0	59105	73.0	262.0	0.262	2.4
Sun	18	255663	190.0	59178	73.0	263.0	0.263	2.3
Mon	19	255853	143.0	59251	36.0	179.0	0.179	2.1
Tue	20	255996	441.0	59287	115.0	556.0	0.556	2.0
Wed	21	256437	215.0	59402	70.0	285.0	0.285	1.9
Thu	22	256652	216.0	59472	71.0	287.0	0.287	1.9
Fri	23	256868	122.0	59543	72.0	194.0	0.194	2.3
Sat	24	256990	121.0	59615	72.0	193.0	0.193	2.5
Sun	25	257111	122.0	59687	73.0	195.0	0.195	2.2
Mon	26	257233	122.0	59760	72.0	194.0	0.194	2.4
Tue	27	257355	215.0	59832	74.0	289.0	0.289	2.1
Wed	28	257570	198.0	59906	70.0	268.0	0.268	2.2
Thu	29	257768	155.0	59976	73.0	228.0	0.228	2.2
Fri	30	257923	126.0	60049	73.0	199.0	0.199	2.2
Sat	31	258049	125.0	60122	73.0	198.0	0.198	2.0
Sun	1	258174		60195				
Total			6915.0		2272.0	9187.0	9.2	
Avg.			223.1		73.3	296.4	0.297	2.2
Max.			441.0		115.0	556.0	0.556	3.0
Min.			121.0		36.0	179.0	0.179	1.7

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**MONTH: **January 2026**LOCATION: **Hatley MM**I.D. #: **2270016**

		METER No S/n	SIZE 6"	METER #151074A	SIZE 3"	TOTAL FLOW
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL
Thu	1	101	0.0	7569	0.0	0.0
Fri	2	101	0.0	7569	0.0	0.0
Sat	3	101	0.0	7569	0.0	0.0
Sun	4	101	0.0	7569	0.0	0.0
Mon	5	101	0.0	7569	0.0	0.0
Tue	6	101	0.0	7569	0.0	0.0
Wed	7	101	0.0	7569	0.0	0.0
Thu	8	101	0.0	7569	0.0	0.0
Fri	9	101	0.0	7569	0.0	0.0
Sat	10	101	0.0	7569	0.0	0.0
Sun	11	101	0.0	7569	0.0	0.0
Mon	12	101	0.0	7569	0.0	0.0
Tue	13	101	0.0	7569	0.0	0.0
Wed	14	101	0.0	7569	0.0	0.0
Thu	15	101	0.0	7569	0.0	0.0
Fri	16	101	0.0	7569	0.0	0.0
Sat	17	101	0.0	7569	0.0	0.0
Sun	18	101	0.0	7569	0.0	0.0
Mon	19	101	0.0	7569	0.0	0.0
Tue	20	101	0.0	7569	0.0	0.0
Wed	21	101	0.0	7569	0.0	0.0
Thu	22	101	0.0	7569	0.0	0.0
Fri	23	101	0.0	7569	0.0	0.0
Sat	24	101	0.0	7569	0.0	0.0
Sun	25	101	0.0	7569	0.0	0.0
Mon	26	101	0.0	7569	0.0	0.0
Tue	27	101	0.0	7569	0.0	0.0
Wed	28	101	0.0	7569	0.0	0.0
Thu	29	101	0.0	7569	0.0	0.0
Fri	30	101	0.0	7569	0.0	0.0
Sat	31	101	0.0	7569	0.0	0.0
Sun	1	101		7569		
Total			0.0		0.0	0.0
Avg.			0.0		0.0	0.0
Max.			0.0		0.0	0.0
Min.			0.0		0.0	0.0

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**MONTH: **January 2026**LOCATION: **Riley MM**I.D. #: **2270016**

		METER No S/N	SIZE 6"	METER No S/N	SIZE 3"	TOTAL FLOW
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL
Thu	1	3627	0.0	21544	0.0	0.0
Fri	2	3627	0.0	21544	0.0	0.0
Sat	3	3627	0.0	21544	0.0	0.0
Sun	4	3627	0.0	21544	0.0	0.0
Mon	5	3627	0.0	21544	0.0	0.0
Tue	6	3627	0.0	21544	0.0	0.0
Wed	7	3627	0.0	21544	0.0	0.0
Thu	8	3627	0.0	21544	0.0	0.0
Fri	9	3627	0.0	21544	0.0	0.0
Sat	10	3627	5.0	21544	0.0	5.0
Sun	11	3632	0.0	21544	0.0	0.0
Mon	12	3632	0.0	21544	0.0	0.0
Tue	13	3632	0.0	21544	0.0	0.0
Wed	14	3632	0.0	21544	0.0	0.0
Thu	15	3632	0.0	21544	0.0	0.0
Fri	16	3632	0.0	21544	0.0	0.0
Sat	17	3632	0.0	21544	0.0	0.0
Sun	18	3632	0.0	21544	0.0	0.0
Mon	19	3632	0.0	21544	0.0	0.0
Tue	20	3632	0.0	21544	0.0	0.0
Wed	21	3632	0.0	21544	0.0	0.0
Thu	22	3632	0.0	21544	0.0	0.0
Fri	23	3632	0.0	21544	0.0	0.0
Sat	24	3632	0.0	21544	0.0	0.0
Sun	25	3632	0.0	21544	0.0	0.0
Mon	26	3632	0.0	21544	0.0	0.0
Tue	27	3632	0.0	21544	0.0	0.0
Wed	28	3632	0.0	21544	0.0	0.0
Thu	29	3632	0.0	21544	0.0	0.0
Fri	30	3632	0.0	21544	0.0	0.0
wed	31	3632	0.0	21544	0.0	0.0
Sun	1	3632		21544		
Total			5.0		0.0	5.0
Avg.			0.2		0.0	0.2
Max.			5.0		0.0	5.0
Min.			0.0		0.0	0.0

Operator: _____