



OPERATOR'S REPORT

City of Rollingwood



April 17, 2024



MEMORANDUM

To: Ms. Ashley Wayman, City Administrator, City of Rollingwood
From: Ben Ingallina, Crossroads Utility Services LLC
Subject: Monthly Report
Date: 04/10/24

Previous Directives

- *No directives*

Current Operations Report

- I. **Utility Operations Report**
 - A. **Billing Report/ Water Accountability** – Please see enclosed water operations report
 - B. **Water System Operations and Maintenance** –
 - a. No items to report
 - C. **Wastewater Collection System Operations and Maintenance** – No items to report
 - D. **Lift Station Maintenance** – *See enclosed report*
- II. **Customer Service Issues** – No reported issues
- III. **Emergency Response Items** – No new items. We are awaiting the plan for generator installations at the lift stations.
- IV. **Drought Contingency Plan / Watering Restrictions**
 - a. Lake Travis Level – 630.69– Current Storage 427,865 acre-feet (37.4% full) -0.7% down from last month.
 - b. The City of Austin is currently in Stage 2 watering restrictions – (Started August 15th 2023)

Lakes Travis and Buchanan, reservoir lakes for the area's water supply, are expected to drop below 900,000 acre-feet.

The City of Austin is currently in **Stage 2 Drought Water Use Restrictions**.

Austin's Stage 2 water restrictions

The City of Austin is currently in **Stage 2 Drought Water Use Restrictions**.

- ***Residential***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - Even address - Sunday
 - Odd address - Saturday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - Even address - Thursday
 - Odd address - Wednesday
- ***Commercial / Multi-family***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - Even address - Tuesday
 - Odd address – Friday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - Even address - Tuesday
 - Odd address - Friday
- ***Public Schools***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - All addresses - Monday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - All addresses - Monday

- **Wasting water** is prohibited.
- Washing vehicles at home is permitted with a bucket.
- Charity car washes prohibited.
- Fountains must recirculate water and those with a 4-inch emission or fall of water are prohibited.
- Fountains with a greater than 4-inch emission or fall of water are prohibited
- Restaurants may not serve water unless requested by a customer.
- Patio misters at commercial properties (*including restaurants and bars*) may only operate between 4 p.m. and midnight.
- **Commercial power/pressure washing equipment** must meet efficiency requirements.
- Golf courses using potable water can only irrigate fairways on their watering day; tees and greens can be watered every other day if Austin Water is notified.
- Irrigation of golf course fairways allowed between midnight and 5:00 a.m. or between 7:00 p.m. and midnight on designated outdoor water-use days only
- Irrigation of golf course greens or tees allowed every other day with notice to and approval by Austin Water only



MEMORANDUM

To: Ms. Ashley Wayman, City of Rollingwood
From: Ben Ingallina, Crossroads Utility Services LLC
Subject: Lift Station Report Detail
Date: 04/10/24

Lift Station 1 – Dellana Ln.

- No issues. Need spare generator keys.

Lift Station 2 – Hatley Dr.

- No issues.

Lift Station 3 – Almarion Way

- No issues.

Lift Station 4- Rockway Cv.

- No issues.

Lift Station 5 – Vale Dr.

- No issues.

Lift Station 6 – Pleasant Cv.

- Very low flow recently. No issues.

Lift Station 7 – Nixon Dr.

- AT&T repaired phone line twice. Dialer up and running. No issues.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
 Water Utilities Division

Monthly Operational Report For Public Water Systems Purchasing Treated Water From Another System
 Which Uses Surface Water Sources or Groundwater Sources Under The Influence of Surface Water

PUBLIC WATER SYSTEM NAME: **City of Rollingwood**

System I.D. #: 2270016

Month: **March 2024**

Submitted by:

Date:

No. of Connections: **537**

License #:

Grade:

TREATED WATER PURCHASED FROM A WHOLESALE SUPPLIER				
Date	Quantity (mgd)	Date	Quantity (mgd)	Monthly Summary (mgd)
1	0.276	16	0.216	Total
2	0.276	17	0.215	
3	0.276	18	0.241	Monthly Purchase: 9.896
4	0.374	19	0.244	
5	0.348	20	0.237	Average Daily: 0.319
6	0.477	21	0.264	
7	0.330	22	0.375	Maximum Daily: 0.478
8	0.292	23	0.373	
9	0.291	24	0.374	Minimum Daily: 0.214
10	0.293	25	0.365	
11	0.443	26	0.373	
12	0.347	27	0.338	
13	0.478	28	0.299	
14	0.360	29	0.298	
15	0.214	30	0.299	
		31	0.298	

DISTRIBUTION SYSTEM (DISINFECTANT RESIDUAL MONITORING)			
Minimum allowable disinfectant residual:	<u>0.5</u> mg/L	Percentage of the measurements below the limit this month:	
Total no. of measurements this month:	<u>29</u>	<input type="text" value="0%"/>	(1A)
No. of measurements below the limit:	<u>0</u>		
Percentage of the measurements below the limit last month:		<input type="text" value="0%"/>	(1B)

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATION	Yes/No	If YES, Date when Notice was Given to the:	
		TCEQ	Customers*
More than 5.0% of the disinfectant residuals in the distribution system below acceptable levels for two consecutive months? - see (1A) and (1B)	NO		

* A sample copy of the Notice to the customers must accompany this report.

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **March 2024**

LOCATION: **Bee Cave Woods**

I.D. #: **2270016**

		METER #07914810	SIZE 6"	METER #18713312	SIZE 3"	TOTAL FLOW	TOTAL GAL PURCHASED	CHLORINE RESIDUAL
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL	MG	mg/L
Fri	1	21242	186.0	10330	62.0	248.0	0.276	2.4
Sat	2	21428	187.0	10392	61.0	248.0	0.276	2.6
Sun	3	21615	186.0	10453	62.0	248.0	0.276	2.3
Mon	4	21801	274.0	10515	66.0	340.0	0.374	2.4
Tue	5	22075	248.0	10581	61.0	309.0	0.348	2.7
Wed	6	22323	369.0	10642	78.0	447.0	0.477	2.7
Thu	7	22692	232.0	10720	64.0	296.0	0.330	2.4
Fri	8	22924	212.0	10784	53.0	265.0	0.292	2.4
Sat	9	23136	212.0	10837	52.0	264.0	0.291	3.0
Sun	10	23348	212.0	10889	53.0	265.0	0.293	2.5
Mon	11	23560	346.0	10942	69.0	415.0	0.443	2.6
Tue	12	23906	281.0	11011	56.0	337.0	0.347	
Wed	13	24187	419.0	11067	53.0	472.0	0.478	2.6
Thu	14	24606	298.0	11120	62.0	360.0	0.360	2.5
Fri	15	24904	168.0	11182	47.0	215.0	0.214	2.5
Sat	16	25072	169.0	11229	47.0	216.0	0.216	2.4
Sun	17	25241	169.0	11276	47.0	216.0	0.215	2.3
Mon	18	25410	196.0	11323	46.0	242.0	0.241	2.5
Tue	19	25606	171.0	11369	74.0	245.0	0.244	2.6
Wed	20	25777	168.0	11443	70.0	238.0	0.237	2.4
Thu	21	25945	189.0	11513	73.0	262.0	0.264	2.4
Fri	22	26134	317.0	11586	58.0	375.0	0.375	2.2
Sat	23	26451	316.0	11644	57.0	373.0	0.373	2.3
Sun	24	26767	316.0	11701	58.0	374.0	0.374	2.4
Mon	25	27083	322.0	11759	43.0	365.0	0.365	2.4
Tue	26	27405	318.0	11802	57.0	375.0	0.373	2.6
Wed	27	27723	265.0	11859	67.0	332.0	0.338	2.3
Thu	28	27988	244.0	11926	55.0	299.0	0.305	2.3
Fri	29	28232	244.0	11981	54.0	298.0	0.304	2.2
Sat	30	28476	244.0	12035	55.0	299.0	0.299	
Sun	31	28720	244.0	12090	54.0	298.0	0.298	2.5
Sat	1	28964		12144				
Total			7722.0		1814.0	9536.0	9.9	
Avg.			249.1		58.5	307.6	0.319	2.5
Max.			419.0		78.0	472.0	0.478	3.0
Min.			168.0		43.0	215.0	0.214	2.2

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **March 2024**

LOCATION: **Riley MM**

I.D. #: **2270016**

DAY	DATE	METER	SIZE	METER	SIZE	TOTAL
		No S/N	6"	No S/N	3"	FLOW
		A	TH GAL	B	TH GAL	TH GAL
Fri	1	3554	0.0	21178	28.0	28.0
Sat	2	3554	0.0	21206	28.0	28.0
Sun	3	3554	0.0	21234	28.0	28.0
Mon	4	3554	0.0	21262	34.0	34.0
Tue	5	3554	6.0	21296	33.0	39.0
Wed	6	3560	0.0	21329	30.0	30.0
Thu	7	3560	6.0	21359	28.0	34.0
Fri	8	3566	1.0	21387	26.0	27.0
Sat	9	3567	1.0	21413	26.0	27.0
Sun	10	3568	2.0	21439	26.0	28.0
Mon	11	3570	1.0	21465	27.0	28.0
Tue	12	3571	0.0	21492	10.0	10.0
Wed	13	3571	5.0	21502	1.0	6.0
Thu	14	3576	0.0	21503	0.0	0.0
Fri	15	3576	0.0	21503	0.0	0.0
Sat	16	3576	1.0	21503	0.0	1.0
Sun	17	3577	1.0	21503	0.0	1.0
Mon	18	3578	0.0	21503	0.0	0.0
Tue	19	3578	1.0	21503	0.0	1.0
Wed	20	3579	0.0	21503	0.0	0.0
Thu	21	3579	2.0	21503	0.0	2.0
Fri	22	3581	0.0	21503	0.0	0.0
Sat	23	3581	1.0	21503	0.0	1.0
Sun	24	3582	1.0	21503	0.0	1.0
Mon	25	3583	0.0	21503	0.0	0.0
Tue	26	3583	0.0	21503	0.0	0.0
Wed	27	3583	0.0	21503	6.0	6.0
Thu	28	3583	0.0	21509	0.0	0.0
Fri	29	3583	0.0	21509	0.0	0.0
Sat	30	3583	0.0	21509	0.0	0.0
Sun	31	3583	0.0	21509	0.0	0.0
Mon	1	3583		21509		
Total			29.0		331.0	360.0
Avg.			0.9		10.7	11.6
Max.			6.0		34.0	39.0
Min.			0.0		0.0	0.0

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **March 2024**

LOCATION: **Hatley MM**

I.D. #: **2270016**

		METER No S/n	SIZE 6"	METER #151074A	SIZE 3"	TOTAL FLOW
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL
Fri	1	90	0.0	7496	0.0	0.0
Sat	2	90	0.0	7496	0.0	0.0
Sun	3	90	0.0	7496	0.0	0.0
Mon	4	90	0.0	7496	0.0	0.0
Tue	5	90	0.0	7496	0.0	0.0
Wed	6	90	0.0	7496	0.0	0.0
Thu	7	90	0.0	7496	0.0	0.0
Fri	8	90	0.0	7496	0.0	0.0
Sat	9	90	0.0	7496	0.0	0.0
Sun	10	90	0.0	7496	0.0	0.0
Mon	11	90	0.0	7496	0.0	0.0
Tue	12	90	0.0	7496	0.0	0.0
Wed	13	90	0.0	7496	0.0	0.0
Thu	14	90	0.0	7496	0.0	0.0
Fri	15	90	0.0	7496	1.0	1.0
Sat	16	90	0.0	7497	1.0	1.0
Sun	17	90	0.0	7498	2.0	2.0
Mon	18	90	0.0	7500	1.0	1.0
Tue	19	90	0.0	7501	2.0	2.0
Wed	20	90	0.0	7503	1.0	1.0
Thu	21	90	0.0	7504	0.0	0.0
Fri	22	90	0.0	7504	0.0	0.0
Sat	23	90	0.0	7504	1.0	1.0
Sun	24	90	0.0	7505	1.0	1.0
Mon	25	90	0.0	7506	0.0	0.0
Tue	26	90	0.0	7506	2.0	2.0
Wed	27	90	0.0	7508	0.0	0.0
Thu	28	90	0.0	7508	0.0	0.0
Fri	29	90	0.0	7508	0.0	0.0
Sat	30	90	0.0	7508	0.0	0.0
Sun	31	90	0.0	7508	0.0	0.0
Mon	1	90		7508		
Total			0.0		12.0	12.0
Avg.			0.0		0.4	0.4
Max.			0.0		2.0	2.0
Min.			0.0		0.0	0.0

Operator: _____