

Complained about August and September bills

Reported no leak

10/15/2019

Meter was swapped out and sent for testing.

10-24/2019

Email was sent to Mr. Attal, stating that the meter tested and measured at 98.5% and above for accuracy purposes. This means the meter was and is accurate and meets American Water Works Association standards.

Mr. Attal selected to appeal his bill to the Utility Commission.