

FMS

FLUID METER SERVICE, CORP.

FMS (800) 944-4472
(512) 258-3594 Tel.
(512) 258-4386 Fax

Gary Faber - C.E.O.
512-426-4035 Mobile
Email fluidmeter1@aol.com

SALES • REPAIR • TESTING • CALIBRATION
METERS • CONTROL VALVES • BACKFLOW PREVENTERS

P.O. Box 340215
Austin, TX 78734-0215

7304 McNeil Dr., #604
Austin, TX 78729

TO: City of Rollingwood

DATE: 10-17-2019

SIZE: 5/8" x 3/4" MAKE: Badger TYPE: C-700

2612 Rollingwood Dr
METER LOCATION

METER# 44572481
Read: 0900750
BEFORE: _____

P.O.# _____ W.O.# _____ FMS ORDER # _____

QUANTITY	DESCRIPTION	PRICE
1	AWWA Standard Shop test	
note	meter meets AWWA standards	☒ yes ☐ no

CERTIFICATE OF CALIBRATION

This is to certify that the physical standards described below were on this day compared to the standards of the state of Texas which are directly traceable to standards of the National Bureau of Standards [NBS Test-No.'s 39569,40093,179355,225713] A.W.W.A Test.

DETAILS OF TEST

LINE NO.	CUFF GALS.	RATE OF FLOW G.P.M.	TOTAL CUFF GALS.	% OF ACCURACY	CORRECTED % OF ACCURACY
1	10	1/4	9.9	99.0 %	
2	10	2	10.0	100.0 %	
3	100	15	98.5	98.5 %	

SIGNATURE: _____

[Signature]