



OPERATOR'S REPORT

City of Rollingwood



December 15, 2021



MEMORANDUM

To: Ms. Ashley Wayman, Assistant City Administrator, City of Rollingwood
From: Andrew Hunt, Crossroads Utility Services LLC
Subject: Monthly Report
Date: 12/7/21

Previous Directives

Current Operations Report

I. Utility Operations Report

A. Billing Report/ Water Accountability – Please see enclosed water operations report

- a. Bac-t samples have been pulled for November 2021 – all clean samples

B. Water System Operations and Maintenance –

- a. We completed three hydrant replacements in November (Wallis/Hatley, Wallis/Rollingwood and 2800 Pickwick)
- b. We troubleshot pressure reducing valve issues along Hatley. Repairs will be needed.
- c. We assisted City staff with locating and updating the valve maps based on information provided from the ME Simpson survey

C. Wastewater Collection System Operations and Maintenance -

- a. Water line repair 404 Wallis completed
- b. Repaired water line break 2410 Vance
- c. Replaced a broken curbstop at 3 Westgate Cr
- d. Water Line repaired at Nixon/Park Hills
- e. Replaced meters for 3003 Bee Caves and 3001 Bee Caves Rd

D. Lift Station Maintenance – *See enclosed report*

II. Customer Service Issues– No reported issues

III. Emergency Response Items –We are coordinating with the SitePro improvements at each Lift Station. Training is schedule for 12/10/21

IV. Drought Contingency Plan / Watering Restrictions

- a. Lake Travis Level - 662.33 – Current Storage 801,193 acre-feet (72% full)
 - b. The City of Austin is currently in Conservation Stage watering restrictions – (twice per week watering)
- V. **COVID-19** –Crossroads is currently in “Normal” operations phase with all of its operational resources reporting (Phase 1 out of 4).



MEMORANDUM

To: Ms. Amber Lewis, City Administrator, City of Rollingwood
From: Andrew Hunt, Crossroads Utility Services LLC
Subject: Lift Station Report Detail
Date: 12/7/21

1. Lift Station 1 – Dellana Ln.
 - No reported alarms
2. Lift Station 2 – Hatley Dr.
 - No reported alarms
3. Lift Station 3 – Almarion Way
 - Cleaned lift station wet well
 - Repaired dialer
4. Lift Station 4- Rockway Cv.
 - No reported alarms
5. Lift Station 5 – Vale Dr.
 - No reported alarms
6. Lift Station 6 – Pleasant Cv.
 - No reported alarms
7. Lift Station 7 – Nixon Dr.
 - No reported alarms

Monthly Operational Report For Public Water Systems Purchasing Treated Water From Another System
 Which Uses Surface Water Sources or Groundwater Sources Under The Influence of Surface Water

PUBLIC WATER SYSTEM NAME: **City of Rollingwood**

System I.D. #: 2270016

Month: **November 2021**

Submitted by:

Date:

No. of Connections: **537**

License #:

Grade:

TREATED WATER PURCHASED FROM A WHOLESALE SUPPLIER				
Date	Quantity (mgd)	Date	Quantity (mgd)	Monthly Summary (mgd)
1	0.180	16	0.363	Total
2	0.182	17	0.338	
3	0.616	18	0.342	Monthly Purchase: 9.343
4	0.285	19	0.281	
5	0.303	20	0.282	Average Daily: 0.311
6	0.300	21	0.283	
7	0.299	22	0.322	Maximum Daily: 0.616
8	0.289	23	0.323	
9	0.369	24	0.264	Minimum Daily: 0.173
10	0.173	25	0.264	
11	0.173	26	0.264	
12	0.444	27	0.264	
13	0.445	28	0.265	
14	0.446	29	0.311	
15	0.362	30	0.314	

DISTRIBUTION SYSTEM (DISINFECTANT RESIDUAL MONITORING)			
Minimum allowable disinfectant residual:	<u>0.5</u> mg/L	Percentage of the measurements below the limit this month:	
Total no. of measurements this month:	<u> </u>	<input type="text" value="0%"/>	(1A)
No. of measurements below the limit:	<u>0</u>		
Percentage of the measurements below the limit last month:		<input type="text" value="0%"/>	(1B)

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATION	Yes/No	If YES, Date when Notice was Given to the:	
		TCEQ	Customers*
More that 5.0% of the disinfectant residuals in the distribution system below acceptable levels for two consecutive months? - see (1A) and (1B)	NO		

* A sample copy of the Notice to the customers must accompany this report.

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **November 2021**

LOCATION: **Bee Cave Woods**

I.D. #: **2270016**

		METER #07914810	SIZE 6"	METER #18713312	SIZE 3"	TOTAL FLOW	TOTAL GAL PURCHASED	CHLORINE RESIDUAL
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL	MG	mg/L
Mon	1	801471	107.0	39596	73.0	180.0	0.180	2.2
Tue	2	801578	108.0	39669	74.0	182.0	0.182	2.5
Wed	3	801686	298.0	39743	318.0	616.0	0.616	2.1
Thu	4	801984	121.0	40061	164.0	285.0	0.285	2.6
Fri	5	802105	136.0	40225	167.0	303.0	0.303	2.5
Sat	6	802241	136.0	40392	167.0	303.0	0.300	2.0
Sun	7	802377	136.0	40559	167.0	303.0	0.299	2.2
Mon	8	802513	161.0	40726	128.0	289.0	0.289	2.7
Tue	9	802674	191.0	40854	178.0	369.0	0.369	2.6
Wed	10	802865	90.0	41032	83.0	173.0	0.173	2.0
Thu	11	802955	90.0	41115	83.0	173.0	0.173	2.4
Fri	12	803045	223.0	41198	221.0	444.0	0.444	2.0
Sat	13	803268	224.0	41419	221.0	445.0	0.445	2.8
Sun	14	803492	224.0	41640	222.0	446.0	0.446	2.7
Mon	15	803716	196.0	41862	166.0	362.0	0.362	2.4
Tue	16	803912	197.0	42028	166.0	363.0	0.363	2.3
Wed	17	804109	151.0	42194	151.0	302.0	0.338	2.2
Thu	18	804260	152.0	42345	151.0	303.0	0.342	2.2
Fri	19	804412	91.0	42496	151.0	242.0	0.281	2.7
Sat	20	804503	92.0	42647	151.0	243.0	0.282	2.7
Sun	21	804595	92.0	42798	151.0	243.0	0.283	2.6
Mon	22	804687	150.0	42949	155.0	305.0	0.322	2.1
Tue	23	804837	150.0	43104	155.0	305.0	0.323	2.8
Wed	24	804987	111.0	43259	153.0	264.0	0.264	2.8
Thu	25	805098	111.0	43412	153.0	264.0	0.264	1.8
Fri	26	805209	111.0	43565	153.0	264.0	0.264	2.6
Sat	27	805320	111.0	43718	153.0	264.0	0.264	2.5
Sun	28	805431	111.0	43871	154.0	265.0	0.265	2.5
Mon	29	805542	133.0	44025	176.0	309.0	0.311	2.4
Tue	30	805675	134.0	44201	177.0	311.0	0.311	2.6
Wed	1	805809		44378				
Total			4338.0		4782.0	9120.0	9.3	
Avg.			144.6		159.4	304.0	0.311	2.4
Max.			298.0		318.0	616.0	0.616	2.8
Min.			90.0		73.0	173.0	0.173	1.8

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **November 2021**

LOCATION: **Riley MM**

I.D. #: **2270016**

DAY	DATE	METER SIZE		METER SIZE		TOTAL FLOW
		No S/N	6"	No S/N	3"	
		A	TH GAL	B	TH GAL	TH GAL
Mon	1	437	0.0	137	0.0	0.0
Tue	2	437	0.0	137	0.0	0.0
Wed	3	437	0.0	137	0.0	0.0
Thu	4	437	0.0	137	0.0	0.0
Fri	5	437	0.0	137	0.0	0.0
Sat	6	437	0.0	137	0.0	0.0
Sun	7	437	0.0	137	0.0	0.0
Mon	8	437	0.0	137	0.0	0.0
Tue	9	437	0.0	137	0.0	0.0
Wed	10	437	0.0	137	0.0	0.0
Thu	11	437	0.0	137	0.0	0.0
Fri	12	437	0.0	137	0.0	0.0
Sat	13	437	0.0	137	0.0	0.0
Sun	14	437	0.0	137	0.0	0.0
Mon	15	437	0.0	137	0.0	0.0
Tue	16	437	0.0	137	0.0	0.0
Wed	17	437	1.0	137	36.0	37.0
Thu	18	438	2.0	173	37.0	39.0
Fri	19	440	0.0	210	39.0	39.0
Sat	20	440	0.0	249	39.0	39.0
Sun	21	440	0.0	288	40.0	40.0
Mon	22	440	0.0	328	17.0	17.0
Tue	23	440	0.0	345	18.0	18.0
Wed	24	440	0.0	363	0.0	0.0
Thu	25	440	0.0	363	0.0	0.0
Fri	26	440	0.0	363	0.0	0.0
Sat	27	440	0.0	363	0.0	0.0
Sun	28	440	0.0	363	0.0	0.0
Mon	29	440	0.0	363	2.0	2.0
Tue	30	440	1.0	365	2.0	3.0
Wed	1	441		367		
Total			4.0		230.0	234.0
Avg.			0.1		7.7	7.8
Max.			2.0		40.0	40.0
Min.			0.0		0.0	0.0

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **November 2021**

LOCATION: **Hatley MM**

I.D. #: **2270016**

DAY	DATE	METER	SIZE	METER	SIZE	TOTAL
		No S/n	6"	#151074A	3"	FLOW
		A	TH GAL	B	TH GAL	TH GAL
Mon	1	76	0.0	6786	0.0	0.0
Tue	2	76	0.0	6786	0.0	0.0
Wed	3	76	0.0	6786	0.0	0.0
Thu	4	76	0.0	6786	0.0	0.0
Fri	5	76	0.0	6786	0.0	0.0
Sat	6	76	0.0	6786	3.0	3.0
Sun	7	76	0.0	6789	4.0	4.0
Mon	8	76	0.0	6793	0.0	0.0
Tue	9	76	0.0	6793	0.0	0.0
Wed	10	76	0.0	6793	0.0	0.0
Thu	11	76	0.0	6793	0.0	0.0
Fri	12	76	0.0	6793	0.0	0.0
Sat	13	76	0.0	6793	0.0	0.0
Sun	14	76	0.0	6793	0.0	0.0
Mon	15	76	0.0	6793	0.0	0.0
Tue	16	76	0.0	6793	0.0	0.0
Wed	17	76	0.0	6793	1.0	1.0
Thu	18	76	0.0	6794	0.0	0.0
Fri	19	76	0.0	6794	0.0	0.0
Sat	20	76	0.0	6794	0.0	0.0
Sun	21	76	0.0	6794	0.0	0.0
Mon	22	76	0.0	6794	0.0	0.0
Tue	23	76	0.0	6794	0.0	0.0
Wed	24	76	0.0	6794	0.0	0.0
Thu	25	76	0.0	6794	0.0	0.0
Fri	26	76	0.0	6794	0.0	0.0
Sat	27	76	0.0	6794	0.0	0.0
Sun	28	76	0.0	6794	0.0	0.0
Mon	29	76	0.0	6794	0.0	0.0
Tue	30	76	0.0	6794	0.0	0.0
Wed	1	76		6794		
Total			0.0		8.0	8.0
Avg.			0.0		0.3	0.3
Max.			0.0		4.0	4.0
Min.			0.0		0.0	0.0

Operator: _____