



OPERATOR'S REPORT

City of Rollingwood



April 16, 2025



MEMORANDUM

To: City Administrator, City of Rollingwood
From: Ben Ingallina, Crossroads Utility Services LLC
Subject: Monthly Report
Date: 04/09/2025

Previous Directives

- *No directives*

Current Operations Report

- I. **Utility Operations Report**
 - A. **Billing Report/ Water Accountability** – Please see enclosed water operations report
 - B. **Water System Operations and Maintenance** –
 - a. No items to report
 - C. **Wastewater Collection System Operations and Maintenance** – No items to report
 - D. **Lift Station Maintenance** – *See enclosed report*
- II. **Customer Service Issues** – No reported issues
- III. **Emergency Response Items** – No new items
- IV. **Drought Contingency Plan / Watering Restrictions**
 - a. Lake Travis Level –635.93 Current Storage 461,365 acre-feet (42.0% full) -.9% down from last month.
 - b. The City of Austin is currently in Stage 2 watering restrictions – (Started August 15th 2023)

Lakes Travis and Buchanan, reservoir lakes for the area's water supply, are expected to drop below 900,000 acre-feet.

The City of Austin is currently in **Stage 2 Drought Water Use Restrictions**.

Austin's Stage 2 water restrictions

The City of Austin is currently in **Stage 2 Drought Water Use Restrictions**.

- ***Residential***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - Even address - Sunday
 - Odd address - Saturday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - Even address - Thursday
 - Odd address - Wednesday
- ***Commercial / Multi-family***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - Even address - Tuesday
 - Odd address – Friday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - Even address - Tuesday
 - Odd address - Friday
- ***Public Schools***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - All addresses - Monday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - All addresses - Monday
- **Wasting water** is prohibited.

- Washing vehicles at home is permitted with a bucket.
- Charity car washes prohibited.
- Fountains must recirculate water and those with a 4-inch emission or fall of water are prohibited.
- Fountains with a greater than 4-inch emission or fall of water are prohibited
- Restaurants may not serve water unless requested by a customer.
- Patio misters at commercial properties (*including restaurants and bars*) may only operate between 4 p.m. and midnight.
- **Commercial power/pressure washing equipment** must meet efficiency requirements.
- Golf courses using potable water can only irrigate fairways on their watering day; tees and greens can be watered every other day if Austin Water is notified.
- Irrigation of golf course fairways allowed between midnight and 5:00 a.m. or between 7:00 p.m. and midnight on designated outdoor water-use days only
- Irrigation of golf course greens or tees allowed every other day with notice to and approval by Austin Water only



MEMORANDUM

To: City of Rollingwood
From: Ben Ingallina, Crossroads Utility Services LLC
Subject: Lift Station Report Detail
Date: 04/09/2025

Lift Station 1 – Dellana Ln.

- No issues.

Lift Station 2 – Hatley Dr.

- No issues.

Lift Station 3 – Almarion Way

- No issues.

Lift Station 4- Rockway Cv.

- No issues.

Lift Station 5 – Vale Dr.

- No issues.

Lift Station 6 – Pleasant Cv.

- No issues.

Lift Station 7 – Nixon Dr.

- No issues.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
Water Utilities Division

Monthly Operational Report For Public Water Systems Purchasing Treated Water From Another System
Which Uses Surface Water Sources or Groundwater Sources Under The Influence of Surface Water

PUBLIC WATER SYSTEM NAME: **City of Rollingwood**

System I.D. #: 2270016

Month: **March 2025**

Submitted by:

Date:

No. of Connections: **537**

License #:

Grade:

TREATED WATER PURCHASED FROM A WHOLESALE SUPPLIER				
Date	Quantity (mgd)	Date	Quantity (mgd)	Monthly Summary (mgd)
1	0.298	16	0.323	Total
2	0.298	17	0.356	Monthly
3	0.298	18	0.403	Purchase: 10.107
4	0.227	19	0.412	
5	0.364	20	0.407	Average
6	0.338	21	0.328	Daily: 0.326
7	0.290	22	0.329	
8	0.290	23	0.329	Maximum
9	0.291	24	0.291	Daily: 0.808
10	0.366	25	0.366	
11	0.384	26	0.299	Minimum
12	0.808	27	0.240	Daily: 0.086
13	0.086	28	0.239	
14	0.296	29	0.239	
15	0.322	30	0.238	
		31	0.352	

DISTRIBUTION SYSTEM			
(DISINFECTANT RESIDUAL MONITORING)			
Minimum allowable disinfectant residual:	0.5	mg/L	Percentage of the measurements below the limit this month:
Total no. of measurements this month:	32		0% (1A)
No. of measurements below the limit:	0		
Percentage of the measurements below the limit last month:			0% (1B)

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATION	Yes/No	If YES, Date when Notice was Given to the:	
		TCEQ	Customers*
More than 5.0% of the disinfectant residuals in the distribution system below acceptable levels for two consecutive months? - see (1A) and (1B)	NO		

* A sample copy of the Notice to the customers must accompany this report.

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **March 2025**

LOCATION: **Bee Cave Woods**

I.D. #: **2270016**

		METER #07914810	SIZE 6"	METER #18713312	SIZE 3"	TOTAL FLOW	TOTAL GAL PURCHASED	CHLORINE RESIDUAL
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL	MG	mg/L
Sat	1	152263	208.0	34466	90.0	298.0	0.298	2.4
Sun	2	152471	208.0	34556	90.0	298.0	0.298	2.9
Mon	3	152679	207.0	34646	91.0	298.0	0.298	2.5
Tue	4	152886	168.0	34737	59.0	227.0	0.227	2.6
Wed	5	153054	267.0	34796	97.0	364.0	0.364	2.5
Thu	6	153321	258.0	34893	80.0	338.0	0.338	2.6
Fri	7	153579	210.0	34973	80.0	290.0	0.290	2.7
Sat	8	153789	209.0	35053	81.0	290.0	0.290	1.1
Sun	9	153998	210.0	35134	81.0	291.0	0.291	1.5
Mon	10	154208	282.0	35215	84.0	366.0	0.366	2.4
Tue	11	154490	307.0	35299	77.0	384.0	0.384	2.5
Wed	12	154797	718.0	35376	90.0	808.0	0.808	2.4
Thu	13	155515	0.0	35466	86.0	86.0	0.086	2.6
Fri	14	155515	214.0	35552	82.0	296.0	0.296	2.4
Sat	15	155729	240.0	35634	82.0	322.0	0.322	2.9
Sun	16	155969	240.0	35716	83.0	323.0	0.323	1.7
Mon	17	156209	274.0	35799	82.0	356.0	0.356	2.3
Tue	18	156483	319.0	35881	84.0	403.0	0.403	2.4
Wed	19	156802	328.0	35965	84.0	412.0	0.412	2.7
Thu	20	157130	326.0	36049	81.0	407.0	0.407	2.3
Fri	21	157456	244.0	36130	84.0	328.0	0.328	2.6
Sat	22	157700	244.0	36214	85.0	329.0	0.329	2.6
Sun	23	157944	244.0	36299	85.0	329.0	0.329	2.5
Mon	24	158188	214.0	36384	77.0	291.0	0.291	2.4
Tue	25	158402	282.0	36461	84.0	366.0	0.366	2.6
Wed	26	158684	214.0	36545	85.0	299.0	0.299	2.6
Thu	27	158898	158.0	36630	82.0	240.0	0.240	2.3
Fri	28	159056	160.0	36712	79.0	239.0	0.239	2.6
Sat	29	159216	159.0	36791	80.0	239.0	0.239	2.4
Sun	30	159375	159.0	36871	79.0	238.0	0.238	2.5
Mon	31	159534	265.0	36950	87.0	352.0	0.352	
Tue	1	159799		37037				
Total			7536.0	27140.0	2571.0	10107.0	10.1	
Avg.			243.1		82.9	326.0	0.326	2.4
Max.			718.0		97.0	808.0	0.808	2.9
Min.			0.0		59.0	86.0	0.086	1.1

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **March 2025**

LOCATION: **Hatley MM**

I.D. #: **2270016**

		METER No S/n	SIZE 6"	METER #151074A	SIZE 3"	TOTAL FLOW
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL
Sat	1	92	0.0	7547	0.0	0.0
Sun	2	92	0.0	7547	0.0	0.0
Mon	3	92	0.0	7547	0.0	0.0
Tue	4	92	0.0	7547	0.0	0.0
Wed	5	92	0.0	7547	0.0	0.0
Thu	6	92	0.0	7547	0.0	0.0
Fri	7	92	0.0	7547	0.0	0.0
Sat	8	92	0.0	7547	0.0	0.0
Sun	9	92	0.0	7547	0.0	0.0
Mon	10	92	0.0	7547	0.0	0.0
Tue	11	92	0.0	7547	0.0	0.0
Wed	12	92	0.0	7547	0.0	0.0
Thu	13	92	0.0	7547	0.0	0.0
Fri	14	92	0.0	7547	0.0	0.0
Sat	15	92	0.0	7547	0.0	0.0
Sun	16	92	0.0	7547	0.0	0.0
Mon	17	92	0.0	7547	0.0	0.0
Tue	18	92	0.0	7547	0.0	0.0
Wed	19	92	0.0	7547	0.0	0.0
Thu	20	92	0.0	7547	0.0	0.0
Fri	21	92	0.0	7547	0.0	0.0
Sat	22	92	0.0	7547	0.0	0.0
Sun	23	92	0.0	7547	0.0	0.0
Mon	24	92	0.0	7547	0.0	0.0
Tue	25	92	0.0	7547	0.0	0.0
Wed	26	92	0.0	7547	0.0	0.0
Thu	27	92	0.0	7547	0.0	0.0
Fri	28	92	0.0	7547	0.0	0.0
Sat	29	92	0.0	7547	0.0	0.0
Sun	30	92	0.0	7547	0.0	0.0
Mon	31	92	0.0	7547	0.0	0.0
Tue	1	92		7547		
Total			0.0		0.0	0.0
Avg.			0.0		0.0	0.0
Max.			0.0		0.0	0.0
Min.			0.0		0.0	0.0

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **March 2025**

LOCATION: **Riley MM**

I.D. #: **2270016**

		METER No S/N	SIZE 6"	METER No S/N	SIZE 3"	TOTAL FLOW
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL
Sat	1	3619	0.0	21519	0.0	0.0
Sun	2	3619	0.0	21519	0.0	0.0
Mon	3	3619	0.0	21519	0.0	0.0
Sat	4	3619	0.0	21519	0.0	0.0
Sun	5	3619	0.0	21519	0.0	0.0
Mon	6	3619	0.0	21519	0.0	0.0
Tue	7	3619	0.0	21519	0.0	0.0
Wed	8	3619	0.0	21519	0.0	0.0
Thu	9	3619	0.0	21519	0.0	0.0
Fri	10	3619	0.0	21519	0.0	0.0
Sat	11	3619	0.0	21519	0.0	0.0
Sun	12	3619	0.0	21519	0.0	0.0
Mon	13	3619	0.0	21519	0.0	0.0
Tue	14	3619	0.0	21519	0.0	0.0
Wed	15	3619	0.0	21519	0.0	0.0
Thu	16	3619	0.0	21519	0.0	0.0
Fri	17	3619	0.0	21519	0.0	0.0
Sat	18	3619	0.0	21519	0.0	0.0
Sun	19	3619	0.0	21519	0.0	0.0
Mon	20	3619	0.0	21519	0.0	0.0
Tue	21	3619	0.0	21519	0.0	0.0
Wed	22	3619	0.0	21519	0.0	0.0
Thu	23	3619	0.0	21519	0.0	0.0
Fri	24	3619	0.0	21519	0.0	0.0
Sat	25	3619	0.0	21519	0.0	0.0
Sun	26	3619	0.0	21519	0.0	0.0
Mon	27	3619	0.0	21519	0.0	0.0
Tue	28	3619	0.0	21519	0.0	0.0
Wed	29	3619	0.0	21519	0.0	0.0
Thu	30	3619	0.0	21519	0.0	0.0
Fri	31	3619	0.0	21519	0.0	0.0
Sat	1	3619		21519		
Total			0.0		0.0	0.0
Avg.			0.0		0.0	0.0
Max.			0.0		0.0	0.0
Min.			0.0		0.0	0.0

Operator: _____