



OPERATOR'S REPORT

City of Rollingwood



November 16, 2022



MEMORANDUM

To: Ms. Ashley Wayman, City Administrator, City of Rollingwood
From: Andrew Hunt, Crossroads Utility Services LLC
Subject: Monthly Report
Date: 11/3/22

Previous Directives

- *No directives*

Current Operations Report

I. **Utility Operations Report**

A. **Billing Report/ Water Accountability** – Please see enclosed water operations report

- a. Bac-t samples have been pulled for October 2022 – all clean samples

B. **Water System Operations and Maintenance** –

- a. 2600 Hatley – We repaired a pin hole leak in the main
- b. 5015 Timberline – Responded to damaged waterline
- c. 1003 Ewing- We repaired a 1" service line.

C. **Wastewater Collection System Operations and Maintenance** -

- a. No issues

D. **Lift Station Maintenance** – *See enclosed report*

II. **Customer Service Issues** – No reported issues

III. **Emergency Response Items** – No new items. We are awaiting the plan for generator installations at the lift stations.

IV. **Drought Contingency Plan / Watering Restrictions**

- a. Lake Travis Level – 640.36 – Current Storage 524,235 acre-feet (46% full)
- b. The City of Austin is currently in Stage 1 watering restrictions – (twice per week watering)

City of Austin Stage 1 Restrictions – effective June 6, 2022

As a result of the combined storage in Lake Travis and Lake Buchanan falling below 1.4 million acre-feet, the City of Austin has implemented Drought Stage One Regulations of its Drought Contingency Plan effective June 6, 2022.

The City of Austin is currently in **Stage 1 Drought Water Use Restrictions**.

- Residential
 - **Hose-end Sprinklers** - two days per week - midnight to 8 a.m. and/or 7 p.m. to midnight
 - **Even address** - Thursday, Sunday
 - **Odd address** - Wednesday, Saturday
 - **Automatic Irrigation** - one day per week - midnight to 8 a.m. and/or 7 p.m. to midnight (*Residential customers may also water a second day with a hose-end sprinkler*)
 - **Even address** - Thursday
 - **Odd address** - Wednesday
 - **Commercial / Multi-family / Public Schools**
 - **Hose-end Sprinklers or Automatic Irrigation** - one day per week - midnight to 8 a.m. and/or 7 p.m. to midnight
 - **Even address** - Tuesday
 - **Odd address** - Friday
- **Wasting water** is prohibited
- Washing vehicles at home is permitted with an auto shut-off hose or bucket
- Charity car washes may only be held at a commercial car wash
- Fountains must recirculate water
- Restaurants may not serve water unless requested by a customer
- Patio misters at commercial properties (*including restaurants and bars*) may only operate between 4 p.m. and midnight
- **Commercial power/pressure washing equipment** must meet efficiency requirements



MEMORANDUM

To: Ms. Ashley Wayman, City of Rollingwood
From: Andrew Hunt, Crossroads Utility Services LLC
Subject: Lift Station Report Detail
Date: 11/3/22

1. Lift Station 1 – Dellana Ln.
 - No issues to report
1. Lift Station 2 – Hatley Dr.
 - Trouble shot an issue related to the transducer
 - Ordered new backup dailer – dailer control board was shutting down intermittently
1. Lift Station 3 – Almarion Way
 - No issues to report
1. Lift Station 4- Rockway Cv.
 - Phone line issue reported to ATT
2. Lift Station 5 – Vale Dr.
 - No issues to report
3. Lift Station 6 – Pleasant Cv.
 - No issues to report
4. Lift Station 7 – Nixon Dr.
 - No issues to report

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
Water Utilities Division

Monthly Operational Report For Public Water Systems Purchasing Treated Water From Another System
Which Uses Surface Water Sources or Groundwater Sources Under The Influence of Surface Water

PUBLIC WATER SYSTEM NAME: **City of Rollingwood**

System I.D. #: 2270016

Month: **October 2022**

Submitted by:

Date:

No. of Connections: **537**

License #:

Grade:

TREATED WATER PURCHASED FROM A WHOLESALE SUPPLIER				
Date	Quantity (mgd)	Date	Quantity (mgd)	Monthly Summary (mgd)
1	0.542	16	0.457	Total
2	0.542	17	0.415	Monthly
3	0.570	18	0.424	Purchase: 16.163
4	0.683	19	0.410	
5	0.700	20	0.948	Average
6	0.614	21	0.438	Daily: 0.521
7	0.516	22	0.440	
8	0.516	23	0.441	Maximum
9	0.517	24	0.430	Daily: 0.948
10	0.579	25	0.430	
11	0.655	26	0.551	Minimum
12	0.716	27	0.432	Daily: 0.366
13	0.711	28	0.375	
14	0.455	29	0.375	
15	0.457	30	0.376	
		31	0.475	

DISTRIBUTION SYSTEM			
(DISINFECTANT RESIDUAL MONITORING)			
Minimum allowable disinfectant residual:	0.5	mg/L	Percentage of the measurements below the limit this month:
Total no. of measurements this month:	32		0% (1A)
No. of measurements below the limit:	0		
Percentage of the measurements below the limit last month:			0% (1B)

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATION	Yes/No	If YES, Date when Notice was Given to the:	
		TCEQ	Customers*
More than 5.0% of the disinfectant residuals in the distribution system below acceptable levels for two consecutive months? - see (1A) and (1B)	NO		

* A sample copy of the Notice to the customers must accompany this report.

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **October 2022**

LOCATION: **Bee Cave Woods**

I.D. #: **2270016**

		METER #07914810	SIZE 6"	METER #18713312	SIZE 3"	TOTAL FLOW	TOTAL GAL PURCHASED	CHLORINE RESIDUAL
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL	MG	mg/L
Sat	1	890849	370.0	92143	148.0	518.0	0.542	2.3
Sun	2	891219	370.0	92291	148.0	518.0	0.542	2.4
Mon	3	891589	401.0	92439	148.0	549.0	0.570	2.1
Tue	4	891990	528.0	92587	143.0	671.0	0.683	2.2
Wed	5	892518	527.0	92730	157.0	684.0	0.700	1.9
Thu	6	893045	469.0	92887	129.0	598.0	0.614	2.1
Fri	7	893514	352.0	93016	148.0	500.0	0.516	2.1
Sat	8	893866	352.0	93164	148.0	500.0	0.516	2.2
Sun	9	894218	352.0	93312	149.0	501.0	0.517	2.1
Mon	10	894570	415.0	93461	157.0	572.0	0.579	2.1
Tue	11	894985	505.0	93618	144.0	649.0	0.655	2.1
Wed	12	895490	542.0	93762	153.0	695.0	0.716	2.3
Thu	13	896032	556.0	93915	144.0	700.0	0.711	2.2
Fri	14	896588	278.0	94059	157.0	435.0	0.455	2.1
Sat	15	896866	279.0	94216	158.0	437.0	0.457	2.0
Sun	16	897145	279.0	94374	158.0	437.0	0.457	2.0
Mon	17	897424	257.0	94532	147.0	404.0	0.415	2.2
Tue	18	897681	254.0	94679	166.0	420.0	0.424	2.2
Wed	19	897935	255.0	94845	150.0	405.0	0.410	2.5
Thu	20	898190	690.0	94995	224.0	914.0	0.948	2.3
Fri	21	898880	300.0	95219	117.0	417.0	0.438	2.3
Sat	22	899180	301.0	95336	117.0	418.0	0.440	2.5
Sun	23	899481	301.0	95453	118.0	419.0	0.441	2.5
Mon	24	899782	270.0	95571	157.0	427.0	0.430	2.1
Tue	25	900052	268.0	95728	147.0	415.0	0.430	2.3
Wed	26	900320	411.0	95875	134.0	545.0	0.551	2.2
Thu	27	900731	266.0	96009	156.0	422.0	0.432	2.1
Fri	28	900997	208.0	96165	148.0	356.0	0.366	2.2
Sat	29	901205	208.0	96313	148.0	356.0	0.366	2.7
Sun	30	901413	208.0	96461	149.0	357.0	0.367	2.3
Mon	31	901621	309.0	96610	149.0	458.0	0.475	2.3
Tue	1	901930		96759				
Total			11081.0		4616.0	15697.0	16.2	
Avg.			357.5		148.9	506.4	0.521	2.2
Max.			690.0		224.0	914.0	0.948	2.7
Min.			208.0		117.0	356.0	0.366	1.9

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **October 2022**

LOCATION: **Riley MM**

I.D. #: **2270016**

		METER No S/N	SIZE 6"	METER No S/N	SIZE 3"	TOTAL FLOW
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL
Sat	1	471	0.0	3421	24.0	24.0
Sun	2	471	0.0	3445	24.0	24.0
Mon	3	471	0.0	3469	21.0	21.0
Tue	4	471	0.0	3490	12.0	12.0
Wed	5	471	0.0	3502	16.0	16.0
Thu	6	471	0.0	3518	16.0	16.0
Fri	7	471	0.0	3534	16.0	16.0
Sat	8	471	0.0	3550	16.0	16.0
Sun	9	471	0.0	3566	16.0	16.0
Mon	10	471	0.0	3582	7.0	7.0
Tue	11	471	0.0	3589	6.0	6.0
Wed	12	471	0.0	3595	21.0	21.0
Thu	13	471	0.0	3616	11.0	11.0
Fri	14	471	0.0	3627	20.0	20.0
Sat	15	471	0.0	3647	20.0	20.0
Sun	16	471	0.0	3667	20.0	20.0
Mon	17	471	0.0	3687	11.0	11.0
Tue	18	471	0.0	3698	4.0	4.0
Wed	19	471	0.0	3702	5.0	5.0
Thu	20	471	0.0	3707	34.0	34.0
Fri	21	471	0.0	3741	21.0	21.0
Sat	22	471	0.0	3762	22.0	22.0
Sun	23	471	0.0	3784	22.0	22.0
Mon	24	471	0.0	3806	3.0	3.0
Tue	25	471	0.0	3809	15.0	15.0
Wed	26	471	0.0	3824	6.0	6.0
Thu	27	471	0.0	3830	10.0	10.0
Fri	28	471	0.0	3840	19.0	19.0
Sat	29	471	0.0	3859	19.0	19.0
Sun	30	471	0.0	3878	19.0	19.0
Mon	31	471	0.0	3897	17.0	17.0
Tue	1	471		3914		
Total			0.0		493.0	493.0
Avg.			0.0		15.9	15.9
Max.			0.0		34.0	34.0
Min.			0.0		3.0	3.0

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **October 2022**

LOCATION: **Hatley MM**

I.D. #: **2270016**

		METER No S/n	SIZE 6"	METER #151074A	SIZE 3"	TOTAL FLOW
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL
Sat	1	78	0.0	6826	0.0	0.0
Sun	2	78	0.0	6826	0.0	0.0
Mon	3	78	0.0	6826	0.0	0.0
Tue	4	78	0.0	6826	0.0	0.0
Wed	5	78	0.0	6826	0.0	0.0
Thu	6	78	0.0	6826	0.0	0.0
Fri	7	78	0.0	6826	0.0	0.0
Sat	8	78	0.0	6826	0.0	0.0
Sun	9	78	0.0	6826	0.0	0.0
Mon	10	78	0.0	6826	0.0	0.0
Tue	11	78	0.0	6826	0.0	0.0
Wed	12	78	0.0	6826	0.0	0.0
Thu	13	78	0.0	6826	0.0	0.0
Fri	14	78	0.0	6826	0.0	0.0
Sat	15	78	0.0	6826	0.0	0.0
Sun	16	78	0.0	6826	0.0	0.0
Mon	17	78	0.0	6826	0.0	0.0
Tue	18	78	0.0	6826	0.0	0.0
Wed	19	78	0.0	6826	0.0	0.0
Thu	20	78	0.0	6826	0.0	0.0
Fri	21	78	0.0	6826	0.0	0.0
Sat	22	78	0.0	6826	0.0	0.0
Sun	23	78	0.0	6826	0.0	0.0
Mon	24	78	0.0	6826	0.0	0.0
Tue	25	78	0.0	6826	0.0	0.0
Wed	26	78	0.0	6826	0.0	0.0
Thu	27	78	0.0	6826	0.0	0.0
Fri	28	78	0.0	6826	0.0	0.0
Sat	29	78	0.0	6826	0.0	0.0
Sun	30	78	0.0	6826	0.0	0.0
Mon	31	78	0.0	6826	0.0	0.0
Tue	1	78		6826		
Total			0.0		0.0	0.0
Avg.			0.0		0.0	0.0
Max.			0.0		0.0	0.0
Min.			0.0		0.0	0.0

Operator: _____