



OPERATOR'S REPORT

City of Rollingwood



January 15, 2025



MEMORANDUM

To: Ms. Ashley Wayman, City Administrator, City of Rollingwood
From: Ben Ingallina, Crossroads Utility Services LLC
Subject: Monthly Report
Date: 01/08/25

Previous Directives

- *No directives*

Current Operations Report

- I. **Utility Operations Report**
 - A. **Billing Report/ Water Accountability** – Please see enclosed water operations report
 - B. **Water System Operations and Maintenance** –
 - a. No items to report
 - C. **Wastewater Collection System Operations and Maintenance** – No items to report
 - D. **Lift Station Maintenance** – *See enclosed report*
- II. **Customer Service Issues** – No reported issues
- III. **Emergency Response Items** – No new items
- IV. **Drought Contingency Plan / Watering Restrictions**
 - a. Lake Travis Level –637.65 Current Storage 478,813 acre-feet (43.6% full) -.5% down from last month.
 - b. The City of Austin is currently in Stage 2 watering restrictions – (Started August 15th 2023)

Lakes Travis and Buchanan, reservoir lakes for the area's water supply, are expected to drop below 900,000 acre-feet.

The City of Austin is currently in **Stage 2 Drought Water Use Restrictions**.

Austin's Stage 2 water restrictions

The City of Austin is currently in **Stage 2 Drought Water Use Restrictions**.

- ***Residential***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - Even address - Sunday
 - Odd address - Saturday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - Even address - Thursday
 - Odd address - Wednesday
- ***Commercial / Multi-family***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - Even address - Tuesday
 - Odd address – Friday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - Even address - Tuesday
 - Odd address - Friday
- ***Public Schools***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - All addresses - Monday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - All addresses - Monday
- **Wasting water** is prohibited.

- Washing vehicles at home is permitted with a bucket.
- Charity car washes prohibited.
- Fountains must recirculate water and those with a 4-inch emission or fall of water are prohibited.
- Fountains with a greater than 4-inch emission or fall of water are prohibited
- Restaurants may not serve water unless requested by a customer.
- Patio misters at commercial properties (*including restaurants and bars*) may only operate between 4 p.m. and midnight.
- **Commercial power/pressure washing equipment** must meet efficiency requirements.
- Golf courses using potable water can only irrigate fairways on their watering day; tees and greens can be watered every other day if Austin Water is notified.
- Irrigation of golf course fairways allowed between midnight and 5:00 a.m. or between 7:00 p.m. and midnight on designated outdoor water-use days only
- Irrigation of golf course greens or tees allowed every other day with notice to and approval by Austin Water only



MEMORANDUM

To: Ms. Ashley Wayman, City of Rollingwood
From: Ben Ingallina, Crossroads Utility Services LLC
Subject: Lift Station Report Detail
Date: 01/08/25

Lift Station 1 – Dellana Ln.

- Generator checked last week. Both pumps are in standby. No issues.

Lift Station 2 – Hatley Dr.

- Generator checked last week. Both pumps are in standby. No issues.

Lift Station 3 – Almarion Way

- Generator checked last week. Both pumps are in standby. No issues.

Lift Station 4- Rockway Cv.

- Generator checked last week. Both pumps are in standby. No issues.

Lift Station 5 – Vale Dr.

- Generator checked last week. Both pumps are in standby. No issues.

Lift Station 6 – Pleasant Cv.

- Generator checked last week. Both pumps are in standby. No issues.

Lift Station 7 – Nixon Dr.

- Generator checked last week. Both pumps are in standby. No issues.

Monthly Operational Report For Public Water Systems Purchasing Treated Water From Another System
 Which Uses Surface Water Sources or Groundwater Sources Under The Influence of Surface Water

PUBLIC WATER SYSTEM NAME: **City of Rollingwood**

System I.D. #: 2270016

Month: **December 2024**

Submitted by:

Date:

No. of Connections: **537**

License #:

Grade:

TREATED WATER PURCHASED FROM A WHOLESALE SUPPLIER				
Date	Quantity (mgd)	Date	Quantity (mgd)	Monthly Summary (mgd)
1	0.374	16	0.274	Total
2	0.369	17	0.336	Monthly
3	0.393	18	0.412	Purchase: 8.898
4	0.316	19	0.362	
5	0.376	20	0.237	Average
6	0.211	21	0.238	Daily: 0.287
7	0.213	22	0.238	
8	0.211	23	0.237	Maximum
9	0.314	24	0.239	Daily: 0.412
10	0.340	25	0.237	
11	0.329	26	0.335	Minimum
12	0.259	27	0.236	Daily: 0.211
13	0.259	28	0.236	
14	0.259	29	0.236	
15	0.259	30	0.281	
		31	0.282	

DISTRIBUTION SYSTEM (DISINFECTANT RESIDUAL MONITORING)		
Minimum allowable disinfectant residual:	<u>0.5</u> mg/L	Percentage of the measurements below the limit this month:
Total no. of measurements this month:	<u>33</u>	<input type="text" value="0%"/> (1A)
No. of measurements below the limit:	<u>0</u>	
Percentage of the measurements below the limit last month:		<input type="text" value="0%"/> (1B)

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATION	Yes/No	If YES, Date when Notice was Given to the:	
		TCEQ	Customers*
More than 5.0% of the disinfectant residuals in the distribution system below acceptable levels for two consecutive months? - see (1A) and (1B)	NO		

* A sample copy of the Notice to the customers must accompany this report.

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **December 2024**

LOCATION: **Bee Cave Woods**

I.D. #: **2270016**

		METER #07914810	SIZE 6"	METER #18713312	SIZE 3"	TOTAL FLOW	TOTAL GAL PURCHASED	CHLORINE RESIDUAL
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL	MG	mg/L
Sun	1	136776	291.0	27140	83.0	374.0	0.374	2.3
Mon	2	137067	283.0	27223	86.0	369.0	0.369	2.7
Tue	3	137350	313.0	27309	80.0	393.0	0.393	2.7
Wed	4	137663	236.0	27389	80.0	316.0	0.316	2.7
Thu	5	137899	267.0	27469	109.0	376.0	0.376	2.5
Fri	6	138166	141.0	27578	70.0	211.0	0.211	2.3
Sat	7	138307	142.0	27648	71.0	213.0	0.213	2.5
Sun	8	138449	141.0	27719	70.0	211.0	0.211	2.7
Mon	9	138590	221.0	27789	93.0	314.0	0.314	2.5
Tue	10	138811	258.0	27882	82.0	340.0	0.340	2.6
Wed	11	139069	249.0	27964	80.0	329.0	0.329	2.5
Thu	12	139318	177.0	28044	82.0	259.0	0.259	2.3
Fri	13	139495	177.0	28126	82.0	259.0	0.259	2.2
Sat	14	139672	177.0	28208	82.0	259.0	0.259	2.4
Sun	15	139849	177.0	28290	82.0	259.0	0.259	2.6
Mon	16	140026	191.0	28372	83.0	274.0	0.274	2.4
Tue	17	140217	230.0	28455	106.0	336.0	0.336	2.2
Wed	18	140447	335.0	28561	77.0	412.0	0.412	2.2
Thu	19	140782	272.0	28638	90.0	362.0	0.362	2.6
Fri	20	141054	162.0	28728	75.0	237.0	0.237	2.6
Sat	21	141216	163.0	28803	75.0	238.0	0.238	2.6
Sun	22	141379	162.0	28878	76.0	238.0	0.238	2.2
Mon	23	141541	162.0	28954	75.0	237.0	0.237	2.2
Tue	24	141703	163.0	29029	76.0	239.0	0.239	2.4
Wed	25	141866	162.0	29105	75.0	237.0	0.237	2.5
Thu	26	142028	233.0	29180	102.0	335.0	0.335	2.4
Fri	27	142261	156.0	29282	80.0	236.0	0.236	2.0
Sat	28	142417	156.0	29362	80.0	236.0	0.236	2.4
Sun	29	142573	156.0	29442	80.0	236.0	0.236	2.4
Mon	30	142729	206.0	29522	75.0	281.0	0.281	2.6
Tue	31	142935	206.0	29597	76.0	282.0	0.282	2.6
Wed	1	143141		29673				
Total			6365.0	27140.0	2533.0	8898.0	8.9	
Avg.			205.3		81.7	287.0	0.287	2.4
Max.			335.0		109.0	412.0	0.412	2.7
Min.			141.0		70.0	211.0	0.211	2.0

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **December 2024**

LOCATION: **Hatley MM**

I.D. #: **2270016**

		METER No S/n	SIZE 6"	METER #151074A	SIZE 3"	TOTAL FLOW
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL
Sun	1	92	0.0	7544	0.0	0.0
Mon	2	92	0.0	7544	0.0	0.0
Tue	3	92	0.0	7544	0.0	0.0
Wed	4	92	0.0	7544	0.0	0.0
Thu	5	92	0.0	7544	0.0	0.0
Fri	6	92	0.0	7544	0.0	0.0
Sat	7	92	0.0	7544	0.0	0.0
Sun	8	92	0.0	7544	0.0	0.0
Mon	9	92	0.0	7544	0.0	0.0
Tue	10	92	0.0	7544	0.0	0.0
Wed	11	92	0.0	7544	0.0	0.0
Thu	12	92	0.0	7544	0.0	0.0
Fri	13	92	0.0	7544	0.0	0.0
Sat	14	92	0.0	7544	0.0	0.0
Sun	15	92	0.0	7544	0.0	0.0
Mon	16	92	0.0	7544	0.0	0.0
Tue	17	92	0.0	7544	0.0	0.0
Wed	18	92	0.0	7544	0.0	0.0
Thu	19	92	0.0	7544	0.0	0.0
Fri	20	92	0.0	7544	0.0	0.0
Sat	21	92	0.0	7544	0.0	0.0
Sun	22	92	0.0	7544	0.0	0.0
Mon	23	92	0.0	7544	0.0	0.0
Tue	24	92	0.0	7544	0.0	0.0
Wed	25	92	0.0	7544	0.0	0.0
Thu	26	92	0.0	7544	0.0	0.0
Fri	27	92	0.0	7544	0.0	0.0
Sat	28	92	0.0	7544	0.0	0.0
Sun	29	92	0.0	7544	0.0	0.0
Mon	30	92	0.0	7544	0.0	0.0
Tue	31	92	0.0	7544	0.0	0.0
Wed	1	92		7544		
Total			0.0		0.0	0.0
Avg.			0.0		0.0	0.0
Max.			0.0		0.0	0.0
Min.			0.0		0.0	0.0

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **December 2024**

LOCATION: **Riley MM**

I.D. #: **2270016**

DAY	DATE	METER	SIZE	METER	SIZE	TOTAL
		No S/N	6"	No S/N	3"	FLOW
		A	TH GAL	B	TH GAL	TH GAL
Sun	1	3619	0.0	21519	0.0	0.0
Mon	2	3619	0.0	21519	0.0	0.0
Tue	3	3619	0.0	21519	0.0	0.0
Wed	4	3619	0.0	21519	0.0	0.0
Thu	5	3619	0.0	21519	0.0	0.0
Fri	6	3619	0.0	21519	0.0	0.0
Sat	7	3619	0.0	21519	0.0	0.0
Sun	8	3619	0.0	21519	0.0	0.0
Mon	9	3619	0.0	21519	0.0	0.0
Tue	10	3619	0.0	21519	0.0	0.0
Wed	11	3619	0.0	21519	0.0	0.0
Thu	12	3619	0.0	21519	0.0	0.0
Fri	13	3619	0.0	21519	0.0	0.0
Sat	14	3619	0.0	21519	0.0	0.0
Sun	15	3619	0.0	21519	0.0	0.0
Mon	16	3619	0.0	21519	0.0	0.0
Tue	17	3619	0.0	21519	0.0	0.0
Wed	18	3619	0.0	21519	0.0	0.0
Thu	19	3619	0.0	21519	0.0	0.0
Fri	20	3619	0.0	21519	0.0	0.0
Sat	21	3619	0.0	21519	0.0	0.0
Sun	22	3619	0.0	21519	0.0	0.0
Mon	23	3619	0.0	21519	0.0	0.0
Tue	24	3619	0.0	21519	0.0	0.0
Wed	25	3619	0.0	21519	0.0	0.0
Thu	26	3619	0.0	21519	0.0	0.0
Fri	27	3619	0.0	21519	0.0	0.0
Sat	28	3619	0.0	21519	0.0	0.0
Sun	29	3619	0.0	21519	0.0	0.0
Mon	30	3619	0.0	21519	0.0	0.0
Tue	31	3619	0.0	21519	0.0	0.0
Wed	1	3619		21519		
Total			0.0		0.0	0.0
Avg.			0.0		0.0	0.0
Max.			0.0		0.0	0.0
Min.			0.0		0.0	0.0

Operator: _____