



OPERATOR'S REPORT

City of Rollingwood



August 17, 2022



MEMORANDUM

To: Ms. Ashley Wayman, City Administrator, City of Rollingwood
From: Andrew Hunt, Crossroads Utility Services LLC
Subject: Monthly Report
Date: 8/8/22

Previous Directives

- *No directives*

Current Operations Report

- I. **Utility Operations Report**
 - A. **Billing Report/ Water Accountability** – Please see enclosed water operations report
 - a. Bac-t samples have been pulled for June 2022 – all clean samples
 - B. **Water System Operations and Maintenance** –
 - a. We completed a water line repair at 302 Riley & 2800 Hubbard
 - C. **Wastewater Collection System Operations and Maintenance** -
 - a. We completed lift station wet well cleaning
 - D. **Lift Station Maintenance** – *See enclosed report*
- II. **Customer Service Issues** – No reported issues
- III. **Emergency Response Items** – No new items. We are awaiting the plan for generator installations at the lift stations.
- IV. **Drought Contingency Plan / Watering Restrictions**
 - a. Lake Travis Level – 645.73 – Current Storage 583,927 acre-feet (57% full)
 - b. The City of Austin is currently in Stage 1 watering restrictions – (twice per week watering)

City of Austin Stage 1 Restrictions – effective June 6, 2022

As a result of the combined storage in Lake Travis and Lake Buchanan falling below 1.4 million acre-feet, the City of Austin has implemented Drought Stage One Regulations of its Drought Contingency Plan effective June 6, 2022.

The City of Austin is currently in **Stage 1 Drought Water Use Restrictions**.

- Residential
 - **Hose-end Sprinklers** - two days per week - midnight to 8 a.m. and/or 7 p.m. to midnight
 - **Even address** - Thursday, Sunday
 - **Odd address** - Wednesday, Saturday
 - **Automatic Irrigation** -one day per week - midnight to 8 a.m. and/or 7 p.m. to midnight (*Residential customers may also water a second day with a hose-end sprinkler*)
 - **Even address** - Thursday
 - **Odd address** - Wednesday
 - **Commercial / Multi-family / Public Schools**
 - **Hose-end Sprinklers or Automatic Irrigation** - one day per week - midnight to 8 a.m. and/or 7 p.m. to midnight
 - **Even address** - Tuesday
 - **Odd address** - Friday
- **Wasting water** is prohibited
- Washing vehicles at home is permitted with an auto shut-off hose or bucket
- Charity car washes may only be held at a commercial car wash
- Fountains must recirculate water
- Restaurants may not serve water unless requested by a customer
- Patio misters at commercial properties (*including restaurants and bars*) may only operate between 4 p.m. and midnight
- **Commercial power/pressure washing equipment** must meet efficiency requirements



MEMORANDUM

To: Ms. Ashley Wayman, City of Rollingwood
From: Andrew Hunt, Crossroads Utility Services LLC
Subject: Lift Station Report Detail
Date: 8/8/22

1. Lift Station 1 – Dellana Ln.
 - Troubleshoot issues with Pump #2
 - Cleaned lift station

2. Lift Station 2 – Hatley Dr.
 - Cleaned lift station

3. Lift Station 3 – Almarion Way
 - Troubleshoot issues with Pump #2
 - Cleaned lift station

1. Lift Station 4- Rockway Cv.
 - Cleaned lift station
 - Ran lift station manually with generator after power outages (6/27/22)

2. Lift Station 5 – Vale Dr.
 - Cleaned lift station

3. Lift Station 6 – Pleasant Cv.
 - No issues to report

4. Lift Station 7 – Nixon Dr.
 - Troubleshoot issues with the transducer
 - Cleaned lift station

Monthly Operational Report For Public Water Systems Purchasing Treated Water From Another System
 Which Uses Surface Water Sources or Groundwater Sources Under The Influence of Surface Water

PUBLIC WATER SYSTEM NAME: **City of Rollingwood**

System I.D. #: 2270016

Month: **July 2022**

Submitted by:

Date:

No. of Connections: **537**

License #:

Grade:

TREATED WATER PURCHASED FROM A WHOLESALE SUPPLIER				
Date	Quantity (mgd)	Date	Quantity (mgd)	Monthly Summary (mgd)
1	0.597	16	0.581	Total
2	0.597	17	0.582	Monthly
3	0.597	18	0.658	Purchase: 21.194
4	0.599	19	0.770	
5	0.792	20	0.814	Average
6	0.790	21	0.749	Daily: 0.684
7	0.693	22	0.630	
8	0.670	23	0.632	Maximum
9	0.671	24	0.634	Daily: 0.885
10	0.672	25	0.663	
11	0.633	26	0.770	Minimum
12	0.667	27	0.811	Daily: 0.581
13	0.885	28	0.753	
14	0.643	29	0.689	
15	0.581	30	0.691	
		31	0.692	

DISTRIBUTION SYSTEM (DISINFECTANT RESIDUAL MONITORING)			
Minimum allowable disinfectant residual:	<u>0.5</u> mg/L	Percentage of the measurements below the limit this month:	
Total no. of measurements this month:	<u> </u>	<input type="text" value="0%"/>	(1A)
No. of measurements below the limit:	<u>0</u>		
Percentage of the measurements below the limit last month:		<input type="text" value="0%"/>	(1B)

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATION	Yes/No	If YES, Date when Notice was Given to the:	
		TCEQ	Customers*
More that 5.0% of the disinfectant residuals in the distribution system below acceptable levels for two consecutive months? - see (1A) and (1B)	NO		

* A sample copy of the Notice to the customers must accompany this report.

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **July 2022**

LOCATION: **Bee Cave Woods**

I.D. #: **2270016**

		METER #07914810	SIZE 6"	METER #18713312	SIZE 3"	TOTAL FLOW	TOTAL GAL PURCHASED	CHLORINE RESIDUAL
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL	MG	mg/L
Fri	1	849102	431.0	78346	155.0	586.0	0.597	2.2
Sat	2	849533	431.0	78501	155.0	586.0	0.597	2.4
Sun	3	849964	431.0	78656	155.0	586.0	0.597	2.3
Mon	4	850395	431.0	78811	156.0	587.0	0.599	2.3
Tue	5	850826	628.0	78967	150.0	778.0	0.792	2.1
Wed	6	851454	611.0	79117	164.0	775.0	0.790	2.4
Thu	7	852065	556.0	79281	133.0	689.0	0.693	2.0
Fri	8	852621	498.0	79414	160.0	658.0	0.670	2.2
Sat	9	853119	498.0	79574	160.0	658.0	0.671	2.0
Sun	10	853617	499.0	79734	160.0	659.0	0.672	2.2
Mon	11	854116	460.0	79894	153.0	613.0	0.633	2.5
Tue	12	854576	532.0	80047	114.0	646.0	0.667	2.2
Wed	13	855108	669.0	80161	185.0	854.0	0.885	2.3
Thu	14	855777	442.0	80346	170.0	612.0	0.643	2.2
Fri	15	856219	426.0	80516	147.0	573.0	0.581	1.9
Sat	16	856645	426.0	80663	147.0	573.0	0.581	2.3
Sun	17	857071	426.0	80810	148.0	574.0	0.582	2.4
Mon	18	857497	492.0	80958	150.0	642.0	0.658	2.0
Tue	19	857989	586.0	81108	160.0	746.0	0.770	2.2
Wed	20	858575	636.0	81268	154.0	790.0	0.814	2.1
Thu	21	859211	571.0	81422	154.0	725.0	0.749	2.0
Fri	22	859782	471.0	81576	148.0	619.0	0.630	2.1
Sat	23	860253	471.0	81724	148.0	619.0	0.632	2.8
Sun	24	860724	472.0	81872	149.0	621.0	0.634	2.6
Mon	25	861196	491.0	82021	148.0	639.0	0.663	2.1
Tue	26	861687	605.0	82169	152.0	757.0	0.770	2.2
Wed	27	862292	662.0	82321	147.0	809.0	0.811	2.2
Thu	28	862954	613.0	82468	138.0	751.0	0.753	1.8
Fri	29	863567	523.0	82606	158.0	681.0	0.683	2.3
Sat	30	864090	524.0	82764	159.0	683.0	0.685	2.0
Sun	31	864614	524.0	82923	159.0	683.0	0.692	2.3
Mon	1	865138		83082				
Total			16036.0		4736.0	20772.0	21.2	
Avg.			517.3		152.8	670.1	0.684	2.2
Max.			669.0		185.0	854.0	0.885	2.8
Min.			426.0		114.0	573.0	0.581	1.8

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **July 2022**

LOCATION: **Riley MM**

I.D. #: **2270016**

DAY	DATE	METER	SIZE	METER	SIZE	TOTAL
		No S/N	6"	No S/N	3"	FLOW
		A	TH GAL	B	TH GAL	TH GAL
Fri	1	444	0.0	2266	11.0	11.0
Sat	2	444	0.0	2277	11.0	11.0
Sun	3	444	0.0	2288	11.0	11.0
Mon	4	444	0.0	2299	12.0	12.0
Tue	5	444	0.0	2311	14.0	14.0
Wed	6	444	0.0	2325	15.0	15.0
Thu	7	444	0.0	2340	4.0	4.0
Fri	8	444	0.0	2344	12.0	12.0
Sat	9	444	0.0	2356	13.0	13.0
Sun	10	444	0.0	2369	13.0	13.0
Mon	11	444	0.0	2382	20.0	20.0
Tue	12	444	0.0	2402	21.0	21.0
Wed	13	444	0.0	2423	31.0	31.0
Thu	14	444	0.0	2454	31.0	31.0
Fri	15	444	0.0	2485	8.0	8.0
Sat	16	444	0.0	2493	8.0	8.0
Sun	17	444	0.0	2501	8.0	8.0
Mon	18	444	0.0	2509	16.0	16.0
Tue	19	444	0.0	2525	24.0	24.0
Wed	20	444	0.0	2549	24.0	24.0
Thu	21	444	0.0	2573	24.0	24.0
Fri	22	444	0.0	2597	11.0	11.0
Sat	23	444	1.0	2608	12.0	13.0
Sun	24	445	1.0	2620	12.0	13.0
Mon	25	446	0.0	2632	24.0	24.0
Tue	26	446	0.0	2656	13.0	13.0
Wed	27	446	0.0	2669	2.0	2.0
Thu	28	446	0.0	2671	2.0	2.0
Fri	29	446	0.0	2673	8.0	8.0
Sat	30	446	0.0	2681	8.0	8.0
Sun	31	446	0.0	2689	9.0	9.0
Mon	1	446		2698		
Total			2.0		432.0	434.0
Avg.			0.1		13.9	14.0
Max.			1.0		31.0	31.0
Min.			0.0		2.0	2.0

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **July 2022**

LOCATION: **Hatley MM**

I.D. #: **2270016**

DAY	DATE	METER	SIZE	METER	SIZE	TOTAL
		No S/n	6"	#151074A	3"	FLOW
		A	TH GAL	B	TH GAL	TH GAL
Fri	1	78	0.0	6824	0.0	0.0
Sat	2	78	0.0	6824	0.0	0.0
Sun	3	78	0.0	6824	0.0	0.0
Mon	4	78	0.0	6824	0.0	0.0
Tue	5	78	0.0	6824	0.0	0.0
Wed	6	78	0.0	6824	0.0	0.0
Thu	7	78	0.0	6824	0.0	0.0
Fri	8	78	0.0	6824	0.0	0.0
Sat	9	78	0.0	6824	0.0	0.0
Sun	10	78	0.0	6824	0.0	0.0
Mon	11	78	0.0	6824	0.0	0.0
Tue	12	78	0.0	6824	0.0	0.0
Wed	13	78	0.0	6824	0.0	0.0
Thu	14	78	0.0	6824	0.0	0.0
Fri	15	78	0.0	6824	0.0	0.0
Sat	16	78	0.0	6824	0.0	0.0
Sun	17	78	0.0	6824	0.0	0.0
Mon	18	78	0.0	6824	0.0	0.0
Tue	19	78	0.0	6824	0.0	0.0
Wed	20	78	0.0	6824	0.0	0.0
Thu	21	78	0.0	6824	0.0	0.0
Fri	22	78	0.0	6824	0.0	0.0
Sat	23	78	0.0	6824	0.0	0.0
Sun	24	78	0.0	6824	0.0	0.0
Mon	25	78	0.0	6824	0.0	0.0
Tue	26	78	0.0	6824	0.0	0.0
Wed	27	78	0.0	6824	0.0	0.0
Thu	28	78	0.0	6824	0.0	0.0
Fri	29	78	0.0	6824	0.0	0.0
Sat	30	78	0.0	6824	0.0	0.0
Sun	31	78	0.0	6824	0.0	0.0
Mon	1	78		6824		
Total			0.0		0.0	0.0
Avg.			0.0		0.0	0.0
Max.			0.0		0.0	0.0
Min.			0.0		0.0	0.0

Operator: _____