



OPERATOR'S REPORT

City of Rollingwood



June 12, 2024



MEMORANDUM

To: Ms. Ashley Wayman, City Administrator, City of Rollingwood
From: Ben Ingallina, Crossroads Utility Services LLC
Subject: Monthly Report
Date: 06/06/24

Previous Directives

- *No directives*

Current Operations Report

- I. **Utility Operations Report**
 - A. **Billing Report/ Water Accountability** – Please see enclosed water operations report
 - B. **Water System Operations and Maintenance** –
 - a. No items to report
 - C. **Wastewater Collection System Operations and Maintenance** – No items to report
 - D. **Lift Station Maintenance** – *See enclosed report*
- II. **Customer Service Issues** – No reported issues
- III. **Emergency Response Items** – No new items. We are awaiting the plan for generator installations at the lift stations.
- IV. **Drought Contingency Plan / Watering Restrictions**
 - a. Lake Travis Level – 634.86– Current Storage 467,757 acre-feet (41.0% full) +2.5% up from last month.
 - b. The City of Austin is currently in Stage 2 watering restrictions – (Started August 15th 2023)

Lakes Travis and Buchanan, reservoir lakes for the area's water supply, are expected to drop below 900,000 acre-feet.

The City of Austin is currently in **Stage 2 Drought Water Use Restrictions**.

Austin's Stage 2 water restrictions

The City of Austin is currently in **Stage 2 Drought Water Use Restrictions**.

- ***Residential***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - Even address - Sunday
 - Odd address - Saturday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - Even address - Thursday
 - Odd address - Wednesday
- ***Commercial / Multi-family***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - Even address - Tuesday
 - Odd address – Friday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - Even address - Tuesday
 - Odd address - Friday
- ***Public Schools***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - All addresses - Monday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - All addresses - Monday

- **Wasting water** is prohibited.
- Washing vehicles at home is permitted with a bucket.
- Charity car washes prohibited.
- Fountains must recirculate water and those with a 4-inch emission or fall of water are prohibited.
- Fountains with a greater than 4-inch emission or fall of water are prohibited
- Restaurants may not serve water unless requested by a customer.
- Patio misters at commercial properties (*including restaurants and bars*) may only operate between 4 p.m. and midnight.
- **Commercial power/pressure washing equipment** must meet efficiency requirements.
- Golf courses using potable water can only irrigate fairways on their watering day; tees and greens can be watered every other day if Austin Water is notified.
- Irrigation of golf course fairways allowed between midnight and 5:00 a.m. or between 7:00 p.m. and midnight on designated outdoor water-use days only
- Irrigation of golf course greens or tees allowed every other day with notice to and approval by Austin Water only



MEMORANDUM

To: Ms. Ashley Wayman, City of Rollingwood
From: Ben Ingallina, Crossroads Utility Services LLC
Subject: Lift Station Report Detail
Date: 06/07/24

Lift Station 1 – Dellana Ln.

- No issues.

Lift Station 2 – Hatley Dr.

- Auto Dialer phone line was damaged on AT&T side. Repairs have been completed and the dialer is working normally.

Lift Station 3 – Almarion Way

- No issues.

Lift Station 4- Rockway Cv.

- No issues.

Lift Station 5 – Vale Dr.

- No issues.

Lift Station 6 – Pleasant Cv.

- No issues.

Lift Station 7 – Nixon Dr.

- No issues.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
 Water Utilities Division

Monthly Operational Report For Public Water Systems Purchasing Treated Water From Another System
 Which Uses Surface Water Sources or Groundwater Sources Under The Influence of Surface Water

PUBLIC WATER SYSTEM NAME: **City of Rollingwood**

System I.D. #: 2270016

Month: **May 2024**

Submitted by:

Date:

No. of Connections: **537**

License #:

Grade:

TREATED WATER PURCHASED FROM A WHOLESALE SUPPLIER				
Date	Quantity (mgd)	Date	Quantity (mgd)	Monthly Summary (mgd)
1	0.268	16	0.349	Total
2	0.299	17	0.304	
3	0.227	18	0.303	Monthly Purchase: 11.179
4	0.227	19	0.303	
5	0.227	20	0.391	Average Daily: 0.361
6	0.360	21	0.519	
7	0.373	22	0.518	Maximum Daily: 0.519
8	0.419	23	0.487	
9	0.409	24	0.381	Minimum Daily: 0.227
10	0.319	25	0.382	
11	0.320	26	0.381	
12	0.319	27	0.381	
13	0.375	28	0.424	
14	0.388	29	0.427	
15	0.388	30	0.394	
		31	0.317	

DISTRIBUTION SYSTEM (DISINFECTANT RESIDUAL MONITORING)			
Minimum allowable disinfectant residual:	<u>0.5</u> mg/L	Percentage of the measurements below the limit this month:	
Total no. of measurements this month:	<u>33</u>	<input type="text" value="0%"/>	(1A)
No. of measurements below the limit:	<u>0</u>		
Percentage of the measurements below the limit last month:		<input type="text" value="0%"/>	(1B)

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATION	Yes/No	If YES, Date when Notice was Given to the:	
		TCEQ	Customers*
More than 5.0% of the disinfectant residuals in the distribution system below acceptable levels for two consecutive months? - see (1A) and (1B)	NO		

* A sample copy of the Notice to the customers must accompany this report.

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **May 2024**

LOCATION: **Bee Cave Woods**

I.D. #: **2270016**

		METER #07914810	SIZE 6"	METER #18713312	SIZE 3"	TOTAL FLOW	TOTAL GAL PURCHASED	CHLORINE RESIDUAL
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL	MG	mg/L
Wed	1	37705	211.0	13882	56.0	267.0	0.268	2.0
Thu	2	37916	244.0	13938	55.0	299.0	0.299	2.2
Fri	3	38160	170.0	13993	57.0	227.0	0.227	2.1
Sat	4	38330	169.0	14050	58.0	227.0	0.227	2.2
Sun	5	38499	170.0	14108	57.0	227.0	0.227	2.4
Mon	6	38669	301.0	14165	61.0	362.0	0.360	2.0
Tue	7	38970	317.0	14226	56.0	373.0	0.373	2.2
Wed	8	39287	359.0	14282	60.0	419.0	0.419	2.3
Thu	9	39646	351.0	14342	58.0	409.0	0.409	2.2
Fri	10	39997	262.0	14400	57.0	319.0	0.319	2.2
Sat	11	40259	262.0	14457	58.0	320.0	0.320	2.4
Sun	12	40521	262.0	14515	57.0	319.0	0.319	2.1
Mon	13	40783	307.0	14572	68.0	375.0	0.375	2.2
Tue	14	41090	332.0	14640	56.0	388.0	0.388	1.7
Wed	15	41422	332.0	14696	56.0	388.0	0.388	2.4
Thu	16	41754	290.0	14752	59.0	349.0	0.349	2.2
Fri	17	42044	249.0	14811	55.0	304.0	0.304	2.1
Sat	18	42293	248.0	14866	55.0	303.0	0.303	2.4
Sun	19	42541	248.0	14921	55.0	303.0	0.303	2.3
Mon	20	42789	335.0	14976	56.0	391.0	0.391	2.4
Tue	21	43124	453.0	15032	66.0	519.0	0.519	2.4
Wed	22	43577	452.0	15098	66.0	518.0	0.518	2.2
Thu	23	44029	429.0	15164	58.0	487.0	0.487	2.3
Fri	24	44458	327.0	15222	54.0	381.0	0.381	2.2
Sat	25	44785	328.0	15276	54.0	382.0	0.382	2.3
Sun	26	45113	327.0	15330	54.0	381.0	0.381	2.1
Mon	27	45440	327.0	15384	54.0	381.0	0.381	2.6
Tue	28	45767	366.0	15438	58.0	424.0	0.424	2.3
Wed	29	46133	369.0	15496	58.0	427.0	0.427	2.4
Thu	30	46502	340.0	15554	54.0	394.0	0.394	2.4
Fri	31	46842	267.0	15608	50.0	317.0	0.317	2.4
Sat	1	47109		15658				
Total			9404.0		1776.0	11180.0	11.2	
Avg.			303.4		57.3	360.6	0.361	2.2
Max.			453.0		68.0	519.0	0.519	2.6
Min.			169.0		50.0	227.0	0.227	1.7

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **May 2024**

LOCATION: **Riley MM**

I.D. #: **2270016**

DAY	DATE	METER SIZE		METER SIZE		TOTAL FLOW
		No S/N	6"	No S/N	3"	
		A	TH GAL	B	TH GAL	TH GAL
Wed	1	3586	1.0	21516	0.0	1.0
Thu	2	3587	0.0	21516	0.0	0.0
Fri	3	3587	0.0	21516	0.0	0.0
Sat	4	3587	0.0	21516	0.0	0.0
Sun	5	3587	0.0	21516	0.0	0.0
Mon	6	3587	0.0	21516	0.0	0.0
Tue	7	3587	0.0	21516	0.0	0.0
Wed	8	3587	0.0	21516	0.0	0.0
Thu	9	3587	0.0	21516	0.0	0.0
Fri	10	3587	0.0	21516	0.0	0.0
Sat	11	3587	0.0	21516	0.0	0.0
Sun	12	3587	0.0	21516	0.0	0.0
Mon	13	3587	0.0	21516	0.0	0.0
Tue	14	3587	0.0	21516	0.0	0.0
Wed	15	3587	0.0	21516	0.0	0.0
Thu	16	3587	0.0	21516	0.0	0.0
Fri	17	3587	0.0	21516	0.0	0.0
Sat	18	3587	0.0	21516	0.0	0.0
Sun	19	3587	0.0	21516	0.0	0.0
Mon	20	3587	0.0	21516	0.0	0.0
Tue	21	3587	0.0	21516	0.0	0.0
Wed	22	3587	0.0	21516	0.0	0.0
Thu	23	3587	0.0	21516	0.0	0.0
Fri	24	3587	0.0	21516	0.0	0.0
Sat	25	3587	0.0	21516	0.0	0.0
Sun	26	3587	0.0	21516	0.0	0.0
Mon	27	3587	0.0	21516	0.0	0.0
Tue	28	3587	0.0	21516	0.0	0.0
Wed	29	3587	0.0	21516	0.0	0.0
Thu	30	3587	0.0	21516	0.0	0.0
Fri	31	3587	0.0	21516	0.0	0.0
Sat	1	3587		21516		
Total			1.0		0.0	1.0
Avg.			0.0		0.0	0.0
Max.			1.0		0.0	1.0
Min.			0.0		0.0	0.0

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **May 2024**

LOCATION: **Hatley MM**

I.D. #: **2270016**

DAY	DATE	METER	SIZE	METER	SIZE	TOTAL
		No S/n	6"	#151074A	3"	FLOW
		A	TH GAL	B	TH GAL	TH GAL
Wed	1	92	0.0	7516	0.0	0.0
Thu	2	92	0.0	7516	0.0	0.0
Fri	3	92	0.0	7516	0.0	0.0
Sat	4	92	0.0	7516	0.0	0.0
Sun	5	92	0.0	7516	0.0	0.0
Mon	6	92	2.0	7516	0.0	2.0
Tue	7	94	0.0	7516	0.0	0.0
Wed	8	94	0.0	7516	0.0	0.0
Thu	9	94	0.0	7516	0.0	0.0
Fri	10	94	0.0	7516	0.0	0.0
Sat	11	94	0.0	7516	0.0	0.0
Sun	12	94	0.0	7516	0.0	0.0
Mon	13	94	0.0	7516	0.0	0.0
Tue	14	94	0.0	7516	0.0	0.0
Wed	15	94	0.0	7516	0.0	0.0
Thu	16	94	0.0	7516	0.0	0.0
Fri	17	94	0.0	7516	0.0	0.0
Sat	18	94	0.0	7516	0.0	0.0
Sun	19	94	0.0	7516	0.0	0.0
Mon	20	94	0.0	7516	0.0	0.0
Tue	21	94	0.0	7516	0.0	0.0
Wed	22	94	0.0	7516	0.0	0.0
Thu	23	94	0.0	7516	0.0	0.0
Fri	24	94	0.0	7516	0.0	0.0
Sat	25	94	0.0	7516	0.0	0.0
Sun	26	94	0.0	7516	0.0	0.0
Mon	27	94	0.0	7516	0.0	0.0
Tue	28	94	0.0	7516	0.0	0.0
Wed	29	94	0.0	7516	0.0	0.0
Thu	30	94	0.0	7516	0.0	0.0
Fri	31	94	0.0	7516	0.0	0.0
Sat	1	94		7516		
Total			2.0		0.0	2.0
Avg.			0.1		0.0	0.1
Max.			2.0		0.0	2.0
Min.			0.0		0.0	0.0

Operator: _____