



OPERATOR'S REPORT

City of Rollingwood



December 20, 2023



MEMORANDUM

To: Ms. Ashley Wayman, City Administrator, City of Rollingwood
From: Ben Ingallina, Crossroads Utility Services LLC
Subject: Monthly Report
Date: 12/06/23

Previous Directives

- *No directives*

Current Operations Report

- I. **Utility Operations Report**
 - A. **Billing Report/ Water Accountability** – Please see enclosed water operations report
 - B. **Water System Operations and Maintenance** –
 - a. No items to report
 - C. **Wastewater Collection System Operations and Maintenance** – No items to report
 - D. **Lift Station Maintenance** – *See enclosed report*
- II. **Customer Service Issues** – No reported issues
- III. **Emergency Response Items** – No new items. We are awaiting the plan for generator installations at the lift stations.
- IV. **Drought Contingency Plan / Watering Restrictions**
 - a. Lake Travis Level – 631.49– Current Storage 435,328 acre-feet (38.1% full) -0.7% down from last month.
 - b. The City of Austin is currently in Stage 2 watering restrictions – (Started August 15th)

Lakes Travis and Buchanan, reservoir lakes for the area's water supply, are expected to drop below 900,000 acre-feet.

The City of Austin is currently in **Stage 2 Drought Water Use Restrictions**.

Austin's Stage 2 water restrictions

The City of Austin is currently in **Stage 2 Drought Water Use Restrictions**.

- ***Residential***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - Even address - Sunday
 - Odd address - Saturday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - Even address - Thursday
 - Odd address - Wednesday
- ***Commercial / Multi-family***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - Even address - Tuesday
 - Odd address – Friday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - Even address - Tuesday
 - Odd address - Friday
- ***Public Schools***
 - Hose-end Sprinklers - one day per week - midnight to 10 a.m. and/or 7 p.m. to midnight
 - All addresses - Monday
 - Automatic Irrigation - one day per week - midnight to 5 a.m. and/or 7 p.m. to midnight
 - All addresses - Monday

- **Wasting water** is prohibited.
- Washing vehicles at home is permitted with a bucket.
- Charity car washes prohibited.
- Fountains must recirculate water and those with a 4-inch emission or fall of water are prohibited.
- Fountains with a greater than 4-inch emission or fall of water are prohibited
- Restaurants may not serve water unless requested by a customer.
- Patio misters at commercial properties (*including restaurants and bars*) may only operate between 4 p.m. and midnight.
- **Commercial power/pressure washing equipment** must meet efficiency requirements.
- Golf courses using potable water can only irrigate fairways on their watering day; tees and greens can be watered every other day if Austin Water is notified.
- Irrigation of golf course fairways allowed between midnight and 5:00 a.m. or between 7:00 p.m. and midnight on designated outdoor water-use days only
- Irrigation of golf course greens or tees allowed every other day with notice to and approval by Austin Water only



MEMORANDUM

To: Ms. Ashley Wayman, City of Rollingwood
From: Ben Ingallina, Crossroads Utility Services LLC
Subject: Lift Station Report Detail
Date: 12/06/23

Lift Station 1 – Dellana Ln.

- No issues.

Lift Station 2 – Hatley Dr.

- No issues.

Lift Station 3 – Almarion Way

- No issues.

Lift Station 4- Rockway Cv.

- No issues.

Lift Station 5 – Vale Dr.

- No issues.

Lift Station 6 – Pleasant Cv.

- No issues.

Lift Station 7 – Nixon Dr.

- No issues.

Monthly Operational Report For Public Water Systems Purchasing Treated Water From Another System
Which Uses Surface Water Sources or Groundwater Sources Under The Influence of Surface Water

PUBLIC WATER SYSTEM NAME: **City of Rollingwood**

System I.D. #: 2270016

Month: **November 2023**

Submitted by:

Date:

No. of Connections: **537**

License #:

Grade:

TREATED WATER PURCHASED FROM A WHOLESALE SUPPLIER				
Date	Quantity (mgd)	Date	Quantity (mgd)	Monthly Summary (mgd)
1	0.215	16	0.370	Total Monthly Purchase: 10.179
2	0.041	17	0.282	
3	0.544	18	0.283	Average Daily: 0.339
4	0.543	19	0.284	
5	0.543	20	0.323	Maximum Daily: 0.544
6	0.544	21	0.337	
7	0.420	22	0.313	Minimum Daily: 0.041
8	0.363	23	0.315	
9	0.332	24	0.313	
10	0.256	25	0.314	
11	0.256	26	0.315	
12	0.256	27	0.342	
13	0.301	28	0.405	
14	0.357	29	0.327	
15	0.353	30	0.350	

DISTRIBUTION SYSTEM (DISINFECTANT RESIDUAL MONITORING)			
Minimum allowable disinfectant residual:	<u>0.5</u> mg/L	Percentage of the measurements below the limit this month:	
Total no. of measurements this month:	<u>33</u>	<input type="text" value="0%"/>	(1A)
No. of measurements below the limit:	<u>0</u>		
Percentage of the measurements below the limit last month:		<input type="text" value="0%"/>	(1B)

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATION	Yes/No	If YES, Date when Notice was Given to the:	
		TCEQ	Customers*
More than 5.0% of the disinfectant residuals in the distribution system below acceptable levels for two consecutive months? - see (1A) and (1B)	NO		

* A sample copy of the Notice to the customers must accompany this report.

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **November 2023**

LOCATION: **Bee Cave Woods**

I.D. #: **2270016**

		METER #07914810	SIZE 6"	METER #18713312	SIZE 3"	TOTAL FLOW	TOTAL GAL PURCHASED	CHLORINE RESIDUAL
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL	MG	mg/L
Wed	1	974587	190.0	3185	11.0	201.0	0.215	2.6
Thu	2	974777	0.0	3196	0.0	0.0	0.041	2.5
Fri	3	974777	373.0	3196	140.0	513.0	0.544	2.8
Sat	4	373	373.0	140	139.0	512.0	0.543	2.0
Sun	5	746	373.0	279	139.0	512.0	0.543	2.4
Mon	6	1119	373.0	418	139.0	512.0	0.544	2.4
Tue	7	1492	286.0	557	94.0	380.0	0.420	2.5
Wed	8	1778	233.0	651	90.0	323.0	0.363	2.6
Thu	9	2011	207.0	741	93.0	300.0	0.332	2.6
Fri	10	2218	134.0	834	92.0	226.0	0.256	2.6
Sat	11	2352	134.0	926	92.0	226.0	0.256	2.4
Sun	12	2486	134.0	1018	92.0	226.0	0.256	1.6
Mon	13	2620	184.0	1110	86.0	270.0	0.301	2.2
Tue	14	2804	228.0	1196	92.0	320.0	0.357	2.1
Wed	15	3032	219.0	1288	96.0	315.0	0.353	2.6
Thu	16	3251	244.0	1384	90.0	334.0	0.370	2.3
Fri	17	3495	156.0	1474	91.0	247.0	0.282	2.1
Sat	18	3651	157.0	1565	91.0	248.0	0.283	1.8
Sun	19	3808	157.0	1656	91.0	248.0	0.284	2.7
Mon	20	3965	203.0	1747	91.0	294.0	0.323	2.4
Tue	21	4168	207.0	1838	90.0	297.0	0.337	2.5
Wed	22	4375	188.0	1928	91.0	279.0	0.313	2.0
Thu	23	4563	188.0	2019	92.0	280.0	0.315	2.1
Fri	24	4751	187.0	2111	91.0	278.0	0.313	2.3
Sat	25	4938	188.0	2202	91.0	279.0	0.314	1.9
Sun	26	5126	188.0	2293	92.0	280.0	0.315	1.1
Mon	27	5314	220.0	2385	89.0	309.0	0.342	2.4
Tue	28	5534	263.0	2474	100.0	363.0	0.396	2.5
Wed	29	5797	204.0	2574	85.0	289.0	0.322	2.4
Thu	30	6001	219.0	2659	94.0	313.0	0.346	2.2
Fri	1	6220		2753				
Total			6410.0		2764.0	9174.0	10.2	
Avg.			213.7		92.1	305.8	0.339	2.3
Max.			373.0		140.0	513.0	0.544	2.8
Min.			0.0		0.0	0.0	0.041	1.1

* Meter changed out City of Austin

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **November 2023**

LOCATION: **Riley MM**

I.D. #: **2270016**

DAY	DATE	METER	SIZE	METER	SIZE	TOTAL
		No S/N	6"	No S/N	3"	FLOW
		A	TH GAL	B	TH GAL	TH GAL
Wed	1	3540	0.0	17389	47.0	47.0
Thu	2	3540	0.0	17436	41.0	41.0
Fri	3	3540	0.0	17477	31.0	31.0
Sat	4	3540	0.0	17508	31.0	31.0
Sun	5	3540	0.0	17539	31.0	31.0
Mon	6	3540	0.0	17570	32.0	32.0
Tue	7	3540	0.0	17602	40.0	40.0
Wed	8	3540	0.0	17642	40.0	40.0
Thu	9	3540	0.0	17682	33.0	33.0
Fri	10	3540	0.0	17715	30.0	30.0
Sat	11	3540	0.0	17745	30.0	30.0
Sun	12	3540	0.0	17775	30.0	30.0
Mon	13	3540	0.0	17805	31.0	31.0
Tue	14	3540	0.0	17836	37.0	37.0
Wed	15	3540	0.0	17873	38.0	38.0
Thu	16	3540	0.0	17911	36.0	36.0
Fri	17	3540	0.0	17947	35.0	35.0
Sat	18	3540	0.0	17982	35.0	35.0
Sun	19	3540	0.0	18017	36.0	36.0
Mon	20	3540	0.0	18053	29.0	29.0
Tue	21	3540	1.0	18082	39.0	40.0
Wed	22	3541	0.0	18121	34.0	34.0
Thu	23	3541	0.0	18155	35.0	35.0
Fri	24	3541	0.0	18190	35.0	35.0
Sat	25	3541	0.0	18225	35.0	35.0
Sun	26	3541	0.0	18260	35.0	35.0
Mon	27	3541	0.0	18295	33.0	33.0
Tue	28	3541	0.0	18328	42.0	42.0
Wed	29	3541	0.0	18370	38.0	38.0
Thu	30	3541	0.0	18408	37.0	37.0
Fri	1	3541		18445		
Total			1.0		1056.0	1057.0
Avg.			0.0		35.2	35.2
Max.			1.0		47.0	47.0
Min.			0.0		29.0	29.0

Operator: _____

MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **November 2023**

LOCATION: **Hatley MM**

I.D. #: **2270016**

DAY	DATE	METER	SIZE	METER	SIZE	TOTAL
		No S/n	6"	#151074A	3"	FLOW
		A	TH GAL	B	TH GAL	TH GAL
Wed	1	83	0.0	7430	33.0	33.0
Thu	2	83	0.0	7463	0.0	0.0
Fri	3	83	0.0	7463	0.0	0.0
Sat	4	83	0.0	7463	0.0	0.0
Sun	5	83	0.0	7463	0.0	0.0
Mon	6	83	0.0	7463	0.0	0.0
Tue	7	83	0.0	7463	0.0	0.0
Wed	8	83	0.0	7463	0.0	0.0
Thu	9	83	0.0	7463	1.0	1.0
Fri	10	83	0.0	7464	0.0	0.0
Sat	11	83	0.0	7464	0.0	0.0
Sun	12	83	0.0	7464	0.0	0.0
Mon	13	83	0.0	7464	0.0	0.0
Tue	14	83	0.0	7464	0.0	0.0
Wed	15	83	0.0	7464	0.0	0.0
Thu	16	83	0.0	7464	0.0	0.0
Fri	17	83	0.0	7464	0.0	0.0
Sat	18	83	0.0	7464	0.0	0.0
Sun	19	83	0.0	7464	0.0	0.0
Mon	20	83	0.0	7464	0.0	0.0
Tue	21	83	0.0	7464	0.0	0.0
Wed	22	83	0.0	7464	0.0	0.0
Thu	23	83	0.0	7464	0.0	0.0
Fri	24	83	0.0	7464	0.0	0.0
Sat	25	83	0.0	7464	0.0	0.0
Sun	26	83	0.0	7464	0.0	0.0
Mon	27	83	0.0	7464	0.0	0.0
Tue	28	83	0.0	7464	0.0	0.0
Wed	29	83	0.0	7464	0.0	0.0
Thu	30	83	0.0	7464	0.0	0.0
Fri	1	83		7464		
Total			0.0		34.0	34.0
Avg.			0.0		1.1	1.1
Max.			0.0		33.0	33.0
Min.			0.0		0.0	0.0

Operator: _____