

# FMS

# FLUID METER SERVICE, CORP.

SALES • REPAIR • TESTING • CALIBRATION  
METERS • CONTROL VALVES • BACKFLOW PREVENTERS

**FMS** (800) 944-4472  
(512) 258-3594 Tel.  
(512) 258-4386 Fax

**Gary Faber - C.E.O.**  
512-426-4035 Mobile  
Email fluidmeter1@aol.com

P.O. Box 340215  
Austin, TX 78734-0215

7304 McNeil Dr., #604  
Austin, TX 78729

TO: City of Rollingwood

DATE: 7-29-20

SIZE: 5/8" x 3/4" MAKE: Badger TYPE: C-700

302 Pleasant Dr.  
METER LOCATION

METER# 44572414  
Read:  
BEFORE: 1368500

P.O.# \_\_\_\_\_ W.O.# \_\_\_\_\_ FMS ORDER # \_\_\_\_\_

QUANTITY	DESCRIPTION	PRICE
1	AWWA Standard Shop test	
note: meter meets AWWA standards <u>Yes</u> — NO		

### CERTIFICATE OF CALIBRATION

This is to certify that the physical standards described below were on this day compared to the standards of the state of Texas which are directly traceable to standards of the National Bureau of Standards [NBS Test-No.'s 39569,40093,179355,225713] A.W.W.A Test.

### DETAILS OF TEST

LINE NO.	<del>CUFF</del> GALS.	RATE OF FLOW G.P.M.	TOTAL <del>CUFF</del> GALS.	% OF ACCURACY	CORRECTED % OF ACCURACY
1	10	1/4	9.85	98.5 %	
2	10	2	10.1	101.0 %	
3	100	15	98.5	98.5 %	

SIGNATURE: \_\_\_\_\_

