



## OPERATOR'S REPORT

City of Rollingwood



October 19, 2022



## MEMORANDUM

To: Ms. Ashley Wayman, City Administrator, City of Rollingwood  
From: Andrew Hunt, Crossroads Utility Services LLC  
Subject: Monthly Report  
Date: 10/11/22

### Previous Directives

- *No directives*

### Current Operations Report

- I. **Utility Operations Report**
  - A. **Billing Report/ Water Accountability** – Please see enclosed water operations report
    - a. Bac-t samples have been pulled for August 2022 – all clean samples
  - B. **Water System Operations and Maintenance** –
    - a. 503 Riley – A contractor hit a 6 inch service line.
  - C. **Wastewater Collection System Operations and Maintenance** -
    - a. Grinder issue at 8 Inwood Circle
  - D. **Lift Station Maintenance** – *See enclosed report*
- II. **Customer Service Issues** – No reported issues
- III. **Emergency Response Items** – No new items. We are awaiting the plan for generator installations at the lift stations.
- IV. **Lead and Copper sampling** – We have completed lead and copper sampling. I have included the results within this report. The maximum contaminant level for lead is 0.015 Mg/L. And the maximum contaminant level for copper is 1.3 mg/L. The city's results are well below these federal limits.
- V. **Drought Contingency Plan / Watering Restrictions**
  - a. Lake Travis Level – 641.61 – Current Storage 537,712 acre-feet (48% full)
  - b. The City of Austin is currently in Stage 1 watering restrictions – (twice per week watering)

## City of Austin Stage 1 Restrictions – effective June 6, 2022

As a result of the combined storage in Lake Travis and Lake Buchanan falling below 1.4 million acre-feet, the City of Austin has implemented Drought Stage One Regulations of its Drought Contingency Plan effective June 6, 2022.

The City of Austin is currently in **Stage 1 Drought Water Use Restrictions**.

- Residential
  - **Hose-end Sprinklers** - two days per week - midnight to 8 a.m. and/or 7 p.m. to midnight
    - **Even address** - Thursday, Sunday
    - **Odd address** - Wednesday, Saturday
  - **Automatic Irrigation** - one day per week - midnight to 8 a.m. and/or 7 p.m. to midnight (*Residential customers may also water a second day with a hose-end sprinkler*)
    - **Even address** - Thursday
    - **Odd address** - Wednesday
  - **Commercial / Multi-family / Public Schools**
    - **Hose-end Sprinklers or Automatic Irrigation** - one day per week - midnight to 8 a.m. and/or 7 p.m. to midnight
      - **Even address** - Tuesday
      - **Odd address** - Friday
- **Wasting water** is prohibited
- Washing vehicles at home is permitted with an auto shut-off hose or bucket
- Charity car washes may only be held at a commercial car wash
- Fountains must recirculate water
- Restaurants may not serve water unless requested by a customer
- Patio misters at commercial properties (*including restaurants and bars*) may only operate between 4 p.m. and midnight
- **Commercial power/pressure washing equipment** must meet efficiency requirements



## MEMORANDUM

To: Ms. Ashley Wayman, City of Rollingwood  
From: Andrew Hunt, Crossroads Utility Services LLC  
Subject: Lift Station Report Detail  
Date: 10/11/22

1. Lift Station 1 – Dellana Ln.
  - No issues to report
1. Lift Station 2 – Hatley Dr.
  - Trouble shot an issue related to pumps not switching to secondary mode. New SitePro panel will not automatically switch from primary to secondary controls.
1. Lift Station 3 – Almarion Way
  - No issues to report
1. Lift Station 4- Rockway Cv.
  - Troubleshoot issues with the backup auto dialer
2. Lift Station 5 – Vale Dr.
  - No issues to report
3. Lift Station 6 – Pleasant Cv.
  - No issues to report
4. Lift Station 7 – Nixon Dr.
  - No issues to report

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY  
Water Utilities Division

Monthly Operational Report For Public Water Systems Purchasing Treated Water From Another System  
Which Uses Surface Water Sources or Groundwater Sources Under The Influence of Surface Water

PUBLIC WATER SYSTEM NAME: **City of Rollingwood**

System I.D. #: 2270016

Month: **September 2022**

Submitted by:

Date:

No. of Connections: **537**

License #:

Grade:

TREATED WATER PURCHASED FROM A WHOLESALE SUPPLIER				
Date	Quantity (mgd)	Date	Quantity (mgd)	Monthly Summary (mgd)
1	0.605	16	0.501	Total
2	0.409	17	0.502	Monthly
3	0.410	18	0.502	Purchase: 16.423
4	0.411	19	0.619	
5	0.412	20	0.643	Average
6	0.569	21	0.719	Daily: 0.547
7	0.447	22	0.714	
8	0.472	23	0.537	Maximum
9	0.434	24	0.540	Daily: 0.719
10	0.435	25	0.540	
11	0.437	26	0.573	Minimum
12	0.533	27	0.684	Daily: 0.409
13	0.571	28	0.706	
14	0.634	29	0.677	
15	0.623	30	0.541	

DISTRIBUTION SYSTEM			
(DISINFECTANT RESIDUAL MONITORING)			
Minimum allowable disinfectant residual:	0.5	mg/L	Percentage of the measurements below the limit this month:
Total no. of measurements this month:			0% (1A)
No. of measurements below the limit:	0		
Percentage of the measurements below the limit last month:			0% (1B)

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATION	Yes/No	If YES, Date when Notice was Given to the:	
		TCEQ	Customers*
More than 5.0% of the disinfectant residuals in the distribution system below acceptable levels for two consecutive months? - see (1A) and (1B)	NO		

\* A sample copy of the Notice to the customers must accompany this report.

# MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **September 2022**

LOCATION: **Bee Cave Woods**

I.D. #: **2270016**

		METER #07914810	SIZE 6"	METER #18713312	SIZE 3"	TOTAL FLOW	TOTAL GAL PURCHASED	CHLORINE RESIDUAL
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL	MG	mg/L
Thu	1	879363	422.0	87678	168.0	590.0	0.605	2.1
Fri	2	879785	250.0	87846	150.0	400.0	0.409	2.1
Sat	3	880035	250.0	87996	151.0	401.0	0.410	2.3
Sun	4	880285	251.0	88147	151.0	402.0	0.411	2.2
Mon	5	880536	251.0	88298	151.0	402.0	0.412	2.2
Tue	6	880787	420.0	88449	146.0	566.0	0.569	2.2
Wed	7	881207	293.0	88595	144.0	437.0	0.447	2.1
Thu	8	881500	332.0	88739	135.0	467.0	0.472	2.3
Fri	9	881832	277.0	88874	151.0	428.0	0.434	2.2
Sat	10	882109	277.0	89025	152.0	429.0	0.435	2.0
Sun	11	882386	278.0	89177	152.0	430.0	0.437	2.1
Mon	12	882664	372.0	89329	160.0	532.0	0.533	2.1
Tue	13	883036	438.0	89489	128.0	566.0	0.571	2.4
Wed	14	883474	452.0	89617	151.0	603.0	0.634	2.3
Thu	15	883926	465.0	89768	144.0	609.0	0.623	2.3
Fri	16	884391	334.0	89912	147.0	481.0	0.501	2.1
Sat	17	884725	335.0	90059	147.0	482.0	0.502	2.5
Sun	18	885060	335.0	90206	147.0	482.0	0.502	2.2
Mon	19	885395	417.0	90353	165.0	582.0	0.619	2.1
Tue	20	885812	503.0	90518	123.0	626.0	0.643	2.3
Wed	21	886315	546.0	90641	163.0	709.0	0.719	2.3
Thu	22	886861	527.0	90804	156.0	683.0	0.714	2.2
Fri	23	887388	377.0	90960	148.0	525.0	0.537	2.2
Sat	24	887765	378.0	91108	149.0	527.0	0.540	1.8
Sun	25	888143	378.0	91257	149.0	527.0	0.540	2.0
Mon	26	888521	421.0	91406	137.0	558.0	0.573	2.2
Tue	27	888942	515.0	91543	138.0	653.0	0.684	2.2
Wed	28	889457	517.0	91681	161.0	678.0	0.709	1.9
Thu	29	889974	506.0	91842	153.0	659.0	0.690	2.1
Fri	30	890480	369.0	91995	148.0	517.0	0.548	2.3
Sat	1	890849		92143				
Total			11486.0		4465.0	15951.0	16.4	
Avg.			382.9		148.8	531.7	0.547	2.2
Max.			546.0		168.0	709.0	0.719	2.5
Min.			250.0		123.0	400.0	0.409	1.8

Operator: \_\_\_\_\_

# MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **September 2022**

LOCATION: **Riley MM**

I.D. #: **2270016**

		METER No S/N	SIZE 6"	METER No S/N	SIZE 3"	TOTAL FLOW
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL
Thu	1	471	0.0	2972	15.0	15.0
Fri	2	471	0.0	2987	9.0	9.0
Sat	3	471	0.0	2996	9.0	9.0
Sun	4	471	0.0	3005	9.0	9.0
Mon	5	471	0.0	3014	10.0	10.0
Tue	6	471	0.0	3024	3.0	3.0
Wed	7	471	0.0	3027	10.0	10.0
Thu	8	471	0.0	3037	5.0	5.0
Fri	9	471	0.0	3042	6.0	6.0
Sat	10	471	0.0	3048	6.0	6.0
Sun	11	471	0.0	3054	7.0	7.0
Mon	12	471	0.0	3061	1.0	1.0
Tue	13	471	0.0	3062	5.0	5.0
Wed	14	471	0.0	3067	31.0	31.0
Thu	15	471	0.0	3098	14.0	14.0
Fri	16	471	0.0	3112	20.0	20.0
Sat	17	471	0.0	3132	20.0	20.0
Sun	18	471	0.0	3152	20.0	20.0
Mon	19	471	0.0	3172	37.0	37.0
Tue	20	471	0.0	3209	17.0	17.0
Wed	21	471	0.0	3226	10.0	10.0
Thu	22	471	0.0	3236	31.0	31.0
Fri	23	471	0.0	3267	12.0	12.0
Sat	24	471	0.0	3279	13.0	13.0
Sun	25	471	0.0	3292	13.0	13.0
Mon	26	471	0.0	3305	15.0	15.0
Tue	27	471	0.0	3320	31.0	31.0
Wed	28	471	0.0	3351	28.0	28.0
Thu	29	471	0.0	3379	18.0	18.0
Fri	30	471	0.0	3397	24.0	24.0
Sat	1	471		3421		
Total			0.0		449.0	449.0
Avg.			0.0		15.0	15.0
Max.			0.0		37.0	37.0
Min.			0.0		1.0	1.0

Operator: \_\_\_\_\_

# MASTER METER REPORT

DISTRICT: **City of Rollingwood**

MONTH: **September 2022**

LOCATION: **Hatley MM**

I.D. #: **2270016**

		METER No S/n	SIZE 6"	METER #151074A	SIZE 3"	TOTAL FLOW
DAY	DATE	A	TH GAL	B	TH GAL	TH GAL
Thu	1	78	0.0	6826	0.0	0.0
Fri	2	78	0.0	6826	0.0	0.0
Sat	3	78	0.0	6826	0.0	0.0
Sun	4	78	0.0	6826	0.0	0.0
Mon	5	78	0.0	6826	0.0	0.0
Tue	6	78	0.0	6826	0.0	0.0
Wed	7	78	0.0	6826	0.0	0.0
Thu	8	78	0.0	6826	0.0	0.0
Fri	9	78	0.0	6826	0.0	0.0
Sat	10	78	0.0	6826	0.0	0.0
Sun	11	78	0.0	6826	0.0	0.0
Mon	12	78	0.0	6826	0.0	0.0
Tue	13	78	0.0	6826	0.0	0.0
Wed	14	78	0.0	6826	0.0	0.0
Thu	15	78	0.0	6826	0.0	0.0
Fri	16	78	0.0	6826	0.0	0.0
Sat	17	78	0.0	6826	0.0	0.0
Sun	18	78	0.0	6826	0.0	0.0
Mon	19	78	0.0	6826	0.0	0.0
Tue	20	78	0.0	6826	0.0	0.0
Wed	21	78	0.0	6826	0.0	0.0
Thu	22	78	0.0	6826	0.0	0.0
Fri	23	78	0.0	6826	0.0	0.0
Sat	24	78	0.0	6826	0.0	0.0
Sun	25	78	0.0	6826	0.0	0.0
Mon	26	78	0.0	6826	0.0	0.0
Tue	27	78	0.0	6826	0.0	0.0
Wed	28	78	0.0	6826	0.0	0.0
Thu	29	78	0.0	6826	0.0	0.0
Fri	30	78	0.0	6826	0.0	0.0
Sat	1	78		6826		
Total			0.0		0.0	0.0
Avg.			0.0		0.0	0.0
Max.			0.0		0.0	0.0
Min.			0.0		0.0	0.0

Operator: \_\_\_\_\_



Texas Commission on Environmental Quality	Office of Water	Public Drinking Water Section
County Map of TX	Water System Search	Office of Compliance and Enforcement

Water System Detail			
Water System Facilities	Violations	Enforcement Actions	TCR Sample Results
Source Water Assessment Results	Assistance Actions	Recent Positive TCR Results	TTHM HAA5 Summaries
Sample Points	Compliance Schedules	Other Chemical Results	PBCU Summaries
Sample Schedules / FANLs / Plans	TOC/Alkalinity Results	Chemical Results: Sort by: Name Code	Chlorine Summaries
Site Visits Milestones	LRAA (TTHM/HAA5)	Recent Non-TCR Sample Results	Turbidity Summaries
Operators All POC			TCR Sample Summaries
Glossary		DWW Instructions	

Water System Detail Information			
Water System No.:	TX2270016	Federal Type:	C
Water System Name:	CITY OF ROLLINGWOOD	Federal Source:	SWP
Principal County Served:	TRAVIS	System Status:	A
Principal City Served:		Activity Date:	01-01-1913

*Lead*

### Result List by Analyte

Analyte Code	Analyte Name	Facility	Sample Point	Sample Collection Date	TCEQ Sample ID	Laboratory Sample ID	Method	Less Than Ind.	Level Type	Reporting Level	Concentration	Current Maximum Contaminant Level Allowed (MCL)
1030	LEAD	DS01	LCR009	09/19/2022		F031325-03	200.8	<	MRL	0.000412 MG/L		No MCL for this Analyte
1030	LEAD	DS01	LCR019	09/16/2022		F031325-05	200.8	<	MRL	0.000412 MG/L		No MCL for this Analyte
1030	LEAD	DS01	LCR025	09/16/2022		F031325-02	200.8	<	MRL	0.000412 MG/L		No MCL for this Analyte
1030	LEAD	DS01	LCR024	09/16/2022		F031325-01	200.8				0.00137 MG/L	No MCL for this Analyte
1030	LEAD	DS01	LCR022	09/15/2022		F031325-06	200.8	<	MRL	0.000412 MG/L		No MCL for this Analyte
1030	LEAD	DS01	LCR010	09/15/2022		F031325-04	200.8	<	MRL	0.000412 MG/L		No MCL for this Analyte
1030	LEAD	DS01	LCR023	09/14/2022		F031325-07	200.8	<	MRL	0.000412 MG/L		No MCL for this Analyte
1030	LEAD	DS01	LCR007	09/08/2022		F030066-02	200.8	<	MRL	0.000412 MG/L		No MCL for this Analyte
1030	LEAD	DS01	LCR018	09/08/2022		F030066-01	200.8	<	MRL	0.000412 MG/L		No MCL for this Analyte
1030	LEAD	DS01	LCR020	09/07/2022		F030066-03	200.8	<	MRL	0.000412 MG/L		No MCL for this Analyte
1030	LEAD	DS01	LCR007	09/30/2019		Q1969956002	200.8	<	MRL	0.001 MG/L		No MCL for this Analyte
1030	LEAD	DS01	LCR002	09/27/2019		Q1969956001	200.8	<	MRL	0.001 MG/L		No MCL for this Analyte
1030	LEAD	DS01	LCR013	09/27/2019		Q1969956006	200.8	<	MRL	0.001 MG/L		No MCL for this Analyte
1030	LEAD	DS01	LCR017	09/25/2019		Q1969956007	200.8	<	MRL	0.001 MG/L		No MCL for this Analyte
1030	LEAD	DS01	LCR008	09/25/2019		Q1969956003	200.8	<	MRL	0.001 MG/L		No MCL for this Analyte
1030	LEAD	DS01	LCR020	09/25/2019		Q1969956010	200.8	<	MRL	0.001		No MCL for



Texas Commission on Environmental Quality	Office of Water	Public Drinking Water Section
County Map of TX	Water System Search	Office of Compliance and Enforcement

Water System Detail			
Water System Facilities	Violations	Enforcement Actions	TCR Sample Results
Source Water Assessment Results	Assistance Actions	Recent Positive TCR Results	TTHM HAA5 Summaries
Sample Points	Compliance Schedules	Other Chemical Results	PBCU Summaries
Sample Schedules / FANLs / Plans	TOC/Alkalinity Results	Chemical Results: Sort by: Name Code	Chlorine Summaries
Site Visits Milestones	LRAA (TTHM/HAA5)	Recent Non-TCR Sample Results	Turbidity Summaries
Operators All POC			TCR Sample Summaries
Glossary		DWW Instructions	

Water System Detail Information			
Water System No.:	TX2270016	Federal Type:	C
Water System Name:	CITY OF ROLLINGWOOD	Federal Source:	SWP
Principal County Served:	TRAVIS	System Status:	A
Principal City Served:		Activity Date:	01-01-1913

*Copper*

Result List by Analyte

Analyte Code	Analyte Name	Facility	Sample Point	Sample Collection Date	TCEQ Sample ID	Laboratory Sample ID	Method	Less Than Ind.	Level Type	Reporting Level	Concentration	Current Maximum Contaminant Level Allowed (MCL)
1022	COPPER, FREE	DS01	LCR009	09/19/2022		F031325-03	200.8				0.00417 MG/L	No MCL for this Analyte
1022	COPPER, FREE	DS01	LCR019	09/16/2022		F031325-05	200.8				0.00506 MG/L	No MCL for this Analyte
1022	COPPER, FREE	DS01	LCR025	09/16/2022		F031325-02	200.8				0.0122 MG/L	No MCL for this Analyte
1022	COPPER, FREE	DS01	LCR024	09/16/2022		F031325-01	200.8				0.0794 MG/L	No MCL for this Analyte
1022	COPPER, FREE	DS01	LCR022	09/15/2022		F031325-06	200.8				0.00183 MG/L	No MCL for this Analyte
1022	COPPER, FREE	DS01	LCR010	09/15/2022		F031325-04	200.8				0.00379 MG/L	No MCL for this Analyte
1022	COPPER, FREE	DS01	LCR023	09/14/2022		F031325-07	200.8				0.00376 MG/L	No MCL for this Analyte
1022	COPPER, FREE	DS01	LCR007	09/08/2022		F030066-02	200.8				0.00379 MG/L	No MCL for this Analyte
1022	COPPER, FREE	DS01	LCR018	09/08/2022		F030066-01	200.8	<	MRL	0.000515 MG/L		No MCL for this Analyte
1022	COPPER, FREE	DS01	LCR020	09/07/2022		F030066-03	200.8				0.00514 MG/L	No MCL for this Analyte
1022	COPPER, FREE	DS01	LCR007	09/30/2019		Q1969956002	200.8				0.02 MG/L	No MCL for this Analyte
1022	COPPER, FREE	DS01	LCR013	09/27/2019		Q1969956006	200.8				0.0015 MG/L	No MCL for this Analyte
1022	COPPER, FREE	DS01	LCR002	09/27/2019		Q1969956001	200.8				0.0035 MG/L	No MCL for this Analyte
1022	COPPER, FREE	DS01	LCR008	09/25/2019		Q1969956003	200.8				0.0035 MG/L	No MCL for this Analyte
1022	COPPER, FREE	DS01	LCR020	09/25/2019		Q1969956010	200.8				0.011 MG/L	No MCL for this Analyte
1022	COPPER, FREE	DS01	LCR019	09/25/2019		Q1969956009	200.8				0.0027 MG/L	No MCL for this Analyte
1022	COPPER, FREE	DS01	LCR018	09/25/2019		Q1969956008	200.8				0.0053 MG/L	No MCL for this Analyte