

Water Report for  
May + June 2023  
for the most part the  
water plant has been  
operating with out incident  
for the months of May  
+ June with ~~May~~ with  
the exception of May 24  
when a power surge occurred  
at the Soda ASH Bld on  
a piece of equipment called  
the Honeywell. The surge  
caused the pumps to start  
and stop 28 times Richard  
was on duty when this occurred  
and was able to get ahead  
of Sarah Ramey and she  
was able to walk him thru  
the Reset procedure for  
the soda ASH Bld  
in the future we are going  
to need UPS for the  
Soda ASH Bld + water plant  
UPS is abbreviation for  
Uninterrupted Power Supply  
we also are still having a  
problem with the Allen  
Bradley + Honeywell  
programming for communications

Between the FCC, Allen,  
Bradley & the Honeywell.  
But for the most part  
The water production &  
distribution is without incident.  
Thanks in part to  
Scheduled routine maintenance  
and cleaning of equipment  
and the Resivior  
and we are in the process  
of putting in place a  
maintenance log book for  
Repairs & Maintenance.