

Saxman Water Report  
November 2023

The month of November has been very busy with ANTHC electrician Dave Reed plugging away at a few of the problems we were still experiencing at the WTP which is tedious and time consuming since we must check all the systems by process of elimination to get to the bottom of the system fault in the CPU programming. The program we are in the process of trying to fix now is the one that gives us our three-day turbidity reading, so for now we as operators must go back manually and find and record every 4hr turbidity reading to get sent off monthly.

The monthly total coliform test was normal and the lead and copper for this month are also normal.

We are also building a stronger workforce for the water plant with the new hire Marlen D. who has a lot of experience in installation and removal of piping systems and is eager to learn more and will be attending classes in the future to become a Certified Water Operator.

The Water Treatment Plant is doing good. The few problems we're trying to sort out in no way effects the quality of our water.

Water Operator, Robert Sero

*Robert Sero 11/09/23*