



Distribution System -- 1st Quarter - January, February, & March 2022

Street Valves and Hydrant Valves Installed (including water main projects and others)

Location	Date Installed	Size ("), Jt	Installed By	Type
Indiana Ave ~121' NW of St. 24th St.	3/21/2022	8" MJ	Buteyn-Peterson	G (vert)
Indiana Ave ~723' East of S.Taylor Dr.	3/29/2022	6" MJ	Buteyn-Peterson	G (vert)
Indiana Ave ~720' East of S.Taylor Dr.	3/29/2022	12" MJ	Buteyn-Peterson	G (vert)

Total Valves Installed = 3

Street Valves and Hydrant Valves Removed

Location	Installed	Abandoned	Type
----------	-----------	-----------	------

Total Valves Removed = 0

Street Valves and Hydrant Valves Abandoned

Location	Installed	Abandoned
----------	-----------	-----------

Total Valves Abandoned = 0

Street Valves and Hydrant Valves Maintained

Location	Maintained	Size	By
----------	------------	------	----

Total Valves Maintained = 0

Hydrants Installed (including water main projects and others)

Location	Installed	Tr Size	Valve
----------	-----------	---------	-------

Total Hydrants Installed = 0

Hydrants Removed (including water main projects and others)

Location	Installed	Removed	Hyd Valve?
----------	-----------	---------	------------

Total Hydrants Removed = 0

Hydrants Abandoned (including water main projects and others)

Location	Installed	Abandoned	Tr Size	Hyd Valve?
----------	-----------	-----------	---------	------------

Total Hydrants Abandoned = 0

Hydrants Maintained/Moved (including water main projects and others)

Location	Installed	Maintained
----------	-----------	------------

Total Hydrants Maintained/Moved = 0

Water Main Breaks

Location	Date	Size
----------	------	------

N.28th St & Michigan Ave	1/7/2022	6"
712 Whitcomb	1/10/2022	6"
2529 S. 15th St.	1/10/2022	6"
N.8th St & Center Ave	1/10/2022	8"
1216 Wilson Ave	1/11/2022	10"
1025 N. 26th St.	1/20/2022	6"
2025 N. 12th St.	1/24/2022	6"
Wilson Ave and Wedemeyer St.	1/25/2022	10"
2805 Henry St	1/26/2022	6"
Ashland Ave and Plymouth Ln	1/26/2022	8'
1019 N. Water St.	1/27/2022	6"
1835 N. 19th St.	1/28/2022	6"
1713 Wisconsin Ave	1/28/2022	6"
2125 S. Memorial Place	2/12/2022	6"
N.28th St. and Michigan Ave	2/15/2022	6"
S.22nd St 150' North of Georgia Ave	2/17/2022	12"
N. 6th St. and Michigan Ave	2/17/2022	6"
S.12th St and Washington Ave	2/22/2022	10"
S.19th St. south of Union Ave	2/23/2022	6"
1736 Marvin Ct	2/24/2022	6"
N.12th St. + Superior Ave	2/25/2022	6"
Washington Ave at Maple Cir	3/2/2022	4"
Erie Ave at N.21st.	3/9/2022	30"

Number of Water Main Breaks=23

SUMMARY

Number of feet of 4 inch water main installed	0.0	water main
Number of feet of 6 inch hydrant lead installed	0.0	
Number of feet of 6 inch water main installed	19.5	
Number of feet of 8 inch water main installed	78.5	
Number of feet of 12 inch water main installed	1717.3	
Number of feet of 16 inch water main installed	0.0	
Number of feet of 20 inch water main installed	0.0	
Number of feet of 24 inch water main installed	0.0	
Number of feet of water main abandoned or removed	1,813	
Number of water main breaks repaired	23	
Number of hydrants installed	0	hydrants
Number of hydrants removed or abandoned	0	
Number of hydrants maintained or moved	0	
Number of street valves installed	3	valves
Number of hydrant valves installed	0	
Number of street valves removed or abandoned	0	
Number of hydrant valves removed or abandoned	0	
Number of valves maintained	0	
Number of water connections installed	9	



WATER MAIN AND APPURTENANCES INSTALLATION -- 1st Quarter - January, February, & March 2022

Water Main Projects (including installation or abandonment of more than 3' of pipe by utility or contractors)

Location: 6" Water Main	Installed	New Valves	New Hyd.	New Hyd Valves	Aband. Valves	Aband. Hyd.	Remove Hyd.	Size Installed	Feet Installed	New Hyd Lead	Size Aband.	Feet. Aband.	Feet. Rem.	By
Marvin Ct and Sauk Trail Rd	1/18/2022	0	0	0	0	0	0	6	19.5	0	6" CIP	20	0	Ute.
Totals:		0	0	0	0	0	0		19.5	0		20	0	

Location: 8" Water Main	Installed	New Valves	New Hyd.	New Hyd Valves	Aband. Valves	Aband. Hyd.	Remove Hyd.	Size "	Feet Installed	New Hyd Lead	Size Aband.	Feet. Aband.	Feet. Rem.	By
Indiana Ave 8" Going east from	3/22/2022	0	0	0	0	0	0	8	7	0	6" CIP	0	0	Buteyn-Peterson
Totals:		0	0	0	0	0	0		78.5	0		78	0	

Location: 12" Water Main	Installed	New Valves	New Hyd.	New Hyd Valves	Aband. Valves	Aband. Hyd.	Remove Hyd.	Size "	Feet Installed	New Hyd Lead	Size Aband.	Feet. Aband.	Feet. Rem.	By
Indiana Ave and north west of S.24th St.	3/21/2022	1	0	0	0	0	0	12	15.3	0	6" CIP	15	0	Buteyn-Peterson
Indiana Ave East of Taylor Dr	3/21/2022	1	0	0	0	0	0	12	113	0	8" CIP	113	0	Buteyn-Peterson
Indiana Ave along Lower Falls Rd	3/22/2022	0	0	0	0	0	0	12	221	0	8" CIP	219	0	Buteyn-Peterson
Indiana Ave and Intersection of S. Taylor Dr	3/24/2022	0	0	0	0	0	0	12	320	0	8" CIP	320	0	H&H
indiana Ave along Lower Falls Rd	3/25/2022	0	0	0	0	0	0	12	77	0	8" CIP	77	0	Buteyn-Peterson
Indiana Ave (S.24th St to S.Taylor Dr)	3/28/2022	0	0	0	0	0	0	12	200	0	8" CIP	200	0	Buteyn-Peterson
Indiana Ave (S.24th St to S.Taylor Dr)	3/29/2022	2	0	0	0	0	0	12	271	0	8" CIP	271	0	Buteyn-Peterson
Indiana Ave (S.24th St to S.Taylor Dr)	3/30/2022	0	0	0	0	0	0	12	500	0	8" CIP	500	0	Buteyn-Peterson
Totals:		4	0	0	0	0	0	96	1717.3	0	0	1715	0	