

Res. No. 122 - 23. By Alderpersons Felde and Filicky-Peneski. January 16, 2023.

A RESOLUTION authorizing the emergency repair and reconstruction of storm sewer and road for the intersection of N. 14<sup>th</sup> Street and Erie Avenue, resulting from a broken storm sewer pipe that caused major erosion and authorizing an adjustment to the 2023 budget to fund the repair.

WHEREAS, on January 5, 2023, staff visually observed pavement failing at the intersection of N.  $14^{th}$  Street and Erie Avenue; and

WHEREAS, this condition necessitated immediate, partial closure of the intersection in all four directions; and

WHEREAS, during their investigation, staff learned that a 36" storm sewer pipe beneath the intersection was broken and that due to the heavy flow of water through the pipe, soil was getting drawn into the pipe leaving behind a large and growing void beneath the pavement; and

WHEREAS, the Director of Public Works has determined that this condition constitutes an emergency endangering public health and welfare and that failure to immediately repair the condition could lead to additional damage and loss; and

WHEREAS, while the necessary work constitutes "public construction" as used in Wis. Stat. § 62.15(1), which would ordinarily require taking and receiving bids, Wis. Stat. § 62.15(1b) authorizes a municipality to forgo public bidding when damage to public facilities creates an emergency in which the public health or welfare of the city is endangered.

NOW, THEREFORE, BE IT RESOLVED: That the Common Council finds that the extensive nature of the eroded conditions at the intersection of N. 14<sup>th</sup> Street and Erie Avenue creates an emergency endangering public health and the welfare of the City.

BE IT FURTHER RESOLVED: That the Director of Public Works is hereby authorized to enter into contract with Buteyn-Peterson Construction Co., Inc. for the repair and reconstruction of storm sewer and intersection pavement.

Suspird Rules Adopt Res

BE IT FURTHER RESOLVED: That the Finance Director/Treasurer is hereby authorized to draw funds not to exceed \$215,000.00 from Account No. 631344-641500 (Stormwater Utility Expense - Storm Sewer Infrastructure) in payment of this contract.

BE IT FURTHER RESOLVED: That the Finance Director/Treasurer is authorized to transfer funds in the amount of \$215,000 in payment of same via the following budget amendment:

INCREASE - Stormwater Fund - Storm Sewer Infrastructure (Account No. 631344-641500)

INCREASE - Stormwater Fund - Interfund Transfers In (Account No. 631-492000)

DECREASE - General Fund - City Administration - Contingency (Account No. 101141-810101)

INCREASE - General Fund - Finance - Interfund Transfers Out (Account No. 101150-811100)

I HEREBY CERTIFY that the foregoing Resolution was duly passed by the Common Council of the City of Sheboygan, Wisconsin, on the \_\_\_\_\_ day of \_\_\_\_\_\_, 20\_\_\_\_. Dated \_\_\_\_\_\_ 20\_\_\_\_. City Clerk Approved \_\_\_\_\_\_ 20\_\_\_\_. Mayor



## BUDGET

Date:	1/5/2023	BPC Authorized Signature:	Aaron Katsma
Proposal Submitted to:	C/O Sheboygan	Data of Assentance	
Contact Name:	Ryan Sazama	<ul> <li>Date of Acceptance:</li> </ul>	
Contact Phone:		Acceptance of Proposal:	
Project Name:	14th ST Storm Repair	Acceptance of Proposal.	

\*Acceptance of Proposal includes acceptance of proposed workscope and terms and conditions, this proposal may be withdrawn if not accepted in 20 days \*BPC will bill on Time and Material Basis

\*Contaminated Price would need to be verified after testing is complete

## 14th and Erie EMERGENCY Storm Sewer Repair Budget

<b>ITEM</b>	DESCRIPTION	<u>QTY</u> <u>UNIT</u>		UNIT PRICE		EXTENDED	
	Mob, Sawcut, Bypass Pump		1 LS	\$	20,000.00	\$	20,000.00
	Traffic Control		1 LS	\$	8,000.00	\$	8,000.00
	Install Pipe and 2 Manholes, connect pipes		1 LS	\$	115,000.00	\$	115,000.00
	Concrete Pavement 9"		1 LS	\$	15,000.00	\$	15,000.00
	Haul Off Contaminated Soil		600 TON	\$	95.00	\$	57,000.00

Total Budget= \$ 215,000.00

## Items not included:

Obtain Permits, Testing, As-built Drawings, Surveying Verify, Expose, Removal, coordination, or relocation of conflicting existing utilities Removal and replacement of unsuitable site soils Utitly Relocation

Please Call us if you have any questions,

Sincerely,

Buteyn-Peterson Construction Aaron Katsma