

Memorandum

Date: September 11, 2026
To: Joe Trueblood, Superintendent
From: Bill Swearingen, Operations Supervisor
Subject: 2026 Lead and Copper Monitoring Update

The Utility has completed its required 2026 lead and copper monitoring. A total of 30 customer sampling sites were tested as part of the monitoring period. The Wisconsin Department of Natural Resources (WDNR) has reviewed the sampling results and confirmed that the Utility has completed its 2026 lead and copper sampling requirements.

The final 90th percentile results were:

Lead: 2.2 µg/L

Copper: 19.7 µg/L

These 90th percentile results were below the applicable action levels for lead and copper.

In addition to completing the required sampling, all customer notifications were mailed within the required 30-day notification period. The Utility has completed the required 2026 lead and copper sampling and customer notification requirements, with no lead or copper 90th percentile action level exceedances.

Looking ahead, Wisconsin has incorporated the federal Lead and Copper Rule Improvements (LCRI) into NR 809, with the new LCRI requirements having a compliance date of November 1, 2027. Utility staff will continue preparing for these requirements, including the upcoming lead sampling requirements for elementary schools and licensed/certified child care facilities.

Final- 2026 Lead and Copper							
No.	Sample Site	Service L/C	Sample Location	Tier	Previous Sample Site	LEAD Results	Copper Results
1	LC12	L/C	Kitchen Faucet	1	Yes	0.69	3
2	LC15	L/C	Kitchen Faucet	1	Yes	0.41	9
3	LC 18	L	Kitchen Faucet	1	Yes	0.95	1.3
4	LC28	L	Kitchen Faucet	1	Yes	0.28	7.5
5	LC31	L	Kitchen Faucet	1	Yes	0.20	0.97
6	LC33	L	Kitchen Faucet	1	Yes	1.40	8.4
7	LC35	L	Kitchen Faucet	1	Yes	2.40	17.4
8	LC36	L	Kitchen Faucet	1	Yes	3.10	4.8
9	LC37	L	Kitchen Faucet	1	Yes	1.60	1.9
10	LC40	L	Kitchen Faucet	1	Yes	1.20	2.8
11	LC41	L	Kitchen Faucet	1	Yes	1.60	12.5
12	LC42	L	Kitchen Faucet	1	Yes	0.49	41.4
13	LC45	L	Kitchen Faucet	1	Yes	1.30	4.8
14	LC48	L	Kitchen Faucet	1	Yes	<0.085	3.3
15	LC50	L	Kitchen Faucet	1	Yes	1.70	19.7
16	LC51	L	Kitchen Faucet	1	Yes	0.28	7.8
17	LC 52	L	Kitchen Faucet	1	Yes	0.18	1.2
18	LC55	L	Kitchen Faucet	1	Yes	0.60	5.5
19	LC56	L	Kitchen Faucet	1	Yes	0.84	6.8
20	LC57	L	Kitchen Faucet	1	Yes	0.29	1.9
21	LC 58	L	Kitchen Faucet	1	no	1.00	10.3
22	LC 59	L	Kitchen Faucet	1	no	0.87	4.1
23	LC 60	L	Kitchen Faucet	1	no	0.62	15.6
24	LC63	L	Kitchen Faucet	1	no	2.20	10.3
25	LC67	L	Kitchen Faucet	1	Yes	0.61	6.8
26	LC 68	L	Kitchen Faucet	1	Yes	0.61	0.75
27	LC69	L	Kitchen Faucet	1	no	0.21	0.92
28	LC 71	L	Kitchen Faucet	1	no	57.30	120
29	LC 72	L	Kitchen Faucet	1	no	1.50	61.3
30	LC 73	L	Kitchen Faucet	1	no	0.18	2.5

90th Percentile Results for Lead and Copper		
	LEAD	Copper
30	57.3	120
29	3.1	61.3
28	2.4	41.4
27	2.2	19.7
26	1.7	17.4
25	1.6	15.6
24	1.6	12.5
23	1.5	10.3
22	1.4	10.3
21	1.3	9
20	1.2	8.4
19	1	7.8
18	0.95	7.5
17	0.87	6.8
16	0.84	6.8
15	0.69	5.5
14	0.62	4.8
13	0.61	4.8
12	0.61	4.1
11	0.60	3.3
10	0.49	3
9	0.41	2.8
8	0.29	2.5
7	0.28	1.9
6	0.28	1.9
5	0.21	1.3
4	0.20	1.2
3	0.18	0.97
2	0.18	0.92
1	<0.085	0.75

90th Percentile