



Distribution System -- November 2022

Street Valves and Hydrant Valves Installed (including water main projects and others)

Location	Date Installed	Size ("), Jt	Installed By	Type
----------	----------------	--------------	--------------	------

Total Valves Installed = 0

Street Valves and Hydrant Valves Removed

Location	Installed	Abandoned	Type
----------	-----------	-----------	------

Total Valves Removed = 0

Street Valves and Hydrant Valves Abandoned

Location	Installed	Abandoned
----------	-----------	-----------

Total Valves Abandoned = 0

Street Valves and Hydrant Valves Maintained

Location	Maintained	Size	By
----------	------------	------	----

Total Valves Maintained = 0

Hydrants Installed (including water main projects and others)

Location	Installed	Tr Size	Valve	By
S.8th St @ Wilson Ave (NW)	11/9/2022	6'	n	SWU

Total Hydrants Installed = 1

Hydrants Removed (including water main projects and others)

Location	Installed	Removed	Hyd Valve?
S. 8th St. at Wilson Ave. (NW)		11/9/2022	n

Total Hydrants Removed = 0

Hydrants Abandoned (including water main projects and others)

Location	Installed	Abandoned	Tr Size	Hyd Valve?
----------	-----------	-----------	---------	------------

Total Hydrants Abandoned = 0

Hydrants Maintained/Moved (including water main projects and others)

Location	Installed	Maintained
----------	-----------	------------

Total Hydrants Maintained/Moved = 0

Water Main Breaks

Location	Date	Size
1230 St. Clair Ave	11/11/2022	30"
2209 S. Business Dr.	11/27/2022	8"

Number of Water Main Breaks= 2

SUMMARY

Number of feet of 4 inch water main installed	0.0	water main
Number of feet of 6 inch hydrant lead installed	0.0	
Number of feet of 6 inch water main installed	0.0	
Number of feet of 8 inch water main installed	0.0	
Number of feet of 12 inch water main installed	0.0	
Number of feet of 16 inch water main installed	0.0	
Number of feet of 20 inch water main installed	0.0	
Number of feet of 24 inch water main installed	0.0	
Number of feet of water main abandoned or removed	0	
Number of water main breaks repaired	2	hydrants
Number of hydrants installed	1	
Number of hydrants removed or abandoned	1	
Number of hydrants maintained or moved	0	valves
Number of street valves installed	0	
Number of hydrant valves installed	0	
Number of street valves removed or abandoned	0	
Number of hydrant valves removed or abandoned	0	
Number of valves maintained	0	
Number of water connections installed	2	



MONTHLY CONSTRUCTION-MAINTENANCE DEPARTMENT REPORT

November 2022

Distribution System Maintenance:

- Repaired water main break on South Business Drive.
- Repaired water main break on N 13th St.
- Aided in the removal of seasonal bulk water boxes at remote locations.
- Replaced hydrant on S 8th St. and Wilson Avenue.
- Worked with Engineering to get measure down information on Indiana Ave.
- Completed seasonal hydrant checks.
- Continued pouring permanent service repair holes for the season.
- Finished annual inventory counting.
- Hauled in fill to replenish stock.

Building/Grounds Maintenance:

- General shop maintenance and cleaning.
- Completed annual mowing at Erie and Horizon sites.
- Aided Operations in repair of a shaft in the East Basin.

Water Quality:

- Completed seasonal dead end hydrant flushing.

Taps:

- 1" tap at 1130 N 10th St. Lead Service was removed from the system.
- 8" tap on Horizon Avenue.

Equipment Maintenance:

- Performed routine maintenance and repairs on construction equipment and vehicle fleet.
- Prepped plow and salter for upcoming winter season.