



MONTHLY DISTRIBUTION DEPARTMENT REPORT

December 2023

Distribution System Maintenance:

- Repaired watermain break on S 16th Street.
- Concrete restoration of water main break service hole.
- Hauled out spoils, and hauled fill back in.
- Worked on winter hydrant checks.

Taps:

- 1" tap at 2103 S 7th Street. Lead service was removed from the system.

Building/Grounds Maintenance:

- General shop maintenance and cleaning.
- Built storage racking and organized pipe yard.
- Cleaned, inspected, and replaced light bulbs at Taylor Hill.
- Aided Operations in the start of Filter #3 and #4 repair work.

Equipment Maintenance:

- Performed routine maintenance and repairs on construction equipment and vehicle fleet.
- Maintenance of concrete trailer.

Engineering:

- Continued work on water main design on Lincoln Avenue project.
- Monthly map and database updates.
- Continued design of Lincoln Ave and S 11th St. LSL project.
- Water service replacement record updates.



Distribution System -- December 2023

Street Valves and Hydrant Valves Installed (including water main projects and others)

Location	Date Installed	Size ("), Jt	Installed By	Type
----------	----------------	--------------	--------------	------

Total Valves Installed = 0

Street Valves and Hydrant Valves Removed

Location	Installed	Abandoned	Type
----------	-----------	-----------	------

Total Valves Removed = 0

Street Valves and Hydrant Valves Abandoned

Location	Installed	Abandoned	Type
----------	-----------	-----------	------

Total Valves Abandoned = 0

Street Valves and Hydrant Valves Maintained

Location	Maintained	Size	By
----------	------------	------	----

Total Valves Maintained = 0

Hydrants Installed (including water main projects and others)

Location	Installed	Tr Size	Valve	By
----------	-----------	---------	-------	----

Total Hydrants Installed = 0

Hydrants Removed (including water main projects and others)

Location	Installed	Removed	Hyd Valve?
----------	-----------	---------	------------

Total Hydrants Removed = 0

Hydrants Abandoned (including water main projects and others)

Location	Installed	Abandoned	Tr Size	Hyd Valve?
----------	-----------	-----------	---------	------------

Total Hydrants Abandoned = 0

Hydrants Maintained/Moved (including water main projects and others)

Location	Installed	Maintained
----------	-----------	------------

Total Hydrants Maintained/Moved = 0

Water Main Breaks

Location	Date	Size
813 S. 16th street	12/7/2023	6"

Number of Water Main Breaks= 1

SUMMARY

Number of feet of 4 inch water main installed	0.0	water main
Number of feet of 6 inch hydrant lead installed	0.0	
Number of feet of 6 inch water main installed	0.0	
Number of feet of 8 inch water main installed	0.0	
Number of feet of 12 inch water main installed	0.0	
Number of feet of 16 inch water main installed	0.0	
Number of feet of 20 inch water main installed	0.0	
Number of feet of 24 inch water main installed	0.0	
Number of feet of water main abandoned or removed	0.0	
Number of water main breaks repaired	1	hydrants
Number of hydrants installed	0	
Number of hydrants removed or abandoned	0	
Number of hydrants maintained or moved	0	valves
Number of street valves installed	0	
Number of hydrant valves installed	0	
Number of street valves removed or abandoned	0	
Number of hydrant valves removed or abandoned	0	
Number of valves maintained	4	
Number of water connections installed	1	

