

Public Works Monthly Report

August 2025

To: *Board of Aldermen*

From: *Dan Formyduval, Director of Public Services*

Sewer

- Responded to 19 sewer calls during the day and 7 after hours.
- Randomly inspected 25 pressure sewer services.
- Completed 140 scheduled inspections of main line lift stations.
- Completed upgrades for 1 commercial and one residential sewer service.
- Replaced 1 duplex sewer control panel.
- Installed 2 residential pressure services.
- Cleaned 12,780 linear feet of gravity sewer in the Highlands neighborhood.
- Cleaned 18 lift stations
- Completed a smoke test of the gravity sewer in Village Point Estates and Ownedon. 13 locations were identified and repaired.

Parks & Streets

- Cleaned out and repaired +/- 1600 feet of ditch in the Green Bay neighborhood.
- Completed the resurfacing of Pender.
- Conducted Tree trimming operations on Shallotte Ave and Highlands Glen.
- Edged Sidewalks in the Highlands.

Construction & Engineering

- Responded to **389** NC811 locate tickets.
- Participated in weekly meetings with contractors working on Price Landing.
- Witnessed the sewer force main tap for the Forest Run project
- Responded to two storm water complaints related to new construction.
- Conducted preconstruction meetings for the Brunswick Pines and Cedar Creek Landing projects.
- Conducted a preconstruction meeting with the Town's contractor for the Hwy 17 12" Force Main project.
- Conducted a pre construction meeting with Spectrum's sub contractors for the over build of Summer's Walk.
- Notified the owner of Summer's Walk of some drainage concerns.
- Completed the first phase of water line relocation for the Price Landing / Mulberry St upgrade.

Fleet Maintenance

- Renewal of vehicle inspections certification.

Police Dept.

- 8 Oil Changes
- 16 Inspections
- 6 Tires Changed
- 7 Minor Repairs

Fire Dept.

- Replaced coolant hose.

- Assisted with setting up mower and tractor for the Fire Training facility.

Maintenance Dept.

- Refurbished sewer pressure washer.
- Completed Weld repairs on large portable air compressor
- 4 vehicle inspections
- 1 oil change
- Repaired coolant leak on Village Point lift station generator
- Replaced Battery charger on Green Bay Lift Station generator.



Root Removal From Gravity Sewer Service