



Permit Number: WA0022403

Permittee: SNOQUALMIE WWTP AND RECLAIM FACILITY

Facility County: King

Receiving Waterbody:

Monitoring Period: 05/01/2023 - 05/31/2023

Outfall: 002 - Reclaimed Water

Version: 1

Week	Monitoring Point	Coagulant Additive Lbs/Day Metered/Recorded	Dissolved Oxygen Milligrams/L (mg/L) Continuous Metered/Recorded	Turbidity (NTU) Measured Continuous Metered/Recorded	Flow Million Gallons/Day Continuous Metered/Recorded	Total Coliforms MPN/100 mL 1/Day Grab	Total Coliforms (7 Day Median) MPN/100 mL 1/Day Calculated
		FIL	002	002	002D	002D	002D
1-M	5/1/23	C	C	C	C	C	C
1-T	5/2/23	C	C	C	C	C	C
1-W	5/3/23	C	C	C	C	C	C
1-Th	5/4/23	C	C	C	C	C	C
1-F	5/5/23	C	C	C	C	C	C
1-Sa	5/6/23	C	C	C	C	C	C
2-Su	5/7/23	C	C	C	C	C	C
2-M	5/8/23	C	C	C	C	C	C
2-T	5/9/23	C	C	C	C	C	C
2-W	5/10/23	C	C	C	C	C	C
2-Th	5/11/23	C	C	C	C	C	C
2-F	5/12/23	C	C	C	C	C	C
2-Sa	5/13/23	C	C	C	C	C	C
3-Su	5/14/23	C	C	C	C	C	C
3-M	5/15/23	C	C	C	C	C	C
3-T	5/16/23	C	C	C	C	C	C
3-W	5/17/23	C	C	C	C	C	C
3-Th	5/18/23	C	C	C	C	C	C
3-F	5/19/23	C	C	C	C	C	C
3-Sa	5/20/23	C	C	C	C	C	C
4-Su	5/21/23	C	C	C	C	C	C
4-M	5/22/23	C	C	C	C	C	C
4-T	5/23/23	8	3.30	0.87	0.64	<1	1
4-W	5/24/23	7	3.10	1.21	0.89	<1	1
4-Th	5/25/23	14	2.76	1.00	0.74	<1	1
4-F	5/26/23	15	1.95	1.05	0.85	<1	1
4-Sa	5/27/23	10	1.95	0.67	0.82	<1	1
5-Su	5/28/23	7	2.22	0.50	0.80	<1	1
5-M	5/29/23	10	1.75	0.43	0.88	<1	1
5-T	5/30/23	16	2.04	1.27	0.84	<1	1
5-W	5/31/23	7	2.28	1.77	0.83	<1	1
Daily Minimum			1.75				
			>= 0.2 (RO)				
Average		10	2.37	.97	.81		
		Report Only	Report Only	<= 2	DL: 1.56		
Maximum		16			0.89		
		Report Only			Report Only		
Daily Maximum				1.77		<1	1
				<= 5 (RO)		<= 23 (RO)	<= 2.2 (RO)

Reporting Codes Used: B - Below Detection Limit/No Detection, C - No Discharge



Permit Number: WA0022403

Permittee: SNOQUALMIE WWTP AND RECLAIM FACILITY

Facility County: King

Receiving Waterbody:

Monitoring Period: 06/01/2023 - 06/30/2023

Outfall: 002 - Reclaimed Water

Version: 1

Week	Monitoring Point	Coagulant Additive Lbs/Day Metered/Recorded	Dissolved Oxygen Milligrams/L (mg/L) Continuous Metered/Recorded	Turbidity (NTU) Measured Continuous Metered/Recorded	Flow Million Gallons/Day Continuous Metered/Recorded	Total Coliforms MPN/100 mL 1/Day Grab	Total Coliforms (7 Day Median) MPN/100 mL 1/Day Calculated
		FIL	002	002	002D	002D	002D
1-Th	6/1/23	13.00	2.56	1.65	0.86	<1	1
1-F	6/2/23	9.00	2.45	2.37	0.82	<1	1
1-Sa	6/3/23	10.00	2.03	1.29	0.84	<1	1
2-Su	6/4/23	13.00	1.93	1.70	0.87	<1	1
2-M	6/5/23	11.00	1.96	1.59	0.43	<1	1
2-T	6/6/23	9.00	1.67	1.28	0.82	5.30	1
2-W	6/7/23	9.00	1.84	1.10	0.84	3.10	1
2-Th	6/8/23	12.00	1.87	0.59	0.87	<1	1
2-F	6/9/23	12.00	1.85	0.64	0.87	<1	1
2-Sa	6/10/23	11.00	1.75	0.69	0.05	<1	1
3-Su	6/11/23	C	C	C	C	C	C
3-M	6/12/23	18.00	1.69	0.77	0.29	<1	1
3-T	6/13/23	9.00	1.54	0.60	0.79	<1	1
3-W	6/14/23	7.00	1.49	1.79	0.04	<1	1
3-Th	6/15/23	C	C	C	C	C	C
3-F	6/16/23	C	C	C	C	C	C
3-Sa	6/17/23	8.00	1.49	0.97	0.05	<1	1
4-Su	6/18/23	C	C	C	C	C	C
4-M	6/19/23	C	C	C	C	C	C
4-T	6/20/23	C	C	C	C	C	C
4-W	6/21/23	C	C	C	C	C	C
4-Th	6/22/23	C	C	C	C	C	C
4-F	6/23/23	C	C	C	C	C	C
4-Sa	6/24/23	C	C	C	C	C	C
5-Su	6/25/23	C	C	C	C	C	C
5-M	6/26/23	C	C	C	C	C	C
5-T	6/27/23	C	C	C	C	C	C
5-W	6/28/23	12.00	1.98	4.83	0.38	<1	1
5-Th	6/29/23	17.00	2.10	1.56	0.80	<1	1
5-F	6/30/23	17.00	2.60	0.69	0.78	<1	1
Daily Minimum			1.49				
			>= 0.2 (RO)				
Average		11.59	2.23	1.42	.61		
		Report Only	Report Only	<= 2	DL: 1.56		
Maximum		18			0.87		
		Report Only			Report Only		
Daily Maximum				4.83		5.3	1
				<= 5 (RO)		<= 23 (RO)	<= 2.2 (RO)

Reporting Codes Used: B - Below Detection Limit/No Detection, C - No Discharge



Permit Number: WA0022403

Permittee: SNOQUALMIE WWTP AND RECLAIM FACILITY

Facility County: King

Receiving Waterbody:

Monitoring Period: 07/01/2023 - 07/31/2023

Outfall: 002 - Reclaimed Water

Version: 1

Week	Monitoring Point	Coagulant Additive Lbs/Day Metered/Recorded	Dissolved Oxygen Milligrams/L (mg/L) Continuous Metered/Recorded	Turbidity (NTU) Measured NTU Continuous Metered/Recorded	Flow Million Gallons/Day Continuous Metered/Recorded	Total Coliforms MPN/100 mL 1/Day Grab	Total Coliforms (7 Day Median) MPN/100 mL 1/Day Calculated
		FIL	002	002	002D	002D	002D
1-Sa	7/1/23	11.00	2.06	0.63	0.76	<1	1
2-Su	7/2/23	14.00	1.99	0.66	0.80	<1	1
2-M	7/3/23	15.00	2.19	0.67	0.80	<1	1
2-T	7/4/23	16.00	2.10	0.66	0.80	<1	1
2-W	7/5/23	12.00	2.32	0.68	0.87	<1	1
2-Th	7/6/23	15.00	1.73	1.11	0.80	<1	1
2-F	7/7/23	14.00	1.81	0.88	0.82	<1	1
2-Sa	7/8/23	12.00	1.89	0.81	0.83	1.00	1
3-Su	7/9/23	19.00	1.96	0.70	0.83	<1	1
3-M	7/10/23	14.00	2.29	0.71	0.88	<1	1
3-T	7/11/23	14.00	1.91	0.64	0.82	<1	1
3-W	7/12/23	17.00	2.05	0.65	0.81	<1	1
3-Th	7/13/23	15.00	2.34	0.47	0.51	<1	1
3-F	7/14/23	15.00	2.20	1.41	0.82	1.00	1
3-Sa	7/15/23	14.00	2.20	0.66	0.81	<1	1
4-Su	7/16/23	16.00	1.96	0.64	0.83	<1	1
4-M	7/17/23	20.00	2.15	0.74	0.80	<1	1
4-T	7/18/23	10.00	2.11	0.58	0.77	<1	1
4-W	7/19/23	11.00	3.23	1.24	0.80	<1	1
4-Th	7/20/23	15.00	2.05	1.28	0.83	<1	1
4-F	7/21/23	13.00	1.57	1.05	0.76	<1	1
4-Sa	7/22/23	16.00	1.47	1.17	0.83	<1	1
5-Su	7/23/23	15.00	1.52	0.80	0.86	<1	1
5-M	7/24/23	11.00	1.33	0.79	0.83	<1	1
5-T	7/25/23	14.00	1.79	0.57	0.81	<1	1
5-W	7/26/23	19.00	1.52	1.12	0.81	<1	1
5-Th	7/27/23	14.00	1.43	1.42	0.79	<1	1
5-F	7/28/23	13.00	1.78	0.52	0.76	<1	1
5-Sa	7/29/23	13.00	1.82	0.48	0.11	<1	1
6-Su	7/30/23	14.00	1.79	0.48	0.80	<1	1
6-M	7/31/23	8.00	1.83	0.62	0.77	<1	1
Daily Minimum			1.33				
			>= 0.2 (RO)				
Average		14.1613	1.94806	0.80129	0.778065		
		Report Only	Report Only	<= 2	DL: 1.56		
Maximum		20			0.88		
		Report Only			Report Only		
Daily Maximum				1.42		1	1
				<= 5 (RO)		<= 23 (RO)	<= 2.2 (RO)

Reporting Codes Used: B - Below Detection Limit/No Detection



Permit Number: WA0022403

Permittee: SNOQUALMIE WWTP AND RECLAIM FACILITY

Facility County: King

Receiving Waterbody:

Monitoring Period: 08/01/2023 - 08/31/2023

Outfall: 002 - Reclaimed Water

Version: 1

Week	Monitoring Point	Coagulant Additive Lbs/Day Metered/Recorded	Dissolved Oxygen Milligrams/L (mg/L) Continuous Metered/Recorded	Turbidity (NTU) Measured NTU Continuous Metered/Recorded	Flow Million Gallons/Day Continuous Metered/Recorded	Total Coliforms MPN/100 mL 1/Day Grab	Total Coliforms (7 Day Median) MPN/100 mL 1/Day Calculated
		FIL	002	002	002D	002D	002D
1-T	8/1/23	19.00	1.96	0.05	0.79	<1	1.00
1-W	8/2/23	19.00	1.92	0.52	0.82	<1	1.00
1-Th	8/3/23	15.00	2.02	0.51	0.90	<1	1.00
1-F	8/4/23	14.00	1.96	0.49	0.85	<1	1.00
1-Sa	8/5/23	15.00	2.52	0.45	0.82	<1	1.00
2-Su	8/6/23	12.00	1.90	0.45	0.83	<1	1.00
2-M	8/7/23	12.00	2.17	0.59	0.26	<1	1.00
2-T	8/8/23	12.00	1.92	1.26	0.77	<1	1.00
2-W	8/9/23	17.00	2.08	0.52	0.88	<1	1.00
2-Th	8/10/23	12.00	1.80	0.76	0.84	<1	1.00
2-F	8/11/23	18.00	1.61	1.96	0.85	<1	1.00
2-Sa	8/12/23	12.00	2.90	0.55	0.87	<1	1.00
3-Su	8/13/23	17.00	1.57	0.57	0.87	<1	1.00
3-M	8/14/23	34.00	1.53	0.60	0.80	<1	1.00
3-T	8/15/23	18.00	2.43	0.50	0.89	<1	1.00
3-W	8/16/23	16.00	2.17	1.35	0.86	<1	1.00
3-Th	8/17/23	12.00	2.18	0.55	0.86	<1	1.00
3-F	8/18/23	11.00	2.87	1.59	0.90	<1	1.00
3-Sa	8/19/23	14.00	2.37	0.60	0.82	<1	1.00
4-Su	8/20/23	15.00	2.85	0.66	0.85	<1	1.00
4-M	8/21/23	16.00	1.89	0.75	0.88	<1	1.00
4-T	8/22/23	13.00	2.39	0.69	0.86	<1	1.00
4-W	8/23/23	12.00	2.60	0.68	0.84	<1	1.00
4-Th	8/24/23	19.00	2.49	0.97	0.82	<1	1.00
4-F	8/25/23	14.00	1.93	1.11	0.79	<1	1.00
4-Sa	8/26/23	20.00	1.70	0.69	0.80	<1	1.00
5-Su	8/27/23	21.00	2.11	0.82	0.86	<1	1.00
5-M	8/28/23	12.00	1.85	0.77	0.88	<1	1.00
5-T	8/29/23	13.00	2.01	0.74	0.83	<1	1
5-W	8/30/23	15.00	2.25	1.65	0.79	<1	1
5-Th	8/31/23	15.00	2.10	0.57	0.82	<1	1
Daily Minimum			1.53				
			>= 0.2 (RO)				
Average		15.6129	2.13065	0.773226	0.822581		
		Report Only	Report Only	<= 2	DL: 1.56		
Maximum		34			0.9		
		Report Only			Report Only		
Daily Maximum				1.96		1	1
				<= 5 (RO)		<= 23 (RO)	<= 2.2 (RO)

Reporting Codes Used: B - Below Detection Limit/No Detection



Permit Number: WA0022403

Permittee: SNOQUALMIE WWTP AND RECLAIM FACILITY

Facility County: King

Receiving Waterbody:

Monitoring Period: 09/01/2023 - 09/30/2023

Outfall: 002 - Reclaimed Water

Version: 1

Week	Monitoring Point	Coagulant Additive Lbs/Day Metered/Recorded	Dissolved Oxygen Milligrams/L (mg/L) Continuous Metered/Recorded	Turbidity (NTU) Measured NTU Continuous Metered/Recorded	Flow Million Gallons/Day Continuous Metered/Recorded	Total Coliforms MPN/100 mL 1/Day Grab	Total Coliforms (7 Day Median) MPN/100 mL 1/Day Calculated
		FIL	002	002	002D	002D	002D
1-F	9/1/23	5.00	2.33	0.68	0.14	<1	1
1-Sa	9/2/23	9.00	2.21	0.51	0.65	<1	1
2-Su	9/3/23	18.00	1.86	0.58	0.84	<1	1
2-M	9/4/23	10.00	1.82	0.75	0.84	<1	1
2-T	9/5/23	18.00	1.68	0.94	0.81	<1	1
2-W	9/6/23	12.00	1.36	0.87	0.78	<1	1
2-Th	9/7/23	17.00	3.02	0.79	0.88	<1	1
2-F	9/8/23	13.00	2.07	0.86	0.79	<1	1
2-Sa	9/9/23	14.00	2.31	0.65	0.80	<1	1
3-Su	9/10/23	17.00	2.02	1.15	0.89	<1	1
3-M	9/11/23	17.00	2.08	1.07	0.86	<1	1
3-T	9/12/23	15.00	2.76	0.71	0.79	<1	1
3-W	9/13/23	12.00	3.58	0.54	0.85	<1	1
3-Th	9/14/23	16.00	2.93	0.48	0.79	<1	1
3-F	9/15/23	15.00	3.35	0.68	0.20	<1	1
3-Sa	9/16/23	C	C	C	C	C	C
4-Su	9/17/23	C	C	C	C	C	C
4-M	9/18/23	C	C	C	C	C	C
4-T	9/19/23	C	C	C	C	C	C
4-W	9/20/23	C	C	C	C	C	C
4-Th	9/21/23	C	C	C	C	C	C
4-F	9/22/23	C	C	C	C	C	C
4-Sa	9/23/23	C	C	C	C	C	C
5-Su	9/24/23	C	C	C	C	C	C
5-M	9/25/23	C	C	C	C	C	C
5-T	9/26/23	C	C	C	C	C	C
5-W	9/27/23	C	C	C	C	C	C
5-Th	9/28/23	C	C	C	C	C	C
5-F	9/29/23	C	C	C	C	C	C
5-Sa	9/30/23	C	C	C	C	C	C
Daily Minimum			1.36				
			>= 0.2 (RO)				
Average		13.87	2.36	.75	.73		
		Report Only	Report Only	<= 2	DL: 1.56		
Maximum		18			0.89		
		Report Only			Report Only		
Daily Maximum				1.15		1	1
				<= 5 (RO)		<= 23 (RO)	<= 2.2 (RO)

Reporting Codes Used: B - Below Detection Limit/No Detection, C - No Discharge