

---

To: Dan Buchholtz  
1301 81st Avenue NE  
Spring Lake Park, MN

From: Bruce Paulson  
Mpls

File: 193806949

Date: May 28, 2024

---

**Reference: Spring Lake Park City Hall Emergency Generator quotes**

Hi Dan,

We received three quotes for the new emergency generator for City Hall. 300kW/375kVA diesel generator. Installation not included in any of the quotes.

The quotes are summarized below. All three quotes meet the specifications, except for the three deviations noted under the Kohler quote. For the quotes to be an apples-to-apples comparison, we would expect Kohler to include the added cost to provide the specified factory testing. We do not have an issue with them using their standard rust-free resin hardware.

<b>Kohler Power Systems, Model 300REOZJ</b>	<b>28-32 week lead time after approved submittals</b>
Generator cost	\$78,367.96
Start-up	\$3,625.20
Customer Training	\$475.00
TES Engineering	\$951.58
TES Customization	\$9,999.70
<u>Freight to Job Site</u>	<u>\$3,610.00</u>
Total Cost	\$97,029.44

Deviations from specifications:

1. Spec 1.06, we don't provide factory testing per spec. We do provide one-hour resistive load test. It can be provided at additional cost.
2. We're providing a rust-free resin hardware in lieu of stainless steel hardware.
3. We're providing Kohler Crème Beige in lieu of custom color. It can be provided at additional cost.

Comments:

Proposed enclosure color in their quote is cream beige. [Confirm color.](#)

Quote includes remote annunciator. [We do not show any wiring. All the wiring needs to be added.](#)

**Interstate Power Systems, MTU Model D300 22-24 week lead time after approved submittals**

Generator cost	\$99,900.00
Crane Service	\$850.00

**NOTE:** Interstate has an MTU D300, 480v, with Level 3 enclosure, and 24 hour tank in stock in Becker, MN in their storage facility. It is subject to prior sale, but can be held with a "pending engineering review" or similar email, letter of intent, etc.

Comments:

Proposed enclosure color in their quote is gray. [Confirm color.](#)

Quote includes remote annunciator. [We do not show any wiring. All the wiring needs to be added.](#)

**Ziegler-Cat, Model D300GC 20-22 week lead time after approved submittals**

Generator cost	\$104,935.00	(does not include jobsite delivery)
----------------	--------------	-------------------------------------

May 28, 2024

Dan Buchholtz

Page 2 of 2

**Reference:** Spring Lake Park City Hall Emergency Generator quotes

Comments:

Confirm their startup includes 2 hour load bank.

Confirm their package has a space heater in the enclosure.

Proposed enclosure color in their quote is white. [Confirm color.](#)

Block heater is 2KW, 240volt. If we took this set, would want to confirm heater is adequate when connected to 208vols.

Quote includes remote annunciator. [We do not show any wiring. All the wiring needs to be added.](#)

Let me know if you have any additional questions.

Thank you.

**Stantec Architecture Inc.**



**Bruce P. Paulson**

Senior Project Manager/Architect

Phone: 612 712 2108

Bruce.Paulson@stantec.com

Attachment: Quotes

c. File