



MINNESOTA DEPARTMENT OF HEALTH
Section of Drinking Water Protection
Sanitary Survey Report



System Name: **Spring Lake Park**

PWSID: **1020029**

System Contact: **Terry Randall, Public Works Director**

Survey Date: **08/31/2023**

Surveyor: **Brian A. Noma, P.E.**

PWS Type: **Community**

Requirements and Recommendations

Water Source

As a reminder, it is required that a well for a community public water supply be located according to distances specified in Minn.Rules 4725.4450, including not less than 50 feet from a source of contamination including buried sewers (except as specified in Minn. Rules 4725.5850).

Pumps/Pump Facilities and Controls

No deficiencies observed.

Treatment

No deficiencies observed.

Water Storage

No deficiencies observed.

Distribution

It is recommended that dead ends in the distribution system be minimized by looping. If looping is not feasible, a fire hydrant, approved flushing hydrant or blow off for flushing purposes must be used at the dead ends to maintain water quality and/or chlorine residual. [Recommended Standards for Water Works 8.0]

Monitoring/Reporting Data Verification

The following applicable records are required to be maintained by the water supply system:

- a. Coliform bacteria results - 5 years
- b. Chlorine residual results - 5 years
- c. Chemical analysis results - 10 years
- d. Sanitary survey reports - 10 years
- e. All lead and copper materials - 12 years
- f. Consumer confidence reports - 3 years
- g. Public Notices - 3 years
- h. Fluoride quarterly results and monthly reports - 1 year



MINNESOTA DEPARTMENT OF HEALTH
Section of Drinking Water Protection
Sanitary Survey Report



System Name: **Spring Lake Park**

PWSID: **1020029**

System Contact: **Terry Randall, Public Works Director**

Survey Date: **08/31/2023**

Surveyor: **Brian A. Noma, P.E.**

PWS Type: **Community**

Requirements and Recommendations

Water System Management/Operation

Public water supplies are required to maintain effective security measures to protect physical infrastructure and operational practices. This includes security of the physical infrastructure and related operational practices and institutional controls. Listed below are the security concerns that must be identified and addressed:

- a. Intrusion deterrents such as physical barriers, lighting, camera, alarms, and sturdy locking hardware with hardened protective covers for all facilities and components.
- b. Computer based control technologies such as SCADA must be secured from unauthorized physical access and potential cyber attacks.
- c. Safe delivery, handling and storage of chemicals.
- d. Redundancy and enhanced security features to eliminate single point of failure.

[ANSI/AWWA G430-14(R20) and Recommended Standards for Water Works 2.19]

To ensure security, it is recommended that a daily check of critical system components be conducted, including confirmation that all doors and access hatches are locked.

Engineering plans for new, modifications to, or additions to the water supply system, including watermains, are required to be properly submitted to the Minnesota Department of Health for review. All plans must be approved prior to the start of construction. [Minn. Rules 4720.0010]

Operator Compliance with State Requirements

The certified operators are required to qualify themselves by attending waterworks operators training seminars offered throughout the state. Continuing education is valuable experience for anyone engaged in this field. The required contact hours in the previous 3 years for certification renewal are:

Class A 32 contact hours

Class B 24 contact hours

Class C 16 contact hours

Class D 8 contact hours

Class E 4 contact hours

[Minn. Rules 9400.1200]



MINNESOTA DEPARTMENT OF HEALTH
Section of Drinking Water Protection
Sanitary Survey Report



System Name: Spring Lake Park	Survey Date: 08/31/2023
PWSID: 1020029	Surveyor: Brian A. Noma, P.E.
System Contact: Terry Randall, Public Works Director	PWS Type: Community

Bacteriological Results and Chlorine Residuals

<u>Date</u>	<u>Sampling Location</u>	<u>Chlorine Residual</u> <u>Free / Total</u>	<u>Coliform</u> <u>Bacteria</u>	<u>E.Coli</u>
08/31/2023	City Hall	/ 0.66	Absent	
08/31/2023	Well #5	/	Absent	
08/31/2023	Fire Station #1	/ 0.38	Absent	
08/31/2023	Hyvee Station	/ 0.14	Absent	
08/31/2023	LYONS CLUB	/ 0.75	Absent	
08/31/2023	EMMANUEL CHURCH	/ 0.91	Absent	
08/31/2023	WELL #1	/	Absent	