



# City of Stevenson

Leana Kinley, City Administrator

Phone (509)427-5970  
FAX (509) 427-8202

7121 E Loop Road, PO Box 371  
Stevenson, Washington 98648

To: Stevenson City Council  
From: Karl Russell, Public Works Director and Leana Kinley, City Administrator  
RE: Sewer Plant Update  
Meeting Date: October 21, 2021

## **Executive Summary:**

This is an overview of items staff has been working on over the past month in line with the direction council gave to staff.

## **Overview of Items:**

One of our current Group 1 waste water treatment operators will be striving for their Group 2 certification in November/December of this year. Continuing inflow and Infiltration (I&I) mitigation on the School Street sewer line is scheduled for completion by the end of this year.

## **Plant Operations:**

The average monthly Influent BOD load has been:

### **2018**

- January 675 lbs/day – No Effluent Violations
- February 1,793 lbs/day – No Effluent Violations
- March 1,099 lbs/day – BOD and TSS Effluent Violations
- April 991 lbs/day – BOD and TSS Effluent Violations
- May 1,265 lbs/day – BOD and TSS Effluent Violations
- June 1,124 lbs/day – No Effluent Violations
- July 920 lbs/day – Low pH Violation (one day)
- August 1,113 lbs/day – No Effluent Violations
- September 1,439 lbs/day – Low pH Violation (one day)
- October 1,072 lbs/day – No Effluent Violations
- November 1,032 lbs/day – No Effluent Violations
- December 807 lbs/day – No Effluent Violations

### **2019**

- January 776 lbs/day – Solids washout from clarifiers on 29<sup>th</sup> and 30<sup>th</sup>, TSS and BOD Effluent Violations
- February 749 lbs/day – Solids washout from clarifiers on the 18<sup>th</sup>.
- March 803 lbs/day – Solids washout from clarifiers on March 13<sup>th</sup>, TSS Effluent Violation
- April 589 lbs/day – Solids washout from clarifiers on April 1<sup>st</sup>
- May 1,067 lbs/day – No Effluent Violations
- June 897 lbs/day – No Effluent Violations
- July 785 lbs/day – No Effluent Violations
- August 833 lbs/day – No Effluent Violations
- September 720 lbs/day – No Effluent Violations

- October 810 lbs/day – No Effluent Violations
- November 620 lbs/day – No Effluent Violations
- December 588 lbs/day- No Effluent Violations

#### 2020

- January 417 lbs/day- No Effluent Violations
- February 270 lbs/day- No Influent/Effluent Violations, Inf Flow Total 7.532 Mil/Gal.
- March 324 Lbs/day No Influent/Effluent Violations, Inf Flow Total 4.223 Mil/Gal.
- April 389 lbs/day No Influent/Effluent Violations, Inf Flow Total 3.852 Mil/Gal.
- May 295 lbs/day No influent/Effluent Violations, Inf Flow Total 3.315 Mil/Gal.
- June 502 lbs/day No Influent/Effluent Violations, Inf Flow Total 4.788 Mil/Gal.
- July 427 lbs/day No Influent/Effluent Violations, Inf Flow Total 4.048 Mil/Gal.
- August 458 lbs/day No Influent/Effluent Violations, Inf Flow Total 3.941 Mil/Gal.
- September 427 lbs/day No Influent/Effluent Violations, Inf Flow Total 3.786 Mil/Gal.
- October 353 lbs/day No Influent/Effluent Violations, Inf Flow Total 4.786 Mil/Gal.
- November 417 lbs/day No Influent/Effluent Violations, Inf Flow Total 8.018 Mil/Gal.
- December 363 lbs/day No Influent/Effluent Violations, Inf Flow Total 9.252 Mil/Gal.

#### 2021

- January 834 lbs/day Influent Violation, no effluent violations, Inf Flow Total 8.988 Mil/Gal.
- February 459 lbs/day No Influent/Effluent Violations, Inf Flow Total 8.618 Mil/Gal.
- March 415 lbs/day No Influent/Effluent Violations Inf Flow Total 4.68 Mil/Gal.
- April 444 lbs/day No Influent/Effluent Violations Inf Flow Total 3.977 Mil/Gal.
- May 533 lbs/day No Influent/Effluent Violations Inf Flow Total 5.139 Mil/Gal.
- June 420 lbs/day No Influent/Effluent Violations Inf Flow Total 5.534 Mil/Gal.
- July 510 lbs/day No Influent/Effluent Violations Inf Flow Total 5.39 Mil/Gal.
- August 499 lbs/day No Influent/Effluent Violations Inf Flow Total 4.73 Mil/Gal.
- September 519 lbs/day No Influent/Effluent Violations Inf Flow Total 3.71 Mil/Gal.

The current permit limit for Influent is 612 lbs/day and the current upgrades in the adopted General Sewer Plan call for a design max monthly BOD loading of 1,611 lbs/day.

#### WWTP Design:

Final design of the WWTP has been completed. Bids for the equipment needed for the WWTP Project were due October 13<sup>th</sup> at 2 P.M. and are currently under review. The project bid is scheduled for December 2021. Crestline Construction is still anticipating starting the Rock Creek Lift Station and Storm Outfall in April of 2022.

#### Funding:

The city's application for \$9.9M in construction funding through the Department of Ecology for the wastewater treatment plant and extension of the sewer line has been approved. It is for a \$931,946 grant, \$9,004,054 loan at 1.5% interest for 30 years (approx. \$375k annual payment). A contract will be in place in 2-3 months and costs can be incurred against the project for reimbursement.

#### Action Needed:

None.