

**CITY OF STEVENSON
ORDINANCE 2020-1164**

**AMENDING THE CITY OF STEVENSON ENGINEERING
STANDARDS VOLUME 1 – DESIGN AND PLANNING,
CHAPTER 5 – WATER, SECTION 5.10 – SERVICES.**

WHEREAS, The *City of Stevenson Engineering Standards for Public Works Construction*, herein after referred to as the “Standards” contain design standards for water services; and

WHEREAS, the current standards do not allow deduct meters; and

WHEREAS, the City has changed sewer billing, adding a surcharge based on wastewater effluent strength for commercial customers, making changes to the Standards necessary; and

WHEREAS, amendments to the Standards are permitted according to Volume 1 – Design and Planning, Chapter 1 – General Planning, Design, and Approval Requirements, Section 1.15; and

WHEREAS, the City has decided a Threshold Determination under the State Environmental Policy Act is not necessary for these amendments; and

AND WHEREAS, the City Council determined that the proposed amendments 1) comply with all applicable laws and rules, and 2) are necessary to promote the health, safety, and welfare of the city.

NOW THEREFORE, THE CITY COUNCIL OF THE CITY OF STEVENSON DO ORDAIN AS FOLLOWS:

Section 1 – Amendment to Standards. The *City of Stevenson Engineering Standards for Public Works Construction*, Volume 1 – Design and Planning, Chapter 5 – Water, Section 5.10 – Services shall be amended by adding the underlined and deleting the ~~struck through~~ text as shown in “Exhibit A”.

Section 2 – Severability. If any section, subsection, sentence, clause, phrase, or other portion of this Ordinance, or its application to any person, is, for any reason, declared invalid, in whole or in part by any court or agency of competent jurisdiction, said decision shall not affect the validity of the remaining portions hereof.

Section 3 – Effective Date. This ordinance shall become effective following passage and publication as provided by law.

PASSED by the City Council of the City of Stevenson and approved by the Mayor this _____ day of _____, 2020.

SIGNED:

ATTEST:

Scott Anderson
Mayor of Stevenson

Leana Kinley
Clerk/Treasurer

APPROVED AS TO FORM:

Kenneth B. Woodrich
City Attorney

Exhibit A

5.10 Services

- A. Locate water services and indicate size. Sizes shall be determined by the City.
- B. On offices, multi-family developments and plats with planter areas provide irrigation services.
- C. Irrigation shall be by separate water main connection and service. ~~No deduct meters.~~
- D. Static service pressures at ground floor elevation shall be determined at all lots/buildings to ensure compliance with system pressure standards.
- E. Plan shall identify lots/buildings where builder/owner should install individual pressure reducing valves. Individual service PRVs are required on customer side of service lines (after water meter box) when service pressures exceed 80 psi inside City limits or 100 psi in the County.
- F. Deduct meters may be allowed on commercial buildings existing prior to December 1, 2020 for the purposes of separating out sewer charges based on water usage. Meters must be compatible with the city's current meter reading infrastructure. Meters, location and installation must be approved by the Public Works Director.