



FIRE LANE MARKED WITH 6" WIDE RED TRAFFIC PAINT STRIPES WITH 4" HIGH LETTERING WITH 1/4" WIDE STROKE WITH THE WORDS "FIRE LANE NO PARKING" AT 25'-0" INTERVALS ALONG BOTH SIDES OF FIRE LANE. FIRE LANE SHALL HAVE MINIMUM WIDTH OF 24'-0", MINIMUM INSIDE TURNING RADIUS OF 26'-0", MINIMUM OUTSIDE TURNING RADIUS OF 50'-0", WITH A MINIMUM VERTICAL CLEARANCE OF 14'-6"

SITE PLAN
SCALE: 1"=20'-0"



ARCHITECT
JOHN G. BEVERLY
P.O. BOX 1990
STEPHENVILLE, TEXAS 76401
(254) 396-9999 M.
john@jgbarch.com

DRAWINGS THIS SHEET:
JOB NUMBER: 23C15
START DATE: 10/27/23
SITE PLAN
REVISIONS:
DATE: 1/6/24
DRAWN BY: J.G.B.

