

LOUISIANA

MUNICIPAL WATER POLLUTION PREVENTION

MWPP



Facility Name:

Goodbee Regional Wastewater
Treatment Facility

LPDES Permit Number:

LA0123269

Agency Interest (AI) Number:

153322

Address:

620 N. Tyler St.
Covington, LA 70433

Physical Location:

Off HWY 1077, North of HWY 190
Covington, LA 70435

Parish:

St. Tammany

(Person Completing Form) Name:

Heather Allen

Title:

Compliance Coordinator
Department of Utilities

Date Completed:

March 12, 2024

INSTRUCTIONS

1. Complete only the sections of the Environmental Audit which apply to your wastewater treatment system. Leave sections that do not apply blank and enter a "0" for the point value.
2. Parts 1 through 7 contain questions for which points may be generated. These points are intended to communicate to the department and the governing body or owner what actions will be necessary to prevent effluent violations. Place the point totals from parts 1 through 7 on the Point Calculation page.
3. Add up the point totals.
4. Submit the Environmental Audit to the governing body or owner for review and approval.
5. The governing body must pass a resolution which contains the following items:
 - a. The resolution or letter must acknowledge the governing body or owner has reviewed the Environmental Audit.
 - b. This resolution must indicate specific actions, if any, will be taken to maintain compliance and prevent effluent violations. Proposed actions should address the parts where maximum or close to maximum points were generated in the Environmental Audit.
 - c. The resolution should provide any other information the governing body deems appropriate.

Permit #: LA0123269

PART I: INFLUENT FLOW/LOADINGS (all plants)

- A.** List the average monthly volumetric flows and BOD loadings received at your facility during the last reporting year.

Column 1 Average Monthly Flow (million gallons per day, MGD)		Column 2 Average Monthly BOD5 Concentration (mg/l)		Column 3 Average Monthly BOD5 Loading (pounds per day, lb/day)
0.0576	x	167	x 8.34 =	80.22
0.0624	x	342	x 8.34 =	177.98
0.0558	x	167	x 8.34 =	77.72
0.0600	x	148	x 8.34 =	74.06
0.0300	x	10	x 8.34 =	2.5
0.0609	x	299	x 8.34 =	151.86
0.0697	x	206	x 8.34 =	119.75
0.0297	x	123	x 8.34 =	30.50
0.0654	x	127	x 8.34 =	69.27
0.0695	x	217	x 8.34 =	125.78
0.0701	x	169	x 8.34 =	98.80
0.0846	x	133	x 8.34 =	93.84

BOD loading = Average Monthly Flow (in MGD) x Average Monthly BOD concentration (in mg/l) x 8.34

- B.** List the design flow and design BOD loading for your facility in the blanks below. If you are not aware of these design quantities, refer to your Operation and Maintenance (O&M) Manual or contact your consulting engineer.

Design Flow, MGD:

0.090

x 0.90 =

0.081

Design BOD, lb/day:

104

x 0.90 =

94

Permit #:

LA0123269

- C.** How many months did the monthly flow (Column 1) to the wastewater treatment facility (WWTF) exceed 90% of design flow? Circle the number of months and the corresponding point total. Write the point total in the box below at the right.

<i>months</i>	0	1	2	3	4	5	6	7	8	9	10	11	12
<i>points</i>	0	0	0	0	0	5	5	5	5	5	5	5	5

Write 0 or 5 in the C point total box 0 C Point Total

- D.** How many months did the monthly flow (Column 1) to the WWTF exceed the design flow? Circle the number of months and corresponding point total. Write the point total in the box below at the right.

<i>months</i>	0	1	2	3	4	5	6	7	8	9	10	11	12
<i>points</i>	0	5	5	10	10	15	15	15	15	15	15	15	15

Write 0, 5, 10 or 15 in the D point total box 0 D Point Total

- E.** How many months did the monthly BOD loading (Column 3) to the WWTF exceed 90% of the design loading? Circle the number of months and corresponding point total. Write the point total in the box below at the right.

<i>months</i>	0	1	2	3	4	5	6	7	8	9	10	11	12
<i>points</i>	0	0	5	5	5	10	10	10	10	10	10	10	10

Write 0, 5, or 10 in the E point total box 10 E Point Total

- F.** How many months did the monthly BOD loading (Column 3) to the WWTF exceed the design loading? Circle the number of months and corresponding point total. Write the point total in the box below at the right.

<i>months</i>	0	1	2	3	4	5	6	7	8	9	10	11	12
<i>points</i>	0	10	20	30	40	50	50	50	50	50	50	50	50

Write 0, 10, 20, 30, 40 or 50 in the F point total box 40 F Point Total

- G.** Add together each point total for C through F and place this sum in the box below at the right.

TOTAL POINT VALUE FOR PART 1: 50 (max = 80)

Also enter this value or 80, whichever is less, on the point calculation table on page 16.

Permit #: LA0123269

PART 2: EFFLUENT QUALITY / PLANT PERFORMANCE

A. List the monthly average effluent BOD and TSS concentrations produced by your facility during the last reporting year.

Month	Column 1 Average Monthly BOD (mg/l)	Column 2 Average Monthly TSS (mg/l)
January	9.0	81.0
February	11.0	41.0
March	24.0	75.0
April	20.0	76.0
May	34.0	70.0
June	73.0	57.0
July	68.0	119.0
August	9.0	6.0
September	8.0	9.0
October	6.0	10.0
November	7.0	10.0
December	5.0	10.0

B. List the monthly average permit limits for your facility in the blanks below.

	Permit Limit		90% of Permit Limit
BOD, mg/l	10	x 0.90 =	9
TSS, mg/l	15	x 0.90 =	13.5

Permit #:

LA0123269

C. Continuous Discharge to Surface Water.

- i.** How many months did the effluent BOD (Column 1) exceed 90% of the permit limits? Circle the number of months and the corresponding point total. Write the point total in the box below at the right.

<i>months</i>	0	1	2	3	4	5	6	7	8	9	10	11	12
<i>points</i>	0	0	10	20	30	40	40	40	40	40	40	40	40

Write 0, 10, 20, 30 or 40 in the i point total box 40 i Point Total

- ii.** How many months did the effluent BOD (Column 1) exceed permit limits? Circle the number of months and corresponding point total. Write the point total in the box below at the right.

<i>months</i>	0	1	2	3	4	5	6	7	8	9	10	11	12
<i>points</i>	0	5	5	10	10	10	10	10	10	10	10	10	10

Write 0, 5, or 10 in the ii point total box 10 ii Point Total

- iii.** How many months did the effluent TSS (Column 2) exceed 90% of the permit limits? Circle the number of months and the corresponding point total. Write the point total in the box below at the right.

<i>months</i>	0	1	2	3	4	5	6	7	8	9	10	11	12
<i>points</i>	0	0	10	20	30	40	40	40	40	40	40	40	40

Write 0, 10, 20, 30 or 40 in the iii point total box 40 iii Point Total

- iv.** How many months did the effluent TSS (Column 2) exceed permit limits? Circle the number of months and corresponding point total. Write the point total in the box below at the right.

<i>months</i>	0	1	2	3	4	5	6	7	8	9	10	11	12
<i>points</i>	0	5	5	10	10	10	10	10	10	10	10	10	10

Write 0, 5, or 10 in the iv point total box 10 iv Point Total

- v.** Add together each point total for i through iv and place this sum in the box below at the right.

TOTAL POINT VALUE FOR PART 2: 100 (max = 100)

Also enter this value or 100, whichever is less, on the point calculation table on page 16.

Permit #:

LA0123269

D. Other Monitoring and Limitations

- i.** At any time in the past year was there an exceedance of a permit limit for other pollutants such as: ammonia-nitrogen, phosphorus, pH, total residual chlorine, or fecal coliform?

√ Check one box.



Yes



No

If Yes, Please describe:

There were exceedances in ammonia-nitrogen, fecal coliform and DO.

- ii.** At any time in the past year was there a "failure" of a Biomonitoring (Whole Effluent Toxicity) test of the effluent?

√ Check one box.



Yes



No

If Yes, Please describe:

Bio-monitoring is not required at this facility.

- iii.** At any time in the past year was there an exceedance of a permit limit for a toxic substance?

√ Check one box.



Yes



No

If Yes, Please describe:

Permit #:

LA0123269

PART 3: AGE OF THE WASTEWATER TREATMENT FACILITY

A. What year was the wastewater treatment facility constructed or last major expansion/improvements completed?

$$\begin{array}{rcccl}
 & & & & \underline{2009, 2023} \\
 \text{Current Year} & - & \text{Answer to A} & = & \text{Age in years} \\
 \underline{2023} & & \underline{2009 \& 2023} & & \underline{14 \& 0}
 \end{array}$$

Enter Age in Part C below.

B. Check the type of treatment facility that is employed.

	FACTOR:
<input checked="" type="checkbox"/> Mechanical Treatment Plant (trickling filter, activated sludge, etc...) Specify Type: <u>Return activated sludge</u>	2.5
<input type="checkbox"/> Aerated Lagoon	2.0
<input type="checkbox"/> Stabilization Pond	1.5
<input type="checkbox"/> Other Specify Type: _____	1.0

C. Multiply the factor listed next to the type of facility your community employs by the age of your facility to determine the total point value for Part 3.

TOTAL POINT VALUE FOR PART 3 =

$$\frac{2.5}{\text{Factor}} \times \frac{14 \& 0}{\text{Age}} = \boxed{35} \text{ (max = 50)}$$

Also enter this value or 50, whichever is less, on the point calculation table on page 16.

D. Please attach a schematic of the treatment plant.

PART 4: OVERFLOWS AND BYPASSES**A.**

- i. List the number of times in the last year there was an overflow, bypass or unpermitted discharge of untreated or incompletely treated wastewater due to heavy rain:

0 √ Check one box. 0 = 0 points 3 = 15 points
 1 = 5 points 4 = 30 points
 2 = 10 points 5 or more = 50 points

- ii. List the number of bypasses, overflows or unpermitted discharges shown in A (i) that were within the collection system and the number at the treatment plant

Collection System: 0 Treatment Plant: 0

B.

- i. List the number of times in the last year there was an overflow, bypass or unpermitted discharge of untreated or incompletely treated wastewater due to equipment failure, either at the treatment plant or due to pumping problems in the collection system:

3 √ Check one box. 0 = 0 points 3 = 15 points
 1 = 5 points 4 = 30 points
 2 = 10 points 5 or more = 50 points

- ii. List the number of bypasses, overflows or unpermitted discharges shown in B (i) that were within the collection system and the number at the treatment plant

Collection System: 3 Treatment Plant: 0

- C. Specify whether the bypasses came from the city/village/town sewer system or from contract or tributary communities/sanitary districts, etc...

All SSO from Department of Utilities collection system

- D. Add the point values checked for A and B and place the total in the box below.

TOTAL POINT VALUE FOR PART 4: 15 (max = 100)

Also enter this value or 100, whichever is less, on the point calculation table on page 16.

- E. List the person responsible (name and title) for reporting overflows, bypasses or unpermitted discharges to State and Federal authorities:

Christopher Tissue, Director - Department of Utilities

Describe the procedure for gathering, compiling and reporting:

SSO response and reporting per Dept. of Utilities Sewer Treatment and Collection Systems SOP.

Permit #:

LA0123269

PART 5: SEWAGE SLUDGE STORAGE, USE, AND DISPOSAL

A. Sewage Sludge Storage

How many months of sewage sludge storage capacity does your facility have available, either on-site or off-site?

Circle the number of months and the corresponding point total. Write the point total in the box below at the right.

<i>months</i>	<2	2	3	4-5	6
<i>points</i>	50	30	20	10	0

Write 0, 10, 20, 30 or 50 in the A point total box A Point Total

B. For how many months does your facility have approval to use or dispose of sewage sludge at a properly permitted landfill, land application site, or sewage sludge incinerator?

Circle the number of months and the corresponding point total. Write the point total in the box below at the right.

<i>months</i>	<6	6-11	12-23	24-35	>36
<i>points</i>	50	30	20	10	0

Write 0, 10, 20, 30 or 50 in the B point total box B Point Total

C. Add together the A and B point values and place the sum in the box below at the right:

TOTAL POINT VALUE FOR PART 5: (max = 100)

Also enter this value or 100, whichever is less, on the point calculation table on page 16.

Permit #:

LA0123269

PART 6: NEW DEVELOPMENT

A. Please provide the following information for the total of all sewer line extensions which were installed during the last year.

Design Population: N/A

Design Flow: N/A MGD

Design BOD: N/A mg/l

B. Has an industry (or other development) moved into the community or expanded production in the past year, such that either flow or pollutant loadings to the sewerage system were significantly increased (5% or greater)?

√ Check one box. Yes = 15 points No = 0 points

If Yes, Please describe:

List any new pollutants:

N/A

C. Is there any development (industrial, commercial or residential) anticipated in the next 2-3 years, such that either flow or pollutant loadings to the sewerage system could significantly increase?

√ Check one box. Yes = 15 points No = 0 points

If Yes, Please describe:

New residential developments will require an expansion of the treatment plant facility.

Tantella Lakes- 66 lots, Spring Lakes Ph.3 - 42 lots, Spring Lakes Ph.4 - 6 will be 128 lots.

List any new pollutants you anticipate:

N/A

D. Add together the point value checked in B and C and place the sum in the box below.

TOTAL POINT VALUE FOR PART 6: 15 (max = 30)

Also enter this value or 30, whichever is less, on the point calculation table on page 16.

Permit #:

LA0123269

PART 7: OPERATOR CERTIFICATION AND EDUCATION

A. What was the name of the operator-in-charge for the reporting year?

Name: Glenn Daughdrill

B. What is his or her certification number:

Cert.#: 1158

C. What level of certification is the operator-in-charge required to have to operate the wastewater treatment facility?

Level Required: II

D. What is the level of certification of the operator-in-charge?

Level Certified: IV

E. Was the operator-in-charge of the report year certified at least at the grade level required in order to operate this plant?

√ Check one box. Yes = 0 points No = 50 points

Write 0 or 50 in the E point total box E Point Total

F. Has the operator-in-charge maintained recertification requirements during the reporting year?

√ Check one box. Yes No

G. How many hours of continuing education has the operator-in-charge completed over the last two calendar years?

√ Check one box. > 12 hours = 0 points < 12 hours = 50 points

Write 0 or 50 in the G point total box G Point Total

H. Is there a written policy regarding continuing education an training for wastewater treatment plant employees?

√ Check one box. Yes No

Explain: Budget allocated and training schedule set at beginning of each year.

I. What percentage of the continuing education expenses of the operator-in-charge were paid for:

By the permittee? 100% By the operator? 0%

J. Add together the E and G point values and place the sum in the box below at the right.

TOTAL POINT VALUE FOR PART 7: (max = 100)

Also enter this value or 100, whichever is less, on the point calculation table on page 16.

Permit #:

LA0123269

PART 8: FINANCIAL STATUS

A. Are User-Charge Revenues sufficient to cover operation and maintenance expenses?

√ Check one box. Yes No *If No, How are O&M costs financed?*

B. What financial resources do you have available to pay for your wastewater improvements and reconstruction needs?

Revenue generated from the sale of water and sewer services.

PART 9: SUBJECTIVE EVALUATION**A. Collection System Maintenance**

- i. Describe what sewer system maintenance work has been done in the last year.

General maintenance including point repairs of the collections system, force main repairs and lift station pump replacements as needed.

- ii. Describe what lift station work has been done in the last year.

General maintenance, pumps replaced as needed. Typically burned up due to clogging.

- iii. What collection system improvements does the community have under construction for the next 5 years?

None at this time.

B. If you have ponds please answer the following questions: N/A ✓ Check one box.

- | | | |
|---|------------------------------|-----------------------------|
| i. <i>Do you have duckweed buildup in the ponds?</i> | <input type="checkbox"/> Yes | <input type="checkbox"/> No |
| ii. <i>Do you mow the dikes regularly (at least monthly), to the waters edge?</i> | <input type="checkbox"/> Yes | <input type="checkbox"/> No |
| iii. <i>Do you have bushes or trees growing on the dikes or in the ponds?</i> | <input type="checkbox"/> Yes | <input type="checkbox"/> No |
| iv. <i>Do you have excess sludge buildup (> 1foot) on the bottom of any of your ponds?</i> | <input type="checkbox"/> Yes | <input type="checkbox"/> No |
| v. <i>Do you exercise all of your valves?</i> | <input type="checkbox"/> Yes | <input type="checkbox"/> No |
| vi. <i>Are your control manholes in good structural shape?</i> | <input type="checkbox"/> Yes | <input type="checkbox"/> No |
| vii. <i>Do you maintain at least 3 feet of freeboard in all of your ponds?</i> | <input type="checkbox"/> Yes | <input type="checkbox"/> No |
| viii. <i>Do you visit your pond system at least weekly?</i> | <input type="checkbox"/> Yes | <input type="checkbox"/> No |

Permit #:

LA0123269

C. Treatment Plants

i. Have the influent and effluent flow meters been calibrated in the last year?

Yes No (✓ Check one box.)

N/A

Influent flow meter calibration date(s)

1/25/2023

Effluent flow meter calibration date(s)

ii. What problems, if any, have been experienced over the last year that have threatened treatment?

None

iii. Is your community presently involved in formal planning for treatment facility upgrade?

✓ Check one box.



Yes



No

If Yes, Please describe:

Additional 0.10 capacity is in the process of being added for a total of 0.190 MGD. Funding is being applied for to expand the plant to 0.350 MGD.

Permit #:

LA0123269

D. Preventive Maintenance

- i.** Does your plant have a written plan for preventive maintenance on major equipment items?

√ Check one box.

Yes

No

If Yes, Please describe:

As per manufacturer directives in O&M manual, and Department of Utilities SOP

- ii.** Does this preventive maintenance program depict frequency of intervals, types of lubrication and other preventive maintenance tasks necessary for each piece of equipment?

Yes

No

- iii.** Are these preventive maintenance tasks, as well as equipment problems, being recorded and filed so future maintenance problems can be assured properly?

Yes

No

E. Sewer Use Ordinance

- i.** Does your community have a sewer use ordinance that limits or prohibits the discharge of excessive conventional pollutants (BOD, TSS or pH) or toxic substances to the sewer system from industries, commercial users and residences?

√ Check one box.

Yes

No

If Yes, Please describe:

St. Tammany Parish Ordinance Sec. 40-301 - Wastewater standards prior to entering collection systems of parish is the sewer use ordinance that limits the conventional pollutants that can be discharged into the Parish wastewater collection systems by industrial and light industrial customers.

- ii.** Has it been necessary to enforce?

√ Check one box.

Yes

No

If Yes, Please describe:

- iii.** Any additional comments about your treatment plant or collection system? (Attach additional sheets if necessary.)

N/A

Permit #: LA0123269

POINT CALCULATION TABLE

	Actual Values	Maximum
Part 1: <i>Influent Flow/Loadings</i>	<u>50</u>	80 points
Part 2: <i>Effluent Quality / Plant Performance</i>	<u>100</u>	100 points
Part 3: <i>Age of WWTF</i>	<u>35</u>	50 points
Part 4: <i>Overflows and Bypasses</i>	<u>15</u>	100 points
Part 5: <i>Ultimate Disposition of Sludge</i>	<u>40</u>	100 points
Part 6: <i>New Development</i>	<u>15</u>	30 points
Part 7: <i>Operator Certification Training</i>	<u>0</u>	100 points

TOTAL POINTS: 255

ATTACHMENT 3

SAMPLE MWPP RESOLUTION

Resolved that the village/town/city of _____ informs the Louisiana Department of Environmental Quality that the following actions were taken by _____ (governing body).

1. Resolved the Municipal Water Pollution Prevention Environmental Audit Report which is attached to this resolution.
2. Set forth the following actions necessary to maintain permit requirements contained in the Louisiana Pollution Discharge Elimination System (LPDES) permit, number LA_____ .

(Please be specific in listing the actions that will be taken to address the problems identified in the audit report.)

a.

b.

c.

d.

etc..

Passed by a majority/unanimous (circle one) vote of the _____ on _____ (date).



CLERK