

ST. TAMMANY PARISH COUNCIL

RESOLUTION

RESOLUTION COUNCIL SERIES NO.: C-6938

COUNCIL SPONSOR: CAZaubon/COOPER

PROVIDED BY: UTILITIES/CIVIL DIV. ADA

RESOLUTION TO ACKNOWLEDGE THE RECEIPT AND REVIEW OF THE 2023 MUNICIPAL WATER POLLUTION PREVENTION ENVIRONMENTAL AUDIT REPORT FOR THE WEST ST. TAMMANY SEWAGE TREATMENT FACILITY (WARD 1, DISTRICT 3)

WHEREAS, St. Tammany Parish Government owns and operates the West St. Tammany Sewage Treatment Facility; and

WHEREAS, the Louisiana Pollutant Discharge Elimination System (LPDES) permit which authorizes effluent discharge from the West St. Tammany Sewage Treatment Facility mandates the Parish to institute a program directed towards pollution prevention in order to improve operating efficiency and extend the useful life of the treatment facility; and

WHEREAS, as part of Other Conditions, Section H. of LPDES permit LA0120235, the Parish Government must complete an annual Environmental Audit Report for the life of the permit, and said Environmental Audit Report is attached hereto.

THE PARISH OF ST. TAMMANY HEREBY RESOLVES that the St. Tammany Parish Council acknowledges the receipt of the 2023 Municipal Water Pollution Prevention Environmental Audit Report for the West St. Tammany sewage Treatment Facility and its finding that expansion of the treatment plant has been completed.

THIS RESOLUTION HAVING BEEN SUBMITTED TO A VOTE, THE VOTE THEREON WAS AS FOLLOWS:

MOVED FOR ADOPTION BY: _____ SECONDED BY: _____

YEAS:

NAYS:

ABSTAIN:

ABSENT:

THIS RESOLUTION WAS DECLARED ADOPTED ON THE 2ND DAY OF MAY 2024, AT A REGULAR MEETING OF THE PARISH COUNCIL, A QUORUM OF THE MEMBERS BEING PRESENT AND VOTING.

ARTHUR LAUGHLIN, COUNCIL CHAIR

ATTEST:

KATRINA L. BUCKLEY, CLERK OF COUNCIL

Administrative Comment

May 2, 2024

Utilities/Civil Division ADA

Pursuant to the permit authorizing effluent discharge, this Resolution is required to acknowledge the Environmental Audit and identify any compliance actions to be taken. Expansion of the treatment facility has been completed to accommodate future growth in the area. The completed expansion adds 0.75 MGD of treatment capacity to the existing wastewater treatment plant.