



# CITY OF SWEENY

102 W. Ashley Wilson Rd. • PO Box 248 • Sweeny, Texas 77480 • P: (979) 548-3321 • F: (979) 548-7745

## Office of Public Works Updates

### Critical Equipment and Generator Report

<b>Generators</b>	
GST 1	Level Indicators are broken - reading level of water that is in GST
GST2	Level Indicators are broken - reading level of water that is in GST
Auto Bar Screen	Not Working
Clarifier West	Not Working
Chlorine Contact Chamber	Not Working
Lift Station 103 Powell	Needs new electric panel
Lift Station St. Bernard	Needs Pump (only has one)
Lift Station 1459	Needs Pump (only has one)
Lift Station 1459	Needs Pump (only has one)
All Lift Station	Needs Suctioned Out
Sewer Plant	Electrical needs to be fixed
<b>Equipment</b>	
Mini Excavator	Hydraulic Cylinder is leaking. Needs repairs as well as repairs to front bucket
Tractor	Front bucket needs repairs

**\*Daily Checklist will be available in handouts.**

#### Administration

- Daniel Wright is scheduled to take his Class C exam at the end of this month.