



Office of Public Works Update

4/25/2025 DeLane Brown Becomes new Public Works Director.

Work Orders:

Water- 30 Closed, 6 water leaks were repaired.

Sewer- 8 Closed, lines were jetted out.

Streets- 8 Closed, 6 potholes, 1 sign repair and the other was a curb repair.

Gas- 9 Closed, 3 gas leaks repaired

Permits- 15 Closed.

Major Equipment:

Powell lift station was redone and added to the SCATA system.

Pecan lift station needed new belts and the generator needs a new battery

Wastewater Plant Clarifier 2 was drained, cleaned and then refilled to be put back into service.

Wastewater plant Lift station pump 1 and 2 cleaned of rags.

Wastewater plant reclaimed pumps piped in.