



Public Works Updates

Critical Equipment and Generator Report

Generators	
GST 1	Level Indicators are broken - reading level of water that is in GST
GST2	Level Indicators are broken - reading level of water that is in GST
Clarifier West	Not Working/ to my knowledge this has been <u>down awhile</u> ; way before my time
Chlorine Contact Chamber	Not Working/ to my knowledge this system is functional just offline
Lift Station 103 Powell	Needs new electric panel/ we do have a quote for them, just waiting on them to come out to install the new panel
Lift Station St. Bernard	Needs Pump (only has one)
Lift Station 1459	Needs Pump (only has one)
All Lift Stations	Needs Suctioned Out
Sewer Plant	Electrical needs to be fixed/ to my knowledge we have had <u>problems</u> with electrical throughout the plant.
Equipment	
Mini Excavator	Hydraulic Cylinder is leaking. <u>Needs</u> repairs, as well as repairs to front bucket
Tractor	Front bucket needs repairs

*Sorry at this time I have not gotten any quotes for any of this. I will try to have quotes at the next meeting.

Administration

- Daniel Wright has passed his test for Class C Water License.



CITY OF SWEENY

102 W. Ashley Wilson Rd. • PO Box 248 • Sweeny, Texas 77480 • P: (979) 548-3321