



AGENDA MEMO

Business of the City Council City of Sweeny, Texas

Meeting Date	09/17/2024	Agenda Items	
Approved by City Manager		Presenter(s)	David Jordan
Reviewed by City Attorney		Department	Administration
Subject	Critical Equipment Report; Generator Self Activation Report		
Council Strategic Goals	Infrastructure Investment and Government Sustainability		
Attachments / Supporting documents			
Financial Information	Expenditure Required:	N/A	
	Amount Budgeted:	N/A	
	Account Number:		
	Additional Appropriation Required:		
	Additional Account Number:		

Executive Summary

Matt Davenport with Coastal Power products has performed a site visit and evaluation on ALL city owned generators.

The process of repairs has begun.

The Fire station has been repaired and is functioning correctly

Water Plant functioned during the storm but when tested needed new batteries. They have been replaced.

Waste Water Plant did not function during the storm but upon inspection by our staff after the event was found the fuel gauge was stuck and actually had no diesel in it. That has been corrected and is functioning properly.

All the others are going through various repairs and Tex has given Coastal a list of priorities to work on.

The new unit at the Community Center has been installed and should be having final testing this week.

As I stated in the budget meeting, it is my recommendation that these unit have maintenance contract that requires them to be inspected and load tested annually in addition to staff periodic staff inspections.