



## **City of Tenino**

Honorable Mayor and Town Council

Monthly Report of Wastewater Treatment Plant Operations & Maintenance

**Month:** May 2019

During the month of May, the treatment plant continues to perform optimally, all testing parameters are well below permit levels.

### **System Maintenance**

- Regular upkeep.
- Awaiting fabric to install on Effluent infiltrators.
- Installed VFD for Blower #3. All running correctly.
- Reconfiguring turbidimeter setup.

### **Process Changes**

- Decanting Biosolids lagoon to minimal levels, in preparation for dewatering. Less than 1 foot of free water remains on surface.

### **Call Outs-Emergencies**

- There were no call outs or emergencies for the month of May.

### **Communications**

- Continuing discussions with Biosolids coordinator, Meeta Panu. Need to resubmit SAP and biosolids management plan for approval.

### **Miscellaneous**

#### **Flows**

- Influent total flow = 2.88 MG
- Average daily flow = 0.093 MG
- Max daily flow = 0.102 MG
- Total gallons wasted = 45,440 gallons