



## **City of Tenino**

Honorable Mayor and Town Council

Monthly Report of Wastewater Treatment Plant Operations & Maintenance

**Month:** October 2020

During the month of October, the treatment plant continues to perform optimally. All testing parameters are well below permit levels.

### **System Maintenance**

- Regular upkeep.

### **Process Changes**

- Dewatering of biosolids lagoon has begun using Tribeca Transport.
- Returning biosolid lagoon clearwater back to treatment plant.

### **Call Outs-Emergencies**

- There were no call outs or emergencies for the month of October.

### **Communications**

- Influent sampling has been suspended by DOE during the COVID-19 outbreak.
- Replacement MBR filters should be purchased.

### **Miscellaneous**

#### **Flows**

- Influent total flow = 2.93 MG
- Average daily flow = 0.094 MG
- Max daily flow = 0.110 MG
- Total gallons wasted = 70,060 gallons