



City of Tenino

Honorable Mayor and Town Council

Monthly Report of Wastewater Treatment Plant Operations & Maintenance

Month: September 2020

During the month of September, the treatment plant continues to perform optimally. All testing parameters are well below permit levels.

System Maintenance

- Regular upkeep.

Process Changes

- Dewatering of biosolids lagoon has begun using Tribeca Transport.

Call Outs-Emergencies

- There were no call outs or emergencies for the month of September.

Communications

- Influent sampling has been suspended by DOE during the COVID-19 outbreak.

Miscellaneous

Flows

- Influent total flow = 2.880 MG
- Average daily flow = 0.096 MG
- Max daily flow = 0.111 MG
- Total gallons wasted = 63,940 gallons