



**City of Tenino**

Honorable Mayor and Town Council

Monthly Report of Wastewater Treatment Plant Operations & Maintenance

**Month:** June 2021

During the month of June, the treatment plant continues to perform optimally. All testing parameters are well below permit levels.

**System Maintenance**

- Regular upkeep.
- Sludge being removed from waiting pond weekly by hauler.

**Process Changes**

- No longer decanting or transferring from EQ basin – Empty.
- Started washing down sludge in EQ Basin.

**Call Outs-Emergencies**

- There were no call outs or emergencies for the month of June.

**Communications**

**Miscellaneous**

- Sludge removal weekly by hauler.
- Removing of sludge from the storage lagoon remains the most urgent issue at this facility.

**Flows**

- Influent total flow = 2,851,360 gallons
- Average daily flow = 95,050 gallons
- Max daily flow = 107,640 gallons
- Total gallons wasted = 63,000 gallons